

CZ042.3509.4213.0282.01 Bořislav

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	52.35	52.05	51.75	51.45	51.15	50.85	50.70	50.40	50.10	49.80	49.50	49.20	49.05
BSK5	kg/d	20.94	20.82	20.70	20.58	20.46	20.34	20.28	20.16	20.04	19.92	19.80	19.68	19.62
NL	kg/d	19.20	19.09	18.98	18.87	18.76	18.65	18.59	18.48	18.37	18.26	18.15	18.04	17.99
CHSK	kg/d	38.39	38.17	37.95	37.73	37.51	37.29	37.18	36.96	36.74	36.52	36.30	36.08	35.97
Počet EO	os.	349	347	345	343	341	339	338	336	334	332	330	328	327
odp.vod likv.na ČOV	m3/den	32.40	32.25	32.10	31.95	31.80	31.50	31.50	31.20	31.05	30.90	30.75	30.60	30.30
odp.vod likv.v septicích	m3/den	19.95	19.80	19.65	19.50	19.35	19.35	19.20	19.20	19.05	18.90	18.75	18.60	18.75
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY 2018 Žalany														
Množství odpadních vod	m3/den	32.40	32.25	32.10	31.95	31.80	31.50	31.50	31.20	31.05	30.90	30.75	30.60	30.30
BSK5	kg/d	12.96	12.90	12.84	12.78	12.72	12.60	12.60	12.48	12.42	12.36	12.30	12.24	12.12
NL	kg/d	11.88	11.83	11.77	11.72	11.66	11.55	11.55	11.44	11.39	11.33	11.28	11.22	11.11
CHSK	kg/d	23.76	23.65	23.54	23.43	23.32	23.10	23.10	22.88	22.77	22.66	22.55	22.44	22.22
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	0.00 0.00 0.00 0.00 0.00												
Množství vyčišť. odp.vod	m3/den	19.95	19.80	19.65	19.50	19.35	19.35	19.20	19.20	19.05	18.90	18.75	18.60	18.75
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	3.99	3.96	3.93	3.90	3.87	3.87	3.84	3.84	3.81	3.78	3.75	3.72	3.75
NL	kg/d	4.32	4.29	4.26	4.23	4.19	4.19	4.16	4.16	4.13	4.10	4.06	4.03	4.06
CHSK	kg/d	6.65	6.60	6.55	6.50	6.45	6.45	6.40	6.40	6.35	6.30	6.25	6.20	6.25
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	3.99	3.96	3.93	3.90	3.87	3.87	3.84	3.84	3.81	3.78	3.75	3.72	3.75
NL	kg/d	2.99	2.97	2.95	2.93	2.90	2.90	2.88	2.88	2.86	2.84	2.81	2.79	2.81
CHSK	kg/d	7.98	7.92	7.86	7.80	7.74	7.74	7.68	7.68	7.62	7.56	7.50	7.44	7.50
Produkce kalu	m3/r	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0282.02 Bílka

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	5.65	5.50	5.50	5.50	5.50	5.50	5.35	5.35	5.35	5.35	5.35	5.35	5.35
BSK5	kg/d	2.16	2.10	2.10	2.10	2.10	2.10	2.04	2.04	2.04	2.04	2.04	2.04	2.04
NL	kg/d	1.98	1.93	1.93	1.93	1.93	1.93	1.87	1.87	1.87	1.87	1.87	1.87	1.87
CHSK	kg/d	3.96	3.85	3.85	3.85	3.85	3.85	3.74	3.74	3.74	3.74	3.74	3.74	3.74
Počet EO	os.	36	35	35	35	35	35	34	34	34	34	34	34	34
odp.vod likv.na ČOV	m3/den	3.00	3.00	3.00	3.00	3.00	3.00	2.85	2.85	2.85	2.85	2.85	2.85	2.70
odp.vod likv.v septicích	m3/den	2.65	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.65
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Žalany												
Množství odpadních vod	m3/den	3.00	3.00	3.00	3.00	3.00	3.00	2.85	2.85	2.85	2.85	2.85	2.85	2.70
BSK5	kg/d	1.20	1.20	1.20	1.20	1.20	1.20	1.14	1.14	1.14	1.14	1.14	1.14	1.08
NL	kg/d	1.10	1.10	1.10	1.10	1.10	1.10	1.05	1.05	1.05	1.05	1.05	1.05	0.99
CHSK	kg/d	2.20	2.20	2.20	2.20	2.20	2.20	2.09	2.09	2.09	2.09	2.09	2.09	1.98
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišt.odp.vod	m3/den	2.65	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.50	2.65
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.43	0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.43
NL	kg/d	0.48	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.48
CHSK	kg/d	0.70	0.65	0.65	0.65	0.65	0.65	0.65	0.65	0.65	0.65	0.65	0.65	0.70
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.53	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.53
NL	kg/d	0.40	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.40
CHSK	kg/d	1.06	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.06
Produkce kalu	m3/r	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0283.01 Bystřany

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	230.11	231.16	232.16	233.21	234.20	235.20	236.40	237.50	238.49	239.54	240.54	241.53	242.78
BSK5	kg/d	83.98	84.40	84.78	85.20	85.58	85.96	86.44	86.85	87.23	87.65	88.03	88.41	88.88
NL	kg/d	76.98	77.36	77.71	78.10	78.44	78.79	79.23	79.61	79.96	80.34	80.69	81.04	81.47
CHSK	kg/d	153.95	154.72	155.42	156.19	156.89	157.58	158.46	159.22	159.91	160.68	161.38	162.08	162.94
Počet EO	os.	1399	1406	1412	1419	1426	1432	1440	1447	1453	1460	1467	1473	1481
odp.vod likv.na ČOV	m3/den	225.41	226.46	227.46	228.51	229.50	230.50	231.70	232.80	233.79	234.84	235.84	236.83	237.78
odp.vod likv.v septicích	m3/den	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.50
odp.vod likv.jiným způsobem	m3/den	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.50
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT 2018 Nechvalice, 2018 Světlce, 2018 Úpořiny, 2018 Bukovice, 2018 Lbín, 2018 Lhenice, 2018 Lysec, 2018 Mošnov														
Množství odpadních vod	m3/den	11370.78	11315.49	11261.91	11207.27	11153.58	11101.21	11046.92	10992.25	10934.73	10879.88	10825.48	10770.93	10716.75
BSK5	kg/d	4503.02	4481.37	4460.06	4438.39	4417.09	4397.82	4376.34	4354.72	4332.38	4310.69	4289.19	4267.63	4246.07
NL	kg/d	33.11	32.78	32.62	32.40	32.40	30.31	30.20	30.14	29.15	29.10	28.93	28.71	28.71
CHSK	kg/d	66.22	65.56	65.23	64.79	64.79	60.61	60.39	60.28	58.30	58.19	57.86	57.42	57.42
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY														
Množství odpadních vod	m3/den	10.91	10.91	11.01	11.01	11.10	11.20	11.20	11.30	11.39	11.39	11.49	11.58	11.68
BSK5	kg/d	3.01	3.01	3.03	3.03	3.05	3.07	3.07	3.09	3.11	3.11	3.13	3.15	3.17
NL	kg/d	2.75	2.75	2.77	2.77	2.79	2.81	2.81	2.83	2.85	2.85	2.86	2.88	2.90
CHSK	kg/d	5.51	5.51	5.55	5.55	5.58	5.62	5.62	5.66	5.69	5.69	5.73	5.77	5.80
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	11596.20	11541.96	11489.37	11435.77	11383.08	11331.71	11278.62	11225.04	11168.52	11114.72	11061.32	11007.76	10954.53
BSK5	kg/d	4585.26	4564.03	4543.10	4521.85	4500.93	4482.04	4461.04	4439.83	4417.86	4396.60	4375.48	4354.30	4333.08
NL	kg/d	108.46	108.52	108.68	108.85	109.23	107.47	107.80	108.13	107.80	107.80	108.02	108.13	108.46
CHSK	kg/d	216.92	217.03	217.36	217.69	218.46	214.94	215.60	216.26	214.94	215.60	216.04	216.26	216.92
Počet EO	os.	76420	76067	75718	75364	75015	74700	74350	73997	73631	73276	72924	72571	72218
Typ ČOV		ČOV-denitr.+nitr.,s.chem.sr. P												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	2.06 1.39 11.48 10.38 0.92												
Množství vyčištěn.odp.vod	m3/den	11598.55	11544.31	11491.72	11438.12	11385.43	11334.06	11280.97	11227.39	11170.87	11117.07	11063.67	11010.11	10957.03
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	4561.77	4540.65	4519.83	4498.69	4477.88	4459.10	4438.21	4417.11	4395.25	4374.10	4353.09	4332.02	4310.94
NL	kg/d	92.79	92.92	93.15	93.39	93.85	92.16	92.57	92.97	92.39	92.80	93.09	93.27	93.71
CHSK	kg/d	84.45	85.18	86.12	87.06	88.44	85.51	86.78	88.05	87.38	88.66	89.71	90.55	91.87
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	25.23	25.12	25.01	24.90	24.79	24.68	24.57	24.46	24.35	24.24	24.13	24.02	24.00
NL	kg/d	17.27	17.19	17.12	17.05	16.97	16.90	16.83	16.75	16.67	16.60	16.53	16.45	16.45
CHSK	kg/d	135.66	135.04	134.43	133.82	133.21	132.62	132.01	131.40	130.75	130.13	129.52	128.90	128.46
Produkce kalu	m3/r	336.25	334.70	333.16	331.61	330.07	328.68	327.14	325.59	323.98	322.42	320.87	319.32	317.76
Způsob likv.kalu		odvodnění kalů												
Množství kalu po odvodnění	m3/r	275.73	274.45	273.20	271.92	270.66	269.52	268.26	266.99	265.67	264.38	263.11	261.84	260.57

CZ042.3509.4213.0283.02 Nechvalice

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	2.62	2.62	2.76	2.69	2.74	2.66	2.70	2.74	2.65	2.67	2.58	2.60	2.60
BSK5	kg/d	0.38	0.38	0.40	0.40	0.42	0.42	0.44	0.46	0.46	0.48	0.48	0.50	0.52
NL	kg/d	0.35	0.35	0.37	0.37	0.39	0.39	0.40	0.42	0.42	0.44	0.44	0.46	0.48
CHSK	kg/d	0.70	0.70	0.73	0.73	0.77	0.77	0.81	0.84	0.84	0.88	0.88	0.92	0.95
Počet EO	os.	6	6	6	6	7	7	7	7	7	8	8	8	8
odp.vod likv.na ČOV	m3/den	2.62	2.62	2.76	2.69	2.74	2.66	2.70	2.74	2.65	2.67	2.58	2.60	2.60
odp.vod likv.v septicích	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bystřany												
Množství odpadních vod	m3/den	2.62	2.62	2.76	2.69	2.74	2.66	2.70	2.74	2.65	2.67	2.58	2.60	2.60
BSK5	kg/d	0.38	0.38	0.40	0.40	0.42	0.42	0.44	0.46	0.46	0.48	0.48	0.50	0.52
NL	kg/d	0.35	0.35	0.37	0.37	0.39	0.39	0.40	0.42	0.42	0.44	0.44	0.46	0.48
CHSK	kg/d	0.70	0.70	0.73	0.73	0.77	0.77	0.81	0.84	0.84	0.88	0.88	0.92	0.95
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišt.odp.vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Produkce kalu	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0283.03 Nové Dvory

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030										
CELKOVÁ PRODUKCE																								
odpadních vod	m3/den	9.00	8.85	8.85	8.85	8.85	8.85	8.85	8.70	8.70	8.70	8.70	8.70	8.70										
BSK5	kg/d	3.60	3.54	3.54	3.54	3.54	3.54	3.54	3.48	3.48	3.48	3.48	3.48	3.48										
NL	kg/d	3.30	3.25	3.25	3.25	3.25	3.25	3.25	3.19	3.19	3.19	3.19	3.19	3.19										
CHSK	kg/d	6.60	6.49	6.49	6.49	6.49	6.49	6.49	6.38	6.38	6.38	6.38	6.38	6.38										
Počet EO	os.	60	59	59	59	59	59	59	58	58	58	58	58	58										
odp.vod likv.na ČOV	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
odp.vod likv.v septicích	m3/den	9.00	8.85	8.85	8.85	8.85	8.85	8.85	8.70	8.70	8.70	8.70	8.70	8.70										
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
PŘÍTOK NA ČOV																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0										
Typ ČOV		žádná																						
KONCENTRACE NA ODTOKU		stávající a navrhované řešení																						
	-	<table><tr><td>BSK5</td><td>NL</td><td>CHSK</td><td>N-celk</td><td>P-celk</td></tr><tr><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td></tr></table>													BSK5	NL	CHSK	N-celk	P-celk	0.00	0.00	0.00	0.00	0.00
BSK5	NL	CHSK	N-celk	P-celk																				
0.00	0.00	0.00	0.00	0.00																				
	mg/l																							
Množství vyčišt.odp.vod	m3/den	9.00	8.85	8.85	8.85	8.85	8.85	8.85	8.70	8.70	8.70	8.70	8.70	8.70										
ODSTRANĚNÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	1.80	1.77	1.77	1.77	1.77	1.77	1.77	1.74	1.74	1.74	1.74	1.74	1.74										
NL	kg/d	1.95	1.92	1.92	1.92	1.92	1.92	1.92	1.89	1.89	1.89	1.89	1.89	1.89										
CHSK	kg/d	3.00	2.95	2.95	2.95	2.95	2.95	2.95	2.90	2.90	2.90	2.90	2.90	2.90										
ZBYTKOVÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	1.80	1.77	1.77	1.77	1.77	1.77	1.77	1.74	1.74	1.74	1.74	1.74	1.74										
NL	kg/d	1.35	1.33	1.33	1.33	1.33	1.33	1.33	1.31	1.31	1.31	1.31	1.31	1.31										
CHSK	kg/d	3.60	3.54	3.54	3.54	3.54	3.54	3.54	3.48	3.48	3.48	3.48	3.48	3.48										
Produkce kalu	m3/r	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.01	0.01	0.01	0.01	0.01	0.01										
Způsob likv.kalu																								
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										

CZ042.3509.4213.0283.04 Světlce

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	72.00	72.45	72.90	73.35	73.80	74.25	74.70	75.15	75.60	76.05	76.50	76.95	77.40
BSK5	kg/d	28.62	28.80	28.98	29.16	29.34	29.52	29.70	29.88	30.06	30.24	30.42	30.60	30.78
NL	kg/d	26.24	26.40	26.57	26.73	26.90	27.06	27.23	27.39	27.56	27.72	27.89	28.05	28.22
CHSK	kg/d	52.47	52.80	53.13	53.46	53.79	54.12	54.45	54.78	55.11	55.44	55.77	56.10	56.43
Počet EO	os.	477	480	483	486	489	492	495	498	501	504	507	510	513
odp.vod likv.na ČOV	m3/den	72.00	72.45	72.90	73.35	73.80	74.25	74.70	75.15	75.60	76.05	76.50	76.95	77.40
odp.vod likv.v septicích	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bystřany												
Množství odpadních vod	m3/den	68.55	69.00	69.45	69.90	70.35	70.80	71.25	71.55	72.00	72.45	72.90	73.35	73.65
BSK5	kg/d	27.24	27.42	27.60	27.78	27.96	28.14	28.32	28.44	28.62	28.80	28.98	29.16	29.28
NL	kg/d	24.97	25.14	25.30	25.47	25.63	25.80	25.96	26.07	26.24	26.40	26.57	26.73	26.84
CHSK	kg/d	49.94	50.27	50.60	50.93	51.26	51.59	51.92	52.14	52.47	52.80	53.13	53.46	53.68
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		Domovní mikročist., biof.												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	30.0030.00110.0030.006.00												
Množství vyčišt.odp.vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Produkce kalu	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Způsob likv.kalu		neurčeno												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0283.05 Úpořiny

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	23.73	23.73	23.88	23.88	24.03	24.03	24.18	24.18	24.33	24.33	24.48	24.48	24.63
BSK5	kg/d	9.54	9.54	9.60	9.60	9.66	9.66	9.72	9.72	9.78	9.78	9.84	9.84	9.90
NL	kg/d	8.75	8.75	8.80	8.80	8.86	8.86	8.91	8.91	8.97	8.97	9.02	9.02	9.08
CHSK	kg/d	17.49	17.49	17.60	17.60	17.71	17.71	17.82	17.82	17.93	17.93	18.04	18.04	18.15
Počet EO	os.	159	159	160	160	161	161	162	162	163	163	164	164	165
odp.vod likv.na ČOV	m3/den	23.73	23.73	23.88	23.88	24.03	24.03	24.18	24.18	24.33	24.33	24.48	24.48	24.63
odp.vod likv.v septicích	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bystřany, 2018 Bystřany												
Množství odpadních vod	m3/den	23.73	23.73	23.88	23.88	24.03	24.03	24.18	24.18	24.33	24.33	24.48	24.48	24.63
BSK5	kg/d	9.54	9.54	9.60	9.60	9.66	9.66	9.72	9.72	9.78	9.78	9.84	9.84	9.90
NL	kg/d	8.75	8.75	8.80	8.80	8.86	8.86	8.91	8.91	8.97	8.97	9.02	9.02	9.08
CHSK	kg/d	17.49	17.49	17.60	17.60	17.71	17.71	17.82	17.82	17.93	17.93	18.04	18.04	18.15
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV			žádná											
KONCENTRACE NA ODTOKU			stávající a navrhované řešení											
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišt.odp.vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Produkce kalu	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0284.01 Bžany

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	30.30	30.15	30.00	29.85	29.70	29.55	29.40	29.25	29.10	28.95	28.80	28.65	28.50
BSK5	kg/d	11.94	11.88	11.82	11.76	11.70	11.64	11.58	11.52	11.46	11.40	11.34	11.28	11.22
NL	kg/d	10.95	10.89	10.84	10.78	10.73	10.67	10.62	10.56	10.51	10.45	10.40	10.34	10.29
CHSK	kg/d	21.89	21.78	21.67	21.56	21.45	21.34	21.23	21.12	21.01	20.90	20.79	20.68	20.57
Počet EO	os.	199	198	197	196	195	194	193	192	191	190	189	188	187
odp.vod likv.na ČOV	m3/den	24.90	24.90	24.75	24.60	24.45	24.30	24.30	24.15	24.00	23.85	23.70	23.55	23.40
odp.vod likv.v septicích	m3/den	5.40	5.25	5.25	5.25	5.25	5.25	5.10	5.10	5.10	5.10	5.10	5.10	5.10
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY 2018 Hradiště														
Množství odpadních vod	m3/den	24.90	24.90	24.75	24.60	24.45	24.30	24.30	24.15	24.00	23.85	23.70	23.55	23.40
BSK5	kg/d	9.81	9.81	9.75	9.69	9.63	9.57	9.57	9.51	9.45	9.39	9.33	9.27	9.21
NL	kg/d	8.99	8.99	8.94	8.88	8.83	8.77	8.77	8.72	8.66	8.61	8.55	8.50	8.44
CHSK	kg/d	17.99	17.99	17.88	17.77	17.66	17.55	17.55	17.44	17.33	17.22	17.11	17.00	16.89
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	0.00 0.00 0.00 0.00 0.00												
Množství vyčišt.odp.vod	m3/den	5.40	5.25	5.25	5.25	5.25	5.25	5.10	5.10	5.10	5.10	5.10	5.10	5.10
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	1.05	1.02	1.02	1.02	1.02	1.02	0.99	0.99	0.99	0.99	0.99	0.99	0.99
NL	kg/d	1.14	1.11	1.11	1.11	1.11	1.11	1.08	1.08	1.08	1.08	1.08	1.08	1.08
CHSK	kg/d	1.75	1.70	1.70	1.70	1.70	1.70	1.65	1.65	1.65	1.65	1.65	1.65	1.65
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	1.08	1.05	1.05	1.05	1.05	1.05	1.02	1.02	1.02	1.02	1.02	1.02	1.02
NL	kg/d	0.81	0.79	0.79	0.79	0.79	0.79	0.77	0.77	0.77	0.77	0.77	0.77	0.77
CHSK	kg/d	2.16	2.10	2.10	2.10	2.10	2.10	2.04	2.04	2.04	2.04	2.04	2.04	2.04
Produkce kalu	m3/r	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0284.02 Bukovice

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	7.65	7.54	7.54	7.53	7.52	7.36	7.35	7.34	7.33	7.17	7.16	7.15	7.14
BSK5	kg/d	2.78	2.76	2.76	2.76	2.76	2.70	2.70	2.70	2.70	2.64	2.64	2.64	2.64
NL	kg/d	2.55	2.53	2.53	2.53	2.53	2.48	2.48	2.48	2.48	2.42	2.42	2.42	2.42
CHSK	kg/d	5.10	5.06	5.06	5.06	5.06	4.95	4.95	4.95	4.95	4.84	4.84	4.84	4.84
Počet EO	os.	46	46	46	46	46	45	45	45	45	44	44	44	44
odp.vod likv.na ČOV	m3/den	1.95	1.84	1.84	1.83	1.82	1.81	1.80	1.79	1.78	1.77	1.76	1.75	1.74
odp.vod likv.v septicích	m3/den	5.70	5.70	5.70	5.70	5.70	5.55	5.55	5.55	5.55	5.40	5.40	5.40	5.40
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSLUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bystřany												
Množství odpadních vod	m3/den	1.95	1.84	1.84	1.83	1.82	1.81	1.80	1.79	1.78	1.77	1.76	1.75	1.74
BSK5	kg/d	0.50	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48
NL	kg/d	0.46	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44
CHSK	kg/d	0.92	0.88	0.88	0.88	0.88	0.88	0.88	0.88	0.88	0.88	0.88	0.88	0.88
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišť.odp.vod	m3/den	5.70	5.70	5.70	5.70	5.70	5.55	5.55	5.55	5.55	5.40	5.40	5.40	5.40
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	1.14	1.14	1.14	1.14	1.14	1.11	1.11	1.11	1.11	1.08	1.08	1.08	1.08
NL	kg/d	1.24	1.24	1.24	1.24	1.24	1.20	1.20	1.20	1.20	1.17	1.17	1.17	1.17
CHSK	kg/d	1.90	1.90	1.90	1.90	1.90	1.85	1.85	1.85	1.85	1.80	1.80	1.80	1.80
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	1.14	1.14	1.14	1.14	1.14	1.11	1.11	1.11	1.11	1.08	1.08	1.08	1.08
NL	kg/d	0.86	0.86	0.86	0.86	0.86	0.83	0.83	0.83	0.83	0.81	0.81	0.81	0.81
CHSK	kg/d	2.28	2.28	2.28	2.28	2.28	2.22	2.22	2.22	2.22	2.16	2.16	2.16	2.16
Produkce kalu	m3/r	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0284.03 Hradiště

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	27.70	27.55	27.40	27.25	27.10	26.95	26.80	26.65	26.50	26.35	26.20	26.05	26.05
BSK5	kg/d	11.01	10.95	10.89	10.83	10.77	10.71	10.65	10.59	10.53	10.47	10.41	10.35	10.35
NL	kg/d	10.09	10.04	9.98	9.93	9.87	9.82	9.76	9.71	9.65	9.60	9.54	9.49	9.49
CHSK	kg/d	20.19	20.08	19.97	19.86	19.75	19.64	19.53	19.42	19.31	19.20	19.09	18.98	18.98
Počet EO	os.	183	182	181	180	179	178	177	176	175	174	173	172	172
odp.vod likv.na ČOV	m3/den	22.95	22.95	22.80	22.65	22.50	22.35	22.35	22.20	22.05	21.90	21.75	21.60	21.75
odp.vod likv.v septicích	m3/den	4.75	4.60	4.60	4.60	4.60	4.60	4.45	4.45	4.45	4.45	4.45	4.45	4.30
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT 2018 Bžany														
Množství odpadních vod	m3/den	24.90	24.90	24.75	24.60	24.45	24.30	24.30	24.15	24.00	23.85	23.70	23.55	23.40
BSK5	kg/d	9.81	9.81	9.75	9.69	9.63	9.57	9.57	9.51	9.45	9.39	9.33	9.27	9.21
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	47.85	47.85	47.55	47.25	46.95	46.65	46.65	46.35	46.05	45.75	45.45	45.15	45.15
BSK5	kg/d	18.93	18.93	18.81	18.69	18.57	18.45	18.45	18.33	18.21	18.09	17.97	17.85	17.85
NL	kg/d	8.36	8.36	8.31	8.25	8.20	8.14	8.14	8.09	8.03	7.98	7.92	7.87	7.92
CHSK	kg/d	16.72	16.72	16.61	16.50	16.39	16.28	16.28	16.17	16.06	15.95	15.84	15.73	15.84
Počet EO	os.	315	315	313	311	309	307	307	305	303	301	299	297	297
Typ ČOV		Aktivační čistírna												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	3.80 6.30 22.25 0.00 0.00												
Množství vyčišt.odp.vod	m3/den	52.60	52.45	52.15	51.85	51.55	51.25	51.10	50.80	50.50	50.20	49.90	49.60	49.45
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	19.69	19.66	19.54	19.42	19.30	19.18	19.15	19.03	18.92	18.80	18.68	18.56	18.53
NL	kg/d	9.08	9.05	8.99	8.94	8.89	8.83	8.80	8.75	8.69	8.64	8.59	8.54	8.56
CHSK	kg/d	17.22	17.17	17.07	16.96	16.86	16.76	16.71	16.60	16.50	16.40	16.29	16.19	16.25
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	1.13	1.10	1.10	1.10	1.10	1.10	1.07	1.07	1.06	1.06	1.06	1.06	1.03
NL	kg/d	1.01	0.99	0.99	0.99	0.99	0.98	0.96	0.96	0.96	0.96	0.95	0.95	0.93
CHSK	kg/d	2.96	2.90	2.90	2.89	2.88	2.88	2.82	2.81	2.80	2.80	2.79	2.78	2.72
Produkce kalu	m3/r	1.39	1.39	1.39	1.38	1.37	1.36	1.36	1.35	1.34	1.33	1.32	1.31	1.31
Způsob likv.kalu		odvoz na jinou ČOV												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0284.04 Lbín

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	13.74	13.65	13.65	13.50	13.50	13.35	13.35	13.35	13.20	13.20	13.05	13.05	12.99
BSK5	kg/d	5.78	5.76	5.76	5.70	5.70	5.64	5.64	5.64	5.58	5.58	5.52	5.52	5.48
NL	kg/d	5.30	5.28	5.28	5.23	5.23	5.17	5.17	5.17	5.12	5.12	5.06	5.06	5.02
CHSK	kg/d	10.60	10.56	10.56	10.45	10.45	10.34	10.34	10.34	10.23	10.23	10.12	10.12	10.05
Počet EO	os.	96	96	96	95	95	94	94	94	93	93	92	92	91
odp.vod likv.na ČOV	m3/den	1.29	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.29
odp.vod likv.v septicích	m3/den	12.45	12.45	12.45	12.30	12.30	12.15	12.15	12.15	12.00	12.00	11.85	11.85	11.70
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bystřany												
Množství odpadních vod	m3/den	1.29	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.29
BSK5	kg/d	0.80	0.78	0.78	0.78	0.78	0.78	0.78	0.78	0.78	0.78	0.78	0.78	0.80
NL	kg/d	0.73	0.72	0.72	0.72	0.72	0.72	0.72	0.72	0.72	0.72	0.72	0.72	0.73
CHSK	kg/d	1.47	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.47
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišt.odp.vod	m3/den	12.45	12.45	12.45	12.30	12.30	12.15	12.15	12.15	12.00	12.00	11.85	11.85	11.70
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	2.49	2.49	2.49	2.46	2.46	2.43	2.43	2.43	2.40	2.40	2.37	2.37	2.34
NL	kg/d	2.70	2.70	2.70	2.67	2.67	2.63	2.63	2.63	2.60	2.60	2.57	2.57	2.54
CHSK	kg/d	4.15	4.15	4.15	4.10	4.10	4.05	4.05	4.05	4.00	4.00	3.95	3.95	3.90
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	2.49	2.49	2.49	2.46	2.46	2.43	2.43	2.43	2.40	2.40	2.37	2.37	2.34
NL	kg/d	1.87	1.87	1.87	1.85	1.85	1.82	1.82	1.82	1.80	1.80	1.78	1.78	1.76
CHSK	kg/d	4.98	4.98	4.98	4.92	4.92	4.86	4.86	4.86	4.80	4.80	4.74	4.74	4.68
Produkce kalu	m3/r	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0284.05 Lhenice

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030										
CELKOVÁ PRODUKCE																								
odpadních vod	m3/den	12.37	12.25	12.25	12.08	12.05	11.88	11.86	11.84	11.67	11.65	11.47	11.45	11.43										
BSK5	kg/d	4.71	4.69	4.69	4.63	4.63	4.57	4.57	4.57	4.51	4.51	4.45	4.45	4.45										
NL	kg/d	4.32	4.30	4.30	4.24	4.24	4.19	4.19	4.19	4.13	4.13	4.08	4.08	4.08										
CHSK	kg/d	8.64	8.60	8.60	8.49	8.49	8.38	8.38	8.38	8.27	8.27	8.16	8.16	8.16										
Počet EO	os.	78	78	78	77	77	76	76	76	75	75	74	74	74										
odp.vod likv.na ČOV	m3/den	1.72	1.60	1.60	1.58	1.55	1.53	1.51	1.49	1.47	1.45	1.42	1.40	1.38										
odp.vod likv.v septicích	m3/den	10.65	10.65	10.65	10.50	10.50	10.35	10.35	10.35	10.20	10.20	10.05	10.05	10.05										
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bystřany																						
Množství odpadních vod	m3/den	1.72	1.60	1.60	1.58	1.55	1.53	1.51	1.49	1.47	1.45	1.42	1.40	1.38										
BSK5	kg/d	0.45	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43										
NL	kg/d	0.41	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39										
CHSK	kg/d	0.83	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79										
PŘÍTOK NA ČOV																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0										
Typ ČOV		žádná																						
KONCENTRACE NA ODTOKU		stávající a navrhované řešení																						
	-																							
	mg/l	<table><tr><td>BSK5</td><td>NL</td><td>CHSK</td><td>N-celk</td><td>P-celk</td></tr><tr><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td></tr></table>													BSK5	NL	CHSK	N-celk	P-celk	0.00	0.00	0.00	0.00	0.00
BSK5	NL	CHSK	N-celk	P-celk																				
0.00	0.00	0.00	0.00	0.00																				
Množství vyčišť.odp.vod	m3/den	10.65	10.65	10.65	10.50	10.50	10.35	10.35	10.35	10.20	10.20	10.05	10.05	10.05										
ODSTRANĚNÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	2.13	2.13	2.13	2.10	2.10	2.07	2.07	2.07	2.04	2.04	2.01	2.01	2.01										
NL	kg/d	2.31	2.31	2.31	2.28	2.28	2.24	2.24	2.24	2.21	2.21	2.18	2.18	2.18										
CHSK	kg/d	3.55	3.55	3.55	3.50	3.50	3.45	3.45	3.45	3.40	3.40	3.35	3.35	3.35										
ZBYTKOVÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	2.13	2.13	2.13	2.10	2.10	2.07	2.07	2.07	2.04	2.04	2.01	2.01	2.01										
NL	kg/d	1.60	1.60	1.60	1.58	1.58	1.55	1.55	1.55	1.53	1.53	1.51	1.51	1.51										
CHSK	kg/d	4.26	4.26	4.26	4.20	4.20	4.14	4.14	4.14	4.08	4.08	4.02	4.02	4.02										
Produkce kalu	m3/r	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02										
Způsob likv.kalu																								
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										

CZ042.3509.4213.0284.06 Lysec

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	16.90	16.82	16.67	16.67	16.52	16.52	16.37	16.22	16.22	16.07	16.07	15.92	15.85
BSK5	kg/d	6.70	6.68	6.62	6.62	6.56	6.56	6.50	6.44	6.44	6.38	6.38	6.32	6.28
NL	kg/d	6.14	6.12	6.07	6.07	6.01	6.01	5.96	5.90	5.90	5.85	5.85	5.79	5.76
CHSK	kg/d	12.28	12.25	12.14	12.14	12.03	12.03	11.92	11.81	11.81	11.70	11.70	11.59	11.51
Počet EO	os.	111	111	110	110	109	109	108	107	107	106	106	105	104
odp.vod likv.na ČOV	m3/den	1.75	1.97	1.97	1.97	1.97	1.97	1.82	1.82	1.82	1.97	1.97	1.82	4.60
odp.vod likv.v septicích	m3/den	12.00	11.85	11.70	11.70	11.55	11.55	11.55	11.40	11.40	11.25	11.25	11.25	11.25
odp.vod likv.jiným způsobem	m3/den	3.15	3.00	3.00	3.00	3.00	3.00	3.00	3.00	3.00	2.85	2.85	2.85	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY 2018 Bystřany														
Množství odpadních vod	m3/den	0.40	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.40
BSK5	kg/d	0.10	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.10
NL	kg/d	0.09	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.09
CHSK	kg/d	0.18	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.18
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	1.35	1.65	1.65	1.65	1.65	1.65	1.50	1.50	1.50	1.65	1.65	1.50	4.20
BSK5	kg/d	0.54	0.66	0.66	0.66	0.66	0.66	0.60	0.60	0.60	0.66	0.66	0.60	1.68
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	9	11	11	11	11	11	10	10	10	11	11	10	28
Typ ČOV		Domovní mikročist.,biof.												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	30.00 30.00 110.00 30.00 6.00												
Množství vyčišť.odp.vod	m3/den	13.35	13.50	13.35	13.35	13.20	13.20	13.05	12.90	12.90	12.90	12.90	12.75	15.45
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	2.90	2.98	2.95	2.95	2.92	2.92	2.87	2.84	2.84	2.86	2.86	2.81	3.80
NL	kg/d	2.56	2.52	2.49	2.49	2.45	2.45	2.46	2.43	2.43	2.39	2.39	2.39	2.31
CHSK	kg/d	3.85	3.77	3.72	3.72	3.67	3.67	3.69	3.64	3.64	3.57	3.57	3.59	3.29
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	3.70	3.62	3.59	3.59	3.56	3.56	3.56	3.53	3.53	3.44	3.44	3.44	2.38
NL	kg/d	3.00	2.93	2.90	2.90	2.88	2.88	2.88	2.86	2.86	2.78	2.78	2.78	1.81
CHSK	kg/d	7.26	7.12	7.06	7.06	7.00	7.00	6.99	6.93	6.93	6.77	6.77	6.76	4.96
Produkce kalu	m3/r	0.06	0.07	0.07	0.07	0.07	0.07	0.06	0.06	0.06	0.07	0.07	0.06	0.14
Způsob likv.kalu		neurčeno												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0284.07 Mošnov

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030										
CELKOVÁ PRODUKCE																								
odpadních vod	m3/den	9.09	9.00	9.00	9.00	8.85	8.85	8.85	8.70	8.70	8.70	8.55	8.55	8.55										
BSK5	kg/d	3.48	3.46	3.46	3.46	3.40	3.40	3.40	3.34	3.34	3.34	3.28	3.28	3.28										
NL	kg/d	3.19	3.17	3.17	3.17	3.11	3.11	3.11	3.06	3.06	3.06	3.00	3.00	3.00										
CHSK	kg/d	6.37	6.33	6.33	6.33	6.22	6.22	6.22	6.11	6.11	6.11	6.00	6.00	6.00										
Počet EO	os.	57	57	57	57	56	56	56	55	55	55	54	54	54										
odp.vod likv.na ČOV	m3/den	0.99	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90										
odp.vod likv.v septicích	m3/den	8.10	8.10	8.10	8.10	7.95	7.95	7.95	7.80	7.80	7.80	7.65	7.65	7.65										
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bystřany																						
Množství odpadních vod	m3/den	0.99	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90										
BSK5	kg/d	0.24	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22										
NL	kg/d	0.22	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20										
CHSK	kg/d	0.43	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39										
PŘÍTOK NA ČOV																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0										
Typ ČOV		žádná																						
KONCENTRACE NA ODTOKU		stávající a navrhované řešení																						
	-	<table><tr><td>BSK5</td><td>NL</td><td>CHSK</td><td>N-celk</td><td>P-celk</td></tr><tr><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td></tr></table>													BSK5	NL	CHSK	N-celk	P-celk	0.00	0.00	0.00	0.00	0.00
BSK5	NL	CHSK	N-celk	P-celk																				
0.00	0.00	0.00	0.00	0.00																				
	mg/l																							
Množství vyčišť.odp.vod	m3/den	8.10	8.10	8.10	8.10	7.95	7.95	7.95	7.80	7.80	7.80	7.65	7.65	7.65										
ODSTRANĚNÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	1.62	1.62	1.62	1.62	1.59	1.59	1.59	1.56	1.56	1.56	1.53	1.53	1.53										
NL	kg/d	1.76	1.76	1.76	1.76	1.72	1.72	1.72	1.69	1.69	1.69	1.66	1.66	1.66										
CHSK	kg/d	2.70	2.70	2.70	2.70	2.65	2.65	2.65	2.60	2.60	2.60	2.55	2.55	2.55										
ZBYTKOVÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	1.62	1.62	1.62	1.62	1.59	1.59	1.59	1.56	1.56	1.56	1.53	1.53	1.53										
NL	kg/d	1.22	1.22	1.22	1.22	1.19	1.19	1.19	1.17	1.17	1.17	1.15	1.15	1.15										
CHSK	kg/d	3.24	3.24	3.24	3.24	3.18	3.18	3.18	3.12	3.12	3.12	3.06	3.06	3.06										
Produkce kalu	m3/r	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01										
Způsob likv.kalu																								
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										

CZ042.3509.4213.0284.08 Pytlíkov

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	6.00	5.85	5.85	5.85	5.85	5.85	5.70	5.70	5.70	5.70	5.70	5.70	5.70
BSK5	kg/d	2.25	2.19	2.19	2.19	2.19	2.19	2.13	2.13	2.13	2.13	2.13	2.13	2.13
NL	kg/d	2.06	2.01	2.01	2.01	2.01	2.01	1.95	1.95	1.95	1.95	1.95	1.95	1.95
CHSK	kg/d	4.13	4.02	4.02	4.02	4.02	4.02	3.91	3.91	3.91	3.91	3.91	3.91	3.91
Počet EO	os.	37	36	36	36	36	36	35	35	35	35	35	35	35
odp.vod likv.na ČOV	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.v septicích	m3/den	6.00	5.85	5.85	5.85	5.85	5.85	5.70	5.70	5.70	5.70	5.70	5.70	5.70
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišť.odp.vod	m3/den	6.00	5.85	5.85	5.85	5.85	5.85	5.70	5.70	5.70	5.70	5.70	5.70	5.70
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	1.05	1.02	1.02	1.02	1.02	1.02	0.99	0.99	0.99	0.99	0.99	0.99	0.99
NL	kg/d	1.16	1.13	1.13	1.13	1.13	1.13	1.10	1.10	1.10	1.10	1.10	1.10	1.10
CHSK	kg/d	1.73	1.68	1.68	1.68	1.68	1.68	1.63	1.63	1.63	1.63	1.63	1.63	1.63
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	1.20	1.17	1.17	1.17	1.17	1.17	1.14	1.14	1.14	1.14	1.14	1.14	1.14
NL	kg/d	0.90	0.88	0.88	0.88	0.88	0.88	0.86	0.86	0.86	0.86	0.86	0.86	0.86
CHSK	kg/d	2.40	2.34	2.34	2.34	2.34	2.34	2.28	2.28	2.28	2.28	2.28	2.28	2.28
Produkce kalu	m3/r	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0285.01 Dubí

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	732.25	728.35	724.60	720.85	716.95	713.20	709.45	705.55	701.80	698.05	694.15	690.40	686.65
BSK5	kg/d	292.83	291.27	289.77	288.27	286.71	285.21	283.71	282.15	280.65	279.15	277.59	276.09	274.59
NL	kg/d	268.43	267.00	265.62	264.25	262.82	261.44	260.07	258.64	257.26	255.89	254.46	253.08	251.71
CHSK	kg/d	536.86	534.00	531.25	528.50	525.64	522.89	520.14	517.28	514.53	511.78	508.92	506.17	503.42
Počet EO	os.	4880	4854	4829	4804	4778	4753	4728	4702	4677	4652	4626	4601	4576
odp.vod likv.na ČOV	m3/den	600.45	597.30	594.30	591.15	588.00	584.85	581.85	578.70	575.55	572.55	569.25	566.25	563.10
odp.vod likv.v septicích	m3/den	131.80	131.05	130.30	129.70	128.95	128.35	127.60	126.85	126.25	125.50	124.90	124.15	123.55
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSLUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY 2018 Bystřany														
Množství odpadních vod	m3/den	600.45	597.30	594.30	591.15	588.00	584.85	581.85	578.70	575.55	572.55	569.25	566.25	563.10
BSK5	kg/d	240.12	238.86	237.66	236.40	235.14	233.88	232.68	231.42	230.16	228.96	227.64	226.44	225.18
NL	kg/d	220.11	218.96	217.86	216.70	215.55	214.39	213.29	212.14	210.98	209.88	208.67	207.57	206.42
CHSK	kg/d	440.22	437.91	435.71	433.40	431.09	428.78	426.58	424.27	421.96	419.76	417.34	415.14	412.83
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	0.00 0.00 0.00 0.00 0.00												
Množství vyčištěn.odp.vod	m3/den	131.80	131.05	130.30	129.70	128.95	128.35	127.60	126.85	126.25	125.50	124.90	124.15	123.55
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	26.35	26.20	26.05	25.93	25.78	25.66	25.51	25.36	25.24	25.09	24.97	24.82	24.70
NL	kg/d	28.55	28.39	28.22	28.09	27.93	27.80	27.64	27.48	27.35	27.18	27.05	26.89	26.76
CHSK	kg/d	43.92	43.67	43.42	43.22	42.97	42.77	42.52	42.27	42.07	41.82	41.62	41.37	41.17
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	26.36	26.21	26.06	25.94	25.79	25.67	25.52	25.37	25.25	25.10	24.98	24.83	24.71
NL	kg/d	19.77	19.66	19.55	19.46	19.34	19.25	19.14	19.03	18.94	18.83	18.74	18.62	18.53
CHSK	kg/d	52.72	52.42	52.12	51.88	51.58	51.34	51.04	50.74	50.50	50.20	49.96	49.66	49.42
Produkce kalu	m3/r	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.21	0.21	0.21	0.21	0.21
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0285.02 Běhánky

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	137.40	136.65	136.05	135.30	134.70	133.95	133.35	132.60	132.00	131.25	130.65	129.90	129.30
BSK5	kg/d	54.12	53.82	53.58	53.28	53.04	52.74	52.50	52.20	51.96	51.66	51.42	51.12	50.88
NL	kg/d	49.61	49.34	49.12	48.84	48.62	48.35	48.13	47.85	47.63	47.36	47.14	46.86	46.64
CHSK	kg/d	99.22	98.67	98.23	97.68	97.24	96.69	96.25	95.70	95.26	94.71	94.27	93.72	93.28
Počet EO	os.	902	897	893	888	884	879	875	870	866	861	857	852	848
odp.vod likv.na ČOV	m3/den	112.65	112.05	111.60	111.00	110.55	109.95	109.35	108.75	108.30	107.70	107.25	106.65	106.05
odp.vod likv.v septicích	m3/den	24.75	24.60	24.45	24.30	24.15	24.00	24.00	23.85	23.70	23.55	23.40	23.25	23.25
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bystřany												
Množství odpadních vod	m3/den	112.65	112.05	111.60	111.00	110.55	109.95	109.35	108.75	108.30	107.70	107.25	106.65	106.05
BSK5	kg/d	44.37	44.13	43.95	43.71	43.53	43.29	43.05	42.81	42.63	42.39	42.21	41.97	41.73
NL	kg/d	40.67	40.45	40.29	40.07	39.90	39.68	39.46	39.24	39.08	38.86	38.69	38.47	38.25
CHSK	kg/d	81.35	80.91	80.58	80.14	79.81	79.37	78.93	78.49	78.16	77.72	77.39	76.95	76.51
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišť.odp.vod	m3/den	24.75	24.60	24.45	24.30	24.15	24.00	24.00	23.85	23.70	23.55	23.40	23.25	23.25
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	4.80	4.77	4.74	4.71	4.68	4.65	4.65	4.62	4.59	4.56	4.53	4.50	4.50
NL	kg/d	5.23	5.19	5.16	5.13	5.10	5.06	5.06	5.03	5.00	4.97	4.93	4.90	4.90
CHSK	kg/d	7.98	7.93	7.88	7.83	7.78	7.73	7.73	7.68	7.63	7.58	7.53	7.48	7.48
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	4.95	4.92	4.89	4.86	4.83	4.80	4.80	4.77	4.74	4.71	4.68	4.65	4.65
NL	kg/d	3.71	3.69	3.67	3.65	3.62	3.60	3.60	3.58	3.56	3.53	3.51	3.49	3.49
CHSK	kg/d	9.90	9.84	9.78	9.72	9.66	9.60	9.60	9.54	9.48	9.42	9.36	9.30	9.30
Produkce kalu	m3/r	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0285.03 Bystřice

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	171.46	170.48	169.64	168.74	167.91	167.07	166.02	165.19	164.36	163.46	162.62	161.72	160.89
BSK5	kg/d	66.96	66.58	66.26	65.90	65.58	65.26	64.84	64.52	64.20	63.84	63.52	63.16	62.84
NL	kg/d	61.38	61.03	60.74	60.41	60.12	59.82	59.44	59.14	58.85	58.52	58.23	57.90	57.60
CHSK	kg/d	122.76	122.06	121.48	120.82	120.23	119.64	118.87	118.29	117.70	117.04	116.45	115.79	115.21
Počet EO	os.	1116	1109	1104	1098	1093	1087	1080	1075	1070	1064	1058	1052	1047
odp.vod likv.na ČOV	m3/den	160.66	159.83	158.99	158.24	157.41	156.57	155.67	154.84	154.16	153.26	152.42	151.67	150.84
odp.vod likv.v septicích	m3/den	10.80	10.65	10.65	10.50	10.50	10.50	10.35	10.35	10.20	10.20	10.20	10.05	10.05
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY														
2018 Bystřany, 2018 Bystřany														
Množství odpadních vod	m3/den	160.66	159.83	158.99	158.24	157.41	156.57	155.67	154.84	154.16	153.26	152.42	151.67	150.84
BSK5	kg/d	62.64	62.32	62.00	61.70	61.38	61.06	60.70	60.38	60.12	59.76	59.44	59.14	58.82
NL	kg/d	57.42	57.13	56.83	56.56	56.27	55.97	55.64	55.35	55.11	54.78	54.49	54.21	53.92
CHSK	kg/d	114.84	114.25	113.67	113.12	112.53	111.94	111.28	110.70	110.22	109.56	108.97	108.42	107.84
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	0.00 0.00 0.00 0.00 0.00												
Množství vyčišt.odp.vod	m3/den	10.80	10.65	10.65	10.50	10.50	10.50	10.35	10.35	10.20	10.20	10.20	10.05	10.05
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	2.16	2.13	2.13	2.10	2.10	2.10	2.07	2.07	2.04	2.04	2.04	2.01	2.01
NL	kg/d	2.34	2.31	2.31	2.28	2.28	2.28	2.24	2.24	2.21	2.21	2.21	2.18	2.18
CHSK	kg/d	3.60	3.55	3.55	3.50	3.50	3.50	3.45	3.45	3.40	3.40	3.40	3.35	3.35
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	2.16	2.13	2.13	2.10	2.10	2.10	2.07	2.07	2.04	2.04	2.04	2.01	2.01
NL	kg/d	1.62	1.60	1.60	1.58	1.58	1.58	1.55	1.55	1.53	1.53	1.53	1.51	1.51
CHSK	kg/d	4.32	4.26	4.26	4.20	4.20	4.20	4.14	4.14	4.08	4.08	4.08	4.02	4.02
Produkce kalu	m3/r	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0285.04 Cínovec

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	11.75	11.60	11.60	11.60	11.45	11.45	11.45	11.30	11.30	11.30	11.15	11.15	11.15
BSK5	kg/d	4.59	4.53	4.53	4.53	4.47	4.47	4.47	4.41	4.41	4.41	4.35	4.35	4.35
NL	kg/d	4.21	4.15	4.15	4.15	4.10	4.10	4.10	4.04	4.04	4.04	3.99	3.99	3.99
CHSK	kg/d	8.42	8.31	8.31	8.31	8.20	8.20	8.20	8.09	8.09	8.09	7.98	7.98	7.98
Počet EO	os.	76	75	75	75	74	74	74	73	73	73	72	72	72
odp.vod likv.na ČOV	m3/den	9.60	9.60	9.60	9.60	9.45	9.45	9.45	9.30	9.30	9.30	9.15	9.15	9.15
odp.vod likv.v septicích	m3/den	2.15	2.00	2.00	2.00	2.00	2.00	2.00	2.00	2.00	2.00	2.00	2.00	2.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	9.60	9.60	9.60	9.60	9.45	9.45	9.45	9.30	9.30	9.30	9.15	9.15	9.15
BSK5	kg/d	3.75	3.75	3.75	3.75	3.69	3.69	3.69	3.63	3.63	3.63	3.57	3.57	3.57
NL	kg/d	3.41	3.41	3.41	3.41	3.36	3.36	3.36	3.30	3.30	3.30	3.25	3.25	3.25
CHSK	kg/d	6.82	6.82	6.82	6.82	6.71	6.71	6.71	6.60	6.60	6.60	6.49	6.49	6.49
Počet EO	os.	62	62	62	62	61	61	61	60	60	60	59	59	59
Typ ČOV		Akt. č. denitrif.+nitrif.												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	6.40 6.90 24.30 0.00 0.00												
Množství vyčištěn.odp.vod	m3/den	11.75	11.60	11.60	11.60	11.45	11.45	11.45	11.30	11.30	11.30	11.15	11.15	11.15
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	4.10	4.07	4.07	4.07	4.01	4.01	4.01	3.95	3.95	3.95	3.89	3.89	3.89
NL	kg/d	3.79	3.76	3.76	3.76	3.70	3.70	3.70	3.65	3.65	3.65	3.60	3.60	3.60
CHSK	kg/d	7.27	7.22	7.22	7.22	7.11	7.11	7.11	7.00	7.00	7.00	6.90	6.90	6.90
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.49	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46
NL	kg/d	0.39	0.37	0.37	0.37	0.37	0.37	0.37	0.36	0.36	0.36	0.36	0.36	0.36
CHSK	kg/d	1.09	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.03	1.02	1.02	1.02
Produkce kalu	m3/r	0.28	0.28	0.28	0.28	0.27	0.27	0.27	0.27	0.27	0.27	0.26	0.26	0.26
Způsob likv.kalu		odvoz na jinou ČOV												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0285.05 Drahůnky

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	40.03	39.78	39.63	39.39	39.24	38.94	38.85	38.55	38.40	38.16	38.01	37.77	37.56
BSK5	kg/d	15.09	15.01	14.95	14.87	14.81	14.69	14.67	14.55	14.49	14.41	14.35	14.27	14.17
NL	kg/d	13.83	13.76	13.70	13.63	13.58	13.47	13.45	13.34	13.28	13.21	13.15	13.08	12.99
CHSK	kg/d	27.67	27.52	27.41	27.26	27.15	26.93	26.90	26.68	26.57	26.42	26.31	26.16	25.98
Počet EO	os.	251	250	249	247	246	244	244	242	241	240	239	237	236
odp.vod likv.na ČOV	m3/den	7.48	7.38	7.38	7.29	7.29	7.29	7.20	7.20	7.20	7.11	7.11	7.02	7.11
odp.vod likv.v septicích	m3/den	32.55	32.40	32.25	32.10	31.95	31.65	31.65	31.35	31.20	31.05	30.90	30.75	30.45
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bystřany												
Množství odpadních vod	m3/den	7.48	7.38	7.38	7.29	7.29	7.29	7.20	7.20	7.20	7.11	7.11	7.02	7.11
BSK5	kg/d	2.07	2.05	2.05	2.03	2.03	2.03	2.01	2.01	2.01	1.99	1.99	1.97	1.99
NL	kg/d	1.90	1.88	1.88	1.86	1.86	1.86	1.84	1.84	1.84	1.82	1.82	1.81	1.82
CHSK	kg/d	3.80	3.76	3.76	3.72	3.72	3.72	3.69	3.69	3.69	3.65	3.65	3.61	3.65
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišť.odp.vod	m3/den	32.55	32.40	32.25	32.10	31.95	31.65	31.65	31.35	31.20	31.05	30.90	30.75	30.45
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	6.51	6.48	6.45	6.42	6.39	6.33	6.33	6.27	6.24	6.21	6.18	6.15	6.09
NL	kg/d	7.05	7.02	6.99	6.96	6.92	6.86	6.86	6.79	6.76	6.73	6.70	6.66	6.60
CHSK	kg/d	10.85	10.80	10.75	10.70	10.65	10.55	10.55	10.45	10.40	10.35	10.30	10.25	10.15
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	6.51	6.48	6.45	6.42	6.39	6.33	6.33	6.27	6.24	6.21	6.18	6.15	6.09
NL	kg/d	4.88	4.86	4.84	4.82	4.79	4.75	4.75	4.70	4.68	4.66	4.64	4.61	4.57
CHSK	kg/d	13.02	12.96	12.90	12.84	12.78	12.66	12.66	12.54	12.48	12.42	12.36	12.30	12.18
Produkce kalu	m3/r	0.06	0.06	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0285.06 Mstišov

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	72.30	71.85	71.55	71.10	70.80	70.35	70.05	69.60	69.30	68.85	68.55	68.10	67.80
BSK5	kg/d	28.92	28.74	28.62	28.44	28.32	28.14	28.02	27.84	27.72	27.54	27.42	27.24	27.12
NL	kg/d	26.51	26.35	26.24	26.07	25.96	25.80	25.69	25.52	25.41	25.25	25.14	24.97	24.86
CHSK	kg/d	53.02	52.69	52.47	52.14	51.92	51.59	51.37	51.04	50.82	50.49	50.27	49.94	49.72
Počet EO	os.	482	479	477	474	472	469	467	464	462	459	457	454	452
odp.vod likv.na ČOV	m3/den	50.55	50.25	50.10	49.80	49.65	49.20	49.05	48.75	48.60	48.15	48.00	47.70	47.40
odp.vod likv.v septicích	m3/den	21.75	21.60	21.45	21.30	21.15	21.15	21.00	20.85	20.70	20.70	20.55	20.40	20.40
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bystřany												
Množství odpadních vod	m3/den	50.55	50.25	50.10	49.80	49.65	49.20	49.05	48.75	48.60	48.15	48.00	47.70	47.40
BSK5	kg/d	20.22	20.10	20.04	19.92	19.86	19.68	19.62	19.50	19.44	19.26	19.20	19.08	18.96
NL	kg/d	18.54	18.43	18.37	18.26	18.21	18.04	17.99	17.88	17.82	17.66	17.60	17.49	17.38
CHSK	kg/d	37.07	36.85	36.74	36.52	36.41	36.08	35.97	35.75	35.64	35.31	35.20	34.98	34.76
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišť.odp.vod	m3/den	21.75	21.60	21.45	21.30	21.15	21.15	21.00	20.85	20.70	20.70	20.55	20.40	20.40
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	4.35	4.32	4.29	4.26	4.23	4.23	4.20	4.17	4.14	4.14	4.11	4.08	4.08
NL	kg/d	4.71	4.68	4.65	4.62	4.58	4.58	4.55	4.52	4.49	4.49	4.45	4.42	4.42
CHSK	kg/d	7.25	7.20	7.15	7.10	7.05	7.05	7.00	6.95	6.90	6.90	6.85	6.80	6.80
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	4.35	4.32	4.29	4.26	4.23	4.23	4.20	4.17	4.14	4.14	4.11	4.08	4.08
NL	kg/d	3.26	3.24	3.22	3.20	3.17	3.17	3.15	3.13	3.11	3.11	3.08	3.06	3.06
CHSK	kg/d	8.70	8.64	8.58	8.52	8.46	8.46	8.40	8.34	8.28	8.28	8.22	8.16	8.16
Produkce kalu	m3/r	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.03	0.03	0.03
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0286.01 Duchcov

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	1243.35	1237.05	1230.75	1224.45	1218.15	1211.85	1205.70	1199.40	1193.10	1186.80	1180.50	1174.20	1168.05
BSK5	kg/d	494.07	491.55	489.03	486.51	483.99	481.47	479.01	476.49	473.97	471.45	468.93	466.41	463.95
NL	kg/d	452.90	450.59	448.28	445.97	443.66	441.35	439.09	436.78	434.47	432.16	429.85	427.54	425.29
CHSK	kg/d	905.80	901.18	896.56	891.94	887.32	882.70	878.19	873.57	868.95	864.33	859.71	855.09	850.58
Počet EO	os.	8234	8192	8150	8108	8066	8024	7983	7941	7899	7857	7815	7773	7732
odp.vod likv.na ČOV	m3/den	1156.30	1150.45	1144.60	1138.75	1132.90	1127.05	1121.35	1115.50	1109.65	1103.80	1097.95	1092.10	1086.25
odp.vod likv.v septicích	m3/den	87.05	86.60	86.15	85.70	85.25	84.80	84.35	83.90	83.45	83.00	82.55	82.10	81.80
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Želénky												
Množství odpadních vod	m3/den	1156.30	1150.45	1144.60	1138.75	1132.90	1127.05	1121.35	1115.50	1109.65	1103.80	1097.95	1092.10	1086.25
BSK5	kg/d	459.48	457.14	454.80	452.46	450.12	447.78	445.50	443.16	440.82	438.48	436.14	433.80	431.46
NL	kg/d	421.19	419.05	416.90	414.76	412.61	410.47	408.38	406.23	404.09	401.94	399.80	397.65	395.51
CHSK	kg/d	842.38	838.09	833.80	829.51	825.22	820.93	816.75	812.46	808.17	803.88	799.59	795.30	791.01
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišť.odp.vod	m3/den	87.05	86.60	86.15	85.70	85.25	84.80	84.35	83.90	83.45	83.00	82.55	82.10	81.80
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	17.18	17.09	17.00	16.91	16.82	16.73	16.64	16.55	16.46	16.37	16.28	16.19	16.13
NL	kg/d	18.65	18.55	18.46	18.36	18.26	18.16	18.07	17.97	17.87	17.77	17.68	17.58	17.51
CHSK	kg/d	28.60	28.45	28.30	28.15	28.00	27.85	27.70	27.55	27.40	27.25	27.10	26.95	26.85
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	17.41	17.32	17.23	17.14	17.05	16.96	16.87	16.78	16.69	16.60	16.51	16.42	16.36
NL	kg/d	13.06	12.99	12.92	12.86	12.79	12.72	12.65	12.59	12.52	12.45	12.38	12.32	12.27
CHSK	kg/d	34.82	34.64	34.46	34.28	34.10	33.92	33.74	33.56	33.38	33.20	33.02	32.84	32.72
Produkce kalu	m3/r	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.14	0.14	0.14	0.14	0.14	0.14
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0287.01 Háj u Duchcova

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	156.25	155.50	154.75	154.00	153.40	152.65	151.90	151.15	150.55	149.80	149.05	148.30	147.70
BSK5	kg/d	60.60	60.30	60.00	59.70	59.46	59.16	58.86	58.56	58.32	58.02	57.72	57.42	57.18
NL	kg/d	55.55	55.28	55.00	54.73	54.51	54.23	53.96	53.68	53.46	53.19	52.91	52.64	52.42
CHSK	kg/d	111.10	110.55	110.00	109.45	109.01	108.46	107.91	107.36	106.92	106.37	105.82	105.27	104.83
Počet EO	os.	1010	1005	1000	995	991	986	981	976	972	967	962	957	953
odp.vod likv.na ČOV	m3/den	109.30	108.85	108.40	107.80	107.35	106.90	106.30	105.85	105.40	104.80	104.35	103.75	103.45
odp.vod likv.v septicích	m3/den	46.95	46.65	46.35	46.20	46.05	45.75	45.60	45.30	45.15	45.00	44.70	44.55	44.25
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY 2018 Želénky														
Množství odpadních vod	m3/den	109.30	108.85	108.40	107.80	107.35	106.90	106.30	105.85	105.40	104.80	104.35	103.75	103.45
BSK5	kg/d	42.39	42.21	42.03	41.79	41.61	41.43	41.19	41.01	40.83	40.59	40.41	40.17	40.05
NL	kg/d	38.86	38.69	38.53	38.31	38.14	37.98	37.76	37.59	37.43	37.21	37.04	36.82	36.71
CHSK	kg/d	77.72	77.39	77.06	76.62	76.29	75.96	75.52	75.19	74.86	74.42	74.09	73.65	73.43
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	0.00 0.00 0.00 0.00 0.00												
Množství vyčištěn.odp.vod	m3/den	46.95	46.65	46.35	46.20	46.05	45.75	45.60	45.30	45.15	45.00	44.70	44.55	44.25
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	8.82	8.76	8.70	8.67	8.64	8.58	8.55	8.49	8.46	8.43	8.37	8.34	8.28
NL	kg/d	9.65	9.59	9.52	9.49	9.46	9.39	9.36	9.29	9.26	9.23	9.16	9.13	9.07
CHSK	kg/d	14.61	14.51	14.41	14.36	14.31	14.21	14.16	14.06	14.01	13.96	13.86	13.81	13.71
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	9.39	9.33	9.27	9.24	9.21	9.15	9.12	9.06	9.03	9.00	8.94	8.91	8.85
NL	kg/d	7.04	7.00	6.95	6.93	6.91	6.86	6.84	6.80	6.77	6.75	6.71	6.68	6.64
CHSK	kg/d	18.78	18.66	18.54	18.48	18.42	18.30	18.24	18.12	18.06	18.00	17.88	17.82	17.70
Produkce kalu	m3/r	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0287.02 Domaslavice

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	15.05	14.90	14.90	14.75	14.75	14.60	14.60	14.45	14.45	14.30	14.30	14.15	14.15
BSK5	kg/d	5.94	5.88	5.88	5.82	5.82	5.76	5.76	5.70	5.70	5.64	5.64	5.58	5.58
NL	kg/d	5.45	5.39	5.39	5.34	5.34	5.28	5.28	5.23	5.23	5.17	5.17	5.12	5.12
CHSK	kg/d	10.89	10.78	10.78	10.67	10.67	10.56	10.56	10.45	10.45	10.34	10.34	10.23	10.23
Počet EO	os.	99	98	98	97	97	96	96	95	95	94	94	93	93
odp.vod likv.na ČOV	m3/den	10.80	10.65	10.65	10.50	10.50	10.35	10.35	10.35	10.35	10.20	10.20	10.05	10.05
odp.vod likv.v septicích	m3/den	4.25	4.25	4.25	4.25	4.25	4.25	4.25	4.10	4.10	4.10	4.10	4.10	4.10
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Želénky												
Množství odpadních vod	m3/den	10.80	10.65	10.65	10.50	10.50	10.35	10.35	10.35	10.35	10.20	10.20	10.05	10.05
BSK5	kg/d	4.26	4.20	4.20	4.14	4.14	4.08	4.08	4.08	4.08	4.02	4.02	3.96	3.96
NL	kg/d	3.91	3.85	3.85	3.80	3.80	3.74	3.74	3.74	3.74	3.69	3.69	3.63	3.63
CHSK	kg/d	7.81	7.70	7.70	7.59	7.59	7.48	7.48	7.48	7.48	7.37	7.37	7.26	7.26
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišť.odp.vod	m3/den	4.25	4.25	4.25	4.25	4.25	4.25	4.25	4.10	4.10	4.10	4.10	4.10	4.10
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.83	0.83	0.83	0.83	0.83	0.83	0.83	0.80	0.80	0.80	0.80	0.80	0.80
NL	kg/d	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.87	0.87	0.87	0.87	0.87	0.87
CHSK	kg/d	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.33	1.33	1.33	1.33	1.33	1.33
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.82	0.82	0.82	0.82	0.82	0.82
NL	kg/d	0.64	0.64	0.64	0.64	0.64	0.64	0.64	0.62	0.62	0.62	0.62	0.62	0.62
CHSK	kg/d	1.70	1.70	1.70	1.70	1.70	1.70	1.70	1.64	1.64	1.64	1.64	1.64	1.64
Produkce kalu	m3/r	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0288.01 Hrob

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	264.65	263.21	261.92	260.64	259.20	257.91	256.63	255.19	253.90	252.61	251.18	249.89	248.54
BSK5	kg/d	102.72	102.16	101.66	101.16	100.60	100.10	99.60	99.04	98.54	98.04	97.48	96.98	96.44
NL	kg/d	94.16	93.65	93.19	92.73	92.22	91.76	91.30	90.79	90.33	89.87	89.36	88.90	88.40
CHSK	kg/d	188.32	187.29	186.38	185.46	184.43	183.52	182.60	181.57	180.66	179.74	178.71	177.80	176.81
Počet EO	os.	1712	1702	1694	1686	1676	1668	1660	1650	1642	1634	1624	1616	1607
odp.vod likv.na ČOV	m3/den	173.50	172.66	171.82	170.99	170.00	169.16	168.33	167.34	166.50	165.66	164.83	163.84	162.94
odp.vod likv.v septicích	m3/den	91.15	90.55	90.10	89.65	89.20	88.75	88.30	87.85	87.40	86.95	86.35	86.05	85.60
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT 2018 Mlýny														
Množství odpadních vod	m3/den	9.45	9.45	9.45	9.30	9.30	9.30	9.15	9.15	9.15	9.00	9.00	8.85	8.85
BSK5	kg/d	3.78	3.78	3.78	3.72	3.72	3.72	3.66	3.66	3.66	3.60	3.60	3.54	3.54
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY 2018 Bystřany, 2018 Bystřany														
Množství odpadních vod	m3/den	15.75	15.66	15.57	15.49	15.40	15.31	15.23	15.14	15.05	14.96	14.88	14.79	14.79
BSK5	kg/d	3.69	3.67	3.65	3.63	3.61	3.59	3.57	3.55	3.53	3.51	3.49	3.47	3.47
NL	kg/d	3.38	3.36	3.35	3.33	3.31	3.29	3.27	3.25	3.24	3.22	3.20	3.18	3.18
CHSK	kg/d	6.77	6.73	6.69	6.66	6.62	6.58	6.55	6.51	6.47	6.44	6.40	6.36	6.36
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	167.20	166.45	165.70	164.80	163.90	163.15	162.25	161.35	160.60	159.70	158.95	157.90	157.00
BSK5	kg/d	66.54	66.24	65.94	65.58	65.22	64.92	64.56	64.20	63.90	63.54	63.24	62.82	62.46
NL	kg/d	57.53	57.26	56.98	56.71	56.38	56.10	55.83	55.50	55.22	54.95	54.67	54.34	54.01
CHSK	kg/d	115.06	114.51	113.96	113.41	112.75	112.20	111.65	110.99	110.44	109.89	109.34	108.68	108.02
Počet EO	os.	1109	1104	1099	1093	1087	1082	1076	1070	1065	1059	1054	1047	1041
Typ ČOV		Aktivační čistírna												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	5.07 7.60 19.17 0.00 0.00												
Množství vyčištěn. odp. vod	m3/den	258.35	257.00	255.80	254.45	253.10	251.90	250.55	249.20	248.00	246.65	245.30	243.95	242.60
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	83.73	83.32	82.93	82.48	82.04	81.65	81.21	80.76	80.38	79.93	79.51	79.04	78.59
NL	kg/d	75.83	75.43	75.07	74.70	74.28	73.92	73.55	73.13	72.76	72.40	72.00	71.61	71.19
CHSK	kg/d	141.89	141.15	140.47	139.79	138.99	138.31	137.62	136.83	136.15	135.46	134.73	133.99	133.20
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	19.08	18.95	18.86	18.77	18.67	18.58	18.48	18.39	18.29	18.20	18.08	18.01	17.92
NL	kg/d	14.94	14.85	14.77	14.70	14.63	14.55	14.48	14.40	14.33	14.26	14.16	14.11	14.03
CHSK	kg/d	39.67	39.41	39.22	39.02	38.82	38.63	38.43	38.23	38.04	37.84	37.59	37.45	37.25
Produkce kalu	m3/r	5.04	5.01	4.99	4.96	4.94	4.91	4.89	4.86	4.84	4.81	4.79	4.75	4.73
Způsob likv.kalu		vysoušení na kalových polích												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0288.03 Mlýny

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	21.00	20.85	20.70	20.55	20.55	20.40	20.25	20.10	20.10	19.95	19.80	19.65	19.65
BSK5	kg/d	8.40	8.34	8.28	8.22	8.22	8.16	8.10	8.04	8.04	7.98	7.92	7.86	7.86
NL	kg/d	7.70	7.65	7.59	7.54	7.54	7.48	7.43	7.37	7.37	7.32	7.26	7.21	7.21
CHSK	kg/d	15.40	15.29	15.18	15.07	15.07	14.96	14.85	14.74	14.74	14.63	14.52	14.41	14.41
Počet EO	os.	140	139	138	137	137	136	135	134	134	133	132	131	131
odp.vod likv.na ČOV	m3/den	9.45	9.45	9.45	9.30	9.30	9.30	9.15	9.15	9.15	9.00	9.00	8.85	8.85
odp.vod likv.v septicích	m3/den	11.55	11.40	11.25	11.25	11.25	11.10	11.10	10.95	10.95	10.95	10.80	10.80	10.80
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Hrob												
Množství odpadních vod	m3/den	9.45	9.45	9.45	9.30	9.30	9.30	9.15	9.15	9.15	9.00	9.00	8.85	8.85
BSK5	kg/d	3.78	3.78	3.78	3.72	3.72	3.72	3.66	3.66	3.66	3.60	3.60	3.54	3.54
NL	kg/d	3.47	3.47	3.47	3.41	3.41	3.41	3.36	3.36	3.36	3.30	3.30	3.25	3.25
CHSK	kg/d	6.93	6.93	6.93	6.82	6.82	6.82	6.71	6.71	6.71	6.60	6.60	6.49	6.49
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišť.odp.vod	m3/den	11.55	11.40	11.25	11.25	11.25	11.10	11.10	10.95	10.95	10.95	10.80	10.80	10.80
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	2.31	2.28	2.25	2.25	2.25	2.22	2.22	2.19	2.19	2.19	2.16	2.16	2.16
NL	kg/d	2.50	2.47	2.44	2.44	2.44	2.41	2.41	2.37	2.37	2.37	2.34	2.34	2.34
CHSK	kg/d	3.85	3.80	3.75	3.75	3.75	3.70	3.70	3.65	3.65	3.65	3.60	3.60	3.60
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	2.31	2.28	2.25	2.25	2.25	2.22	2.22	2.19	2.19	2.19	2.16	2.16	2.16
NL	kg/d	1.73	1.71	1.69	1.69	1.69	1.67	1.67	1.64	1.64	1.64	1.62	1.62	1.62
CHSK	kg/d	4.62	4.56	4.50	4.50	4.50	4.44	4.44	4.38	4.38	4.38	4.32	4.32	4.32
Produkce kalu	m3/r	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0289.01 Jeníkov

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	48.95	48.65	48.35	48.20	47.90	47.75	47.45	47.15	47.00	46.70	46.55	46.25	46.10
BSK5	kg/d	19.35	19.23	19.11	19.05	18.93	18.87	18.75	18.63	18.57	18.45	18.39	18.27	18.21
NL	kg/d	17.74	17.63	17.52	17.46	17.35	17.30	17.19	17.08	17.02	16.91	16.86	16.75	16.69
CHSK	kg/d	35.48	35.26	35.04	34.93	34.71	34.60	34.38	34.16	34.05	33.83	33.72	33.50	33.39
Počet EO	os.	322	320	318	317	315	314	312	310	309	307	306	304	303
odp.vod likv.na ČOV	m3/den	28.85	28.70	28.55	28.55	28.25	28.25	28.10	27.80	27.80	27.65	27.50	27.35	27.20
odp.vod likv.v septicích	m3/den	20.10	19.95	19.80	19.65	19.65	19.50	19.35	19.35	19.20	19.05	19.05	18.90	18.90
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Želénky												
Množství odpadních vod	m3/den	28.85	28.70	28.55	28.55	28.25	28.25	28.10	27.80	27.80	27.65	27.50	27.35	27.20
BSK5	kg/d	11.40	11.34	11.28	11.28	11.16	11.16	11.10	10.98	10.98	10.92	10.86	10.80	10.74
NL	kg/d	10.45	10.40	10.34	10.34	10.23	10.23	10.18	10.07	10.07	10.01	9.96	9.90	9.85
CHSK	kg/d	20.90	20.79	20.68	20.68	20.46	20.46	20.35	20.13	20.13	20.02	19.91	19.80	19.69
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišť.odp.vod	m3/den	20.10	19.95	19.80	19.65	19.65	19.50	19.35	19.35	19.20	19.05	19.05	18.90	18.90
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	3.93	3.90	3.87	3.84	3.84	3.81	3.78	3.78	3.75	3.72	3.72	3.69	3.69
NL	kg/d	4.27	4.24	4.21	4.18	4.18	4.14	4.11	4.11	4.08	4.05	4.05	4.01	4.01
CHSK	kg/d	6.54	6.49	6.44	6.39	6.39	6.34	6.29	6.29	6.24	6.19	6.19	6.14	6.14
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	4.02	3.99	3.96	3.93	3.93	3.90	3.87	3.87	3.84	3.81	3.81	3.78	3.78
NL	kg/d	3.02	2.99	2.97	2.95	2.95	2.93	2.90	2.90	2.88	2.86	2.86	2.84	2.84
CHSK	kg/d	8.04	7.98	7.92	7.86	7.86	7.80	7.74	7.74	7.68	7.62	7.62	7.56	7.56
Produkce kalu	m3/r	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0289.02 Oldřichov

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	73.85	73.40	73.10	72.65	72.35	71.90	71.60	71.15	70.85	70.40	70.10	69.65	69.35
BSK5	kg/d	29.31	29.13	29.01	28.83	28.71	28.53	28.41	28.23	28.11	27.93	27.81	27.63	27.51
NL	kg/d	26.87	26.70	26.59	26.43	26.32	26.15	26.04	25.88	25.77	25.60	25.49	25.33	25.22
CHSK	kg/d	53.74	53.41	53.19	52.86	52.64	52.31	52.09	51.76	51.54	51.21	50.99	50.66	50.44
Počet EO	os.	488	485	483	480	478	475	473	470	468	465	463	460	458
odp.vod likv.na ČOV	m3/den	50.20	49.90	49.75	49.45	49.30	49.00	48.70	48.40	48.25	47.95	47.80	47.35	47.20
odp.vod likv.v septicích	m3/den	23.65	23.50	23.35	23.20	23.05	22.90	22.90	22.75	22.60	22.45	22.30	22.30	22.15
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Želénky												
Množství odpadních vod	m3/den	50.20	49.90	49.75	49.45	49.30	49.00	48.70	48.40	48.25	47.95	47.80	47.35	47.20
BSK5	kg/d	19.92	19.80	19.74	19.62	19.56	19.44	19.32	19.20	19.14	19.02	18.96	18.78	18.72
NL	kg/d	18.26	18.15	18.10	17.99	17.93	17.82	17.71	17.60	17.55	17.44	17.38	17.22	17.16
CHSK	kg/d	36.52	36.30	36.19	35.97	35.86	35.64	35.42	35.20	35.09	34.87	34.76	34.43	34.32
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišť.odp.vod	m3/den	23.65	23.50	23.35	23.20	23.05	22.90	22.90	22.75	22.60	22.45	22.30	22.30	22.15
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	4.66	4.63	4.60	4.57	4.54	4.51	4.51	4.48	4.45	4.42	4.39	4.39	4.36
NL	kg/d	5.06	5.03	5.00	4.96	4.93	4.90	4.90	4.87	4.83	4.80	4.77	4.77	4.74
CHSK	kg/d	7.76	7.71	7.66	7.61	7.56	7.51	7.51	7.46	7.41	7.36	7.31	7.31	7.26
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	4.73	4.70	4.67	4.64	4.61	4.58	4.58	4.55	4.52	4.49	4.46	4.46	4.43
NL	kg/d	3.55	3.53	3.50	3.48	3.46	3.44	3.44	3.41	3.39	3.37	3.35	3.35	3.32
CHSK	kg/d	9.46	9.40	9.34	9.28	9.22	9.16	9.16	9.10	9.04	8.98	8.92	8.92	8.86
Produkce kalu	m3/r	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0290.01 Kladruby

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	57.60	58.65	59.70	60.75	61.80	62.85	63.90	64.95	66.00	67.05	68.10	69.15	70.35
BSK5	kg/d	23.04	23.46	23.88	24.30	24.72	25.14	25.56	25.98	26.40	26.82	27.24	27.66	28.14
NL	kg/d	21.12	21.51	21.89	22.28	22.66	23.05	23.43	23.82	24.20	24.59	24.97	25.36	25.80
CHSK	kg/d	42.24	43.01	43.78	44.55	45.32	46.09	46.86	47.63	48.40	49.17	49.94	50.71	51.59
Počet EO	os.	384	391	398	405	412	419	426	433	440	447	454	461	469
odp.vod likv.na ČOV	m3/den	57.60	58.65	59.70	60.75	61.80	62.85	63.90	64.95	66.00	67.05	68.10	69.15	70.35
odp.vod likv.v septicích	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	57.60	58.65	59.70	60.75	61.80	62.85	63.90	64.95	66.00	67.05	68.10	69.15	70.35
BSK5	kg/d	23.04	23.46	23.88	24.30	24.72	25.14	25.56	25.98	26.40	26.82	27.24	27.66	28.14
NL	kg/d	21.12	21.51	21.89	22.28	22.66	23.05	23.43	23.82	24.20	24.59	24.97	25.36	25.80
CHSK	kg/d	42.24	43.01	43.78	44.55	45.32	46.09	46.86	47.63	48.40	49.17	49.94	50.71	51.59
Počet EO	os.	384	391	398	405	412	419	426	433	440	447	454	461	469
Typ ČOV		Aktiv. čistírna s nitrif.												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	15.0020.0080.0030.008.00												
Množství vyčišť.odp.vod	m3/den	57.60	58.65	59.70	60.75	61.80	62.85	63.90	64.95	66.00	67.05	68.10	69.15	70.35
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	22.18	22.58	22.98	23.39	23.79	24.20	24.60	25.01	25.41	25.81	26.22	26.62	27.08
NL	kg/d	19.97	20.33	20.70	21.06	21.42	21.79	22.15	22.52	22.88	23.24	23.61	23.97	24.39
CHSK	kg/d	37.63	38.32	39.00	39.69	40.38	41.06	41.75	42.43	43.12	43.81	44.49	45.18	45.96
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.86	0.88	0.90	0.91	0.93	0.94	0.96	0.97	0.99	1.01	1.02	1.04	1.06
NL	kg/d	1.15	1.17	1.19	1.22	1.24	1.26	1.28	1.30	1.32	1.34	1.36	1.38	1.41
CHSK	kg/d	4.61	4.69	4.78	4.86	4.94	5.03	5.11	5.20	5.28	5.36	5.45	5.53	5.63
Produkce kalu	m3/r	1.69	1.72	1.75	1.78	1.81	1.84	1.87	1.91	1.94	1.97	2.00	2.03	2.06
Způsob likv.kalu		neurčeno												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0291.01 Kostomlaty pod Milešovkou

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	131.50	133.57	135.64	137.71	139.73	141.80	143.87	156.81	159.02	161.23	163.46	165.67	167.90
BSK5	kg/d	51.55	52.34	53.13	53.92	54.69	55.48	56.27	63.27	64.14	65.01	65.90	66.77	67.65
NL	kg/d	47.25	47.98	48.70	49.43	50.13	50.85	51.58	58.00	58.80	59.59	60.40	61.20	62.01
CHSK	kg/d	94.51	95.96	97.41	98.85	100.26	101.70	103.15	116.00	117.59	119.19	120.81	122.40	124.03
Počet EO	os.	859	872	885	898	911	924	937	1054	1069	1083	1098	1112	1127
odp.vod likv.na ČOV	m3/den	131.50	133.57	135.64	137.71	139.73	141.80	143.87	156.81	159.02	161.23	163.46	165.67	167.90
odp.vod likv.v septicích	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY 2018 Bilina														
Množství odpadních vod	m3/den	13.00	13.12	13.24	13.36	13.58	13.70	13.82	1.56	1.52	1.48	1.46	1.42	1.40
BSK5	kg/d	4.15	4.16	4.17	4.18	4.23	4.24	4.25	1.17	1.14	1.11	1.10	1.07	1.05
NL	kg/d	3.80	3.81	3.82	3.83	3.87	3.88	3.89	1.07	1.05	1.02	1.00	0.98	0.96
CHSK	kg/d	7.61	7.63	7.65	7.66	7.75	7.76	7.78	2.15	2.09	2.04	2.01	1.95	1.93
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	118.50	120.45	122.40	124.35	126.15	128.10	130.05	155.25	157.50	159.75	162.00	164.25	166.50
BSK5	kg/d	47.40	48.18	48.96	49.74	50.46	51.24	52.02	62.10	63.00	63.90	64.80	65.70	66.60
NL	kg/d	43.45	44.17	44.88	45.60	46.26	46.97	47.69	56.93	57.75	58.58	59.40	60.23	61.05
CHSK	kg/d	86.90	88.33	89.76	91.19	92.51	93.94	95.37	113.85	115.50	117.15	118.80	120.45	122.10
Počet EO	os.	790	803	816	829	841	854	867	1035	1050	1065	1080	1095	1110
Typ ČOV		Aktivační čistírna					Aktiv. čistírna s nitrif.							
KONCENTRACE NA ODTOKU		stávající					navrhované řešení							
	-	BSK5	NL	CHSK	N-celk	P-celk	BSK5	NL	CHSK	N-celk	P-celk	BSK5	NL	CHSK
	mg/l	20.00	20.00	90.00	35.00	8.00	15.00	20.00	80.00	30.00	8.00	15.00	20.00	80.00
Množství vyčištěn. odp.vod	m3/den	118.50	120.45	122.40	124.35	126.15	128.10	130.05	155.25	157.50	159.75	162.00	164.25	166.50
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	45.03	45.77	46.51	47.25	47.94	48.68	49.42	59.77	60.64	61.50	62.37	63.24	64.10
NL	kg/d	41.08	41.76	42.43	43.11	43.73	44.41	45.08	53.82	54.60	55.38	56.16	56.94	57.72
CHSK	kg/d	76.24	77.49	78.74	80.00	81.16	82.41	83.67	101.43	102.90	104.37	105.84	107.31	108.78
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	2.37	2.41	2.45	2.49	2.52	2.56	2.60	2.33	2.36	2.40	2.43	2.46	2.50
NL	kg/d	2.37	2.41	2.45	2.49	2.52	2.56	2.60	3.11	3.15	3.20	3.24	3.29	3.33
CHSK	kg/d	10.67	10.84	11.02	11.19	11.35	11.53	11.70	12.42	12.60	12.78	12.96	13.14	13.32
Produkce kalu	m3/r	3.48	3.53	3.59	3.65	3.70	3.76	3.81	4.55	4.62	4.69	4.75	4.82	4.88
Způsob likv.kalu		vysoušení na kalových polích								neurčeno				
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0291.02 Hlince

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	4.80	4.80	4.80	4.80	4.80	4.80	4.80	4.80	4.80	4.80	4.80	4.80	4.80
BSK5	kg/d	1.65	1.65	1.65	1.65	1.65	1.65	1.65	1.65	1.65	1.65	1.65	1.65	1.65
NL	kg/d	1.51	1.51	1.51	1.51	1.51	1.51	1.51	1.51	1.51	1.51	1.51	1.51	1.51
CHSK	kg/d	3.03	3.03	3.03	3.03	3.03	3.03	3.03	3.03	3.03	3.03	3.03	3.03	3.03
Počet EO	os.	27	27	27	27	27	27	27	27	27	27	27	27	27
odp.vod likv.na ČOV	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.v septicích	m3/den	4.80	4.80	4.80	4.80	4.80	4.80	4.80	4.80	4.80	4.80	4.80	4.80	4.80
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	0.00 0.00 0.00 0.00 0.00												
Množství vyčišť.odp.vod	m3/den	4.80	4.80	4.80	4.80	4.80	4.80	4.80	4.80	4.80	4.80	4.80	4.80	4.80
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69
NL	kg/d	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79
CHSK	kg/d	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96
NL	kg/d	0.72	0.72	0.72	0.72	0.72	0.72	0.72	0.72	0.72	0.72	0.72	0.72	0.72
CHSK	kg/d	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92	1.92
Produkce kalu	m3/r	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0292.01 Košťany

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	249.03	247.82	246.68	245.55	244.27	243.14	242.01	240.73	239.59	238.46	237.18	236.05	234.92
BSK5	kg/d	95.08	94.62	94.18	93.74	93.24	92.80	92.36	91.86	91.42	90.98	90.48	90.04	89.60
NL	kg/d	87.16	86.74	86.33	85.93	85.47	85.07	84.66	84.21	83.80	83.40	82.94	82.54	82.13
CHSK	kg/d	174.31	173.47	172.66	171.86	170.94	170.13	169.33	168.41	167.60	166.80	165.88	165.07	164.27
Počet EO	os.	1584	1577	1569	1562	1554	1546	1539	1531	1523	1516	1508	1500	1493
odp.vod likv.na ČOV	m3/den	249.03	247.82	246.68	245.55	244.27	243.14	242.01	240.73	239.59	238.46	237.18	236.05	234.92
odp.vod likv.v septických	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY 2018 Bystřany, 2018 Bystřany														
Množství odpadních vod	m3/den	249.03	247.82	246.68	245.55	244.27	243.14	242.01	240.73	239.59	238.46	237.18	236.05	234.92
BSK5	kg/d	95.08	94.62	94.18	93.74	93.24	92.80	92.36	91.86	91.42	90.98	90.48	90.04	89.60
NL	kg/d	87.16	86.74	86.33	85.93	85.47	85.07	84.66	84.21	83.80	83.40	82.94	82.54	82.13
CHSK	kg/d	174.31	173.47	172.66	171.86	170.94	170.13	169.33	168.41	167.60	166.80	165.88	165.07	164.27
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	0.00 0.00 0.00 0.00 0.00												
Množství vyčištěn.odp.vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Produkce kalu	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0292.02 Střelná

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	181.03	180.19	179.29	178.46	177.56	176.72	175.82	174.98	174.08	173.24	172.34	171.50	170.60
BSK5	kg/d	69.83	69.51	69.15	68.83	68.47	68.15	67.79	67.47	67.11	66.79	66.43	66.11	65.75
NL	kg/d	64.01	63.71	63.38	63.09	62.76	62.47	62.14	61.84	61.51	61.22	60.89	60.60	60.27
CHSK	kg/d	128.01	127.43	126.77	126.18	125.52	124.93	124.27	123.69	123.03	122.44	121.78	121.19	120.53
Počet EO	os.	1163	1158	1152	1147	1141	1135	1129	1124	1118	1113	1107	1101	1095
odp.vod likv.na ČOV	m3/den	171.63	170.94	170.04	169.21	168.46	167.62	166.72	166.03	165.13	164.29	163.39	162.70	161.65
odp.vod likv.v septicích	m3/den	9.40	9.25	9.25	9.25	9.10	9.10	9.10	8.95	8.95	8.95	8.95	8.80	8.95
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSLUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY														
2018 Bystřany, 2018 Bystřany														
Množství odpadních vod	m3/den	171.63	170.94	170.04	169.21	168.46	167.62	166.72	166.03	165.13	164.29	163.39	162.70	161.65
BSK5	kg/d	66.14	65.88	65.52	65.20	64.90	64.58	64.22	63.96	63.60	63.28	62.92	62.66	62.24
NL	kg/d	60.62	60.39	60.06	59.76	59.49	59.19	58.86	58.63	58.30	58.00	57.67	57.43	57.05
CHSK	kg/d	121.25	120.77	120.11	119.52	118.97	118.39	117.73	117.25	116.59	116.00	115.34	114.87	114.10
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	0.00 0.00 0.00 0.00 0.00												
Množství vyčištěn. odp.vod	m3/den	9.40	9.25	9.25	9.25	9.10	9.10	9.10	8.95	8.95	8.95	8.95	8.80	8.95
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	1.81	1.78	1.78	1.78	1.75	1.75	1.75	1.72	1.72	1.72	1.72	1.69	1.72
NL	kg/d	1.97	1.94	1.94	1.94	1.91	1.91	1.91	1.88	1.88	1.88	1.88	1.84	1.88
CHSK	kg/d	3.01	2.96	2.96	2.96	2.91	2.91	2.91	2.86	2.86	2.86	2.86	2.81	2.86
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	1.88	1.85	1.85	1.85	1.82	1.82	1.82	1.79	1.79	1.79	1.79	1.76	1.79
NL	kg/d	1.41	1.39	1.39	1.39	1.37	1.37	1.37	1.34	1.34	1.34	1.34	1.32	1.34
CHSK	kg/d	3.76	3.70	3.70	3.70	3.64	3.64	3.64	3.58	3.58	3.58	3.58	3.52	3.58
Produkce kalu	m3/r	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0293.01 Krupka

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	1878.25	1868.47	1858.78	1848.94	1839.30	1829.46	1819.77	1809.99	1800.30	1790.46	1780.83	1770.99	1761.24
BSK5	kg/d	747.18	743.30	739.44	735.52	731.70	727.78	723.92	720.04	716.18	712.26	708.44	704.52	700.62
NL	kg/d	684.92	681.36	677.82	674.23	670.73	667.13	663.59	660.04	656.50	652.91	649.40	645.81	642.24
CHSK	kg/d	1369.83	1362.72	1355.64	1348.45	1341.45	1334.26	1327.19	1320.07	1313.00	1305.81	1298.81	1291.62	1284.47
Počet EO	os.	12453	12388	12324	12258	12195	12129	12065	12000	11936	11871	11807	11742	11677
odp.vod likv.na ČOV	m3/den	1651.00	1642.42	1633.93	1625.29	1616.85	1608.21	1599.72	1591.14	1582.50	1573.86	1565.43	1556.79	1548.24
odp.vod likv.v septicích	m3/den	227.25	226.05	224.85	223.65	222.45	221.25	220.05	218.85	217.80	216.60	215.40	214.20	213.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY														
2018 Bystřany, 2018 Bystřany														
Množství odpadních vod	m3/den	1613.20	1604.92	1596.58	1588.09	1579.95	1571.46	1563.12	1554.84	1546.35	1537.86	1529.73	1521.24	1512.69
BSK5	kg/d	641.16	637.88	634.56	631.18	627.96	624.58	621.26	617.98	614.60	611.22	608.00	604.62	601.20
NL	kg/d	587.73	584.72	581.68	578.58	575.63	572.53	569.49	566.48	563.38	560.29	557.33	554.24	551.10
CHSK	kg/d	1175.46	1169.45	1163.36	1157.16	1151.26	1145.06	1138.98	1132.96	1126.77	1120.57	1114.67	1108.47	1102.20
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		Domovní mikročist., biof.												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	30.00 30.00 110.00 30.00 6.00												
Množství vyčišť.odp.vod	m3/den	227.25	226.05	224.85	223.65	222.45	221.25	220.05	218.85	217.80	216.60	215.40	214.20	213.00
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	45.45	45.21	44.97	44.73	44.49	44.25	44.01	43.77	43.56	43.32	43.08	42.84	42.60
NL	kg/d	49.24	48.98	48.72	48.46	48.20	47.94	47.68	47.42	47.19	46.93	46.67	46.41	46.15
CHSK	kg/d	75.75	75.35	74.95	74.55	74.15	73.75	73.35	72.95	72.60	72.20	71.80	71.40	71.00
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	45.45	45.21	44.97	44.73	44.49	44.25	44.01	43.77	43.56	43.32	43.08	42.84	42.60
NL	kg/d	34.09	33.91	33.73	33.55	33.37	33.19	33.01	32.83	32.67	32.49	32.31	32.13	31.95
CHSK	kg/d	90.90	90.42	89.94	89.46	88.98	88.50	88.02	87.54	87.12	86.64	86.16	85.68	85.20
Produkce kalu	m3/r	0.39	0.38	0.38	0.38	0.38	0.38	0.37	0.37	0.37	0.37	0.37	0.36	0.36
Způsob likv.kalu		neurčeno												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0293.03 Fojtovice

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	13.76	13.68	13.68	13.53	13.53	13.38	13.38	13.23	13.23	13.08	13.08	12.93	12.93
BSK5	kg/d	5.44	5.42	5.42	5.36	5.36	5.30	5.30	5.24	5.24	5.18	5.18	5.12	5.12
NL	kg/d	4.99	4.97	4.97	4.91	4.91	4.86	4.86	4.80	4.80	4.75	4.75	4.69	4.69
CHSK	kg/d	9.97	9.94	9.94	9.83	9.83	9.72	9.72	9.61	9.61	9.50	9.50	9.39	9.39
Počet EO	os.	90	90	90	89	89	88	88	87	87	86	86	85	85
odp.vod likv.na ČOV	m3/den	0.41	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33
odp.vod likv.v septicích	m3/den	13.35	13.35	13.35	13.20	13.20	13.05	13.05	12.90	12.90	12.75	12.75	12.60	12.60
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bystřany												
Množství odpadních vod	m3/den	0.41	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33
BSK5	kg/d	0.10	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08
NL	kg/d	0.09	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07
CHSK	kg/d	0.18	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišť.odp.vod	m3/den	13.35	13.35	13.35	13.20	13.20	13.05	13.05	12.90	12.90	12.75	12.75	12.60	12.60
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	2.67	2.67	2.67	2.64	2.64	2.61	2.61	2.58	2.58	2.55	2.55	2.52	2.52
NL	kg/d	2.89	2.89	2.89	2.86	2.86	2.83	2.83	2.80	2.80	2.76	2.76	2.73	2.73
CHSK	kg/d	4.45	4.45	4.45	4.40	4.40	4.35	4.35	4.30	4.30	4.25	4.25	4.20	4.20
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	2.67	2.67	2.67	2.64	2.64	2.61	2.61	2.58	2.58	2.55	2.55	2.52	2.52
NL	kg/d	2.00	2.00	2.00	1.98	1.98	1.96	1.96	1.94	1.94	1.91	1.91	1.89	1.89
CHSK	kg/d	5.34	5.34	5.34	5.28	5.28	5.22	5.22	5.16	5.16	5.10	5.10	5.04	5.04
Produkce kalu	m3/r	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0293.04 Horní Krupka

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	3.60	3.52	3.52	3.52	3.52	3.52	3.37	3.37	3.37	3.37	3.37	3.37	3.37
BSK5	kg/d	1.26	1.24	1.24	1.24	1.24	1.24	1.18	1.18	1.18	1.18	1.18	1.18	1.18
NL	kg/d	1.16	1.14	1.14	1.14	1.14	1.14	1.08	1.08	1.08	1.08	1.08	1.08	1.08
CHSK	kg/d	2.31	2.27	2.27	2.27	2.27	2.27	2.16	2.16	2.16	2.16	2.16	2.16	2.16
Počet EO	os.	21	20	20	20	20	20	19	19	19	19	19	19	19
odp.vod likv.na ČOV	m3/den	1.20	1.12	1.12	1.12	1.12	1.12	1.12	1.12	1.12	1.12	1.12	1.12	1.12
odp.vod likv.v septicích	m3/den	2.40	2.40	2.40	2.40	2.40	2.40	2.25	2.25	2.25	2.25	2.25	2.25	2.25
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bystřany												
Množství odpadních vod	m3/den	1.20	1.12	1.12	1.12	1.12	1.12	1.12	1.12	1.12	1.12	1.12	1.12	1.12
BSK5	kg/d	0.30	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28
NL	kg/d	0.28	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26
CHSK	kg/d	0.55	0.51	0.51	0.51	0.51	0.51	0.51	0.51	0.51	0.51	0.51	0.51	0.51
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišt.odp.vod	m3/den	2.40	2.40	2.40	2.40	2.40	2.40	2.25	2.25	2.25	2.25	2.25	2.25	2.25
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.48	0.48	0.48	0.48	0.48	0.48	0.45	0.45	0.45	0.45	0.45	0.45	0.45
NL	kg/d	0.52	0.52	0.52	0.52	0.52	0.52	0.49	0.49	0.49	0.49	0.49	0.49	0.49
CHSK	kg/d	0.80	0.80	0.80	0.80	0.80	0.80	0.75	0.75	0.75	0.75	0.75	0.75	0.75
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.48	0.48	0.48	0.48	0.48	0.48	0.45	0.45	0.45	0.45	0.45	0.45	0.45
NL	kg/d	0.36	0.36	0.36	0.36	0.36	0.36	0.34	0.34	0.34	0.34	0.34	0.34	0.34
CHSK	kg/d	0.96	0.96	0.96	0.96	0.96	0.96	0.90	0.90	0.90	0.90	0.90	0.90	0.90
Produkce kalu	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0293.07 Soběchleby

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	49.89	49.66	49.36	49.06	48.91	48.61	48.31	48.01	47.86	47.56	47.26	46.96	46.74
BSK5	kg/d	19.92	19.84	19.72	19.60	19.54	19.42	19.30	19.18	19.12	19.00	18.88	18.76	18.66
NL	kg/d	18.26	18.19	18.08	17.97	17.91	17.80	17.69	17.58	17.53	17.42	17.31	17.20	17.11
CHSK	kg/d	36.52	36.37	36.15	35.93	35.82	35.60	35.38	35.16	35.05	34.83	34.61	34.39	34.21
Počet EO	os.	332	330	328	326	325	323	321	319	318	316	314	312	311
odp.vod likv.na ČOV	m3/den	44.94	44.86	44.56	44.26	44.11	43.81	43.66	43.36	43.21	42.91	42.61	42.31	42.09
odp.vod likv.v septicích	m3/den	4.95	4.80	4.80	4.80	4.80	4.80	4.65	4.65	4.65	4.65	4.65	4.65	4.65
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY 2018 Bystřany, 2018 Bystřany														
Množství odpadních vod	m3/den	44.94	44.86	44.56	44.26	44.11	43.81	43.66	43.36	43.21	42.91	42.61	42.31	42.09
BSK5	kg/d	17.94	17.92	17.80	17.68	17.62	17.50	17.44	17.32	17.26	17.14	17.02	16.90	16.80
NL	kg/d	16.45	16.43	16.32	16.21	16.15	16.04	15.99	15.88	15.82	15.71	15.60	15.49	15.40
CHSK	kg/d	32.89	32.85	32.63	32.41	32.30	32.08	31.97	31.75	31.64	31.42	31.20	30.98	30.80
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	0.00 0.00 0.00 0.00 0.00												
Množství vyčištěn.odp.vod	m3/den	4.95	4.80	4.80	4.80	4.80	4.80	4.65	4.65	4.65	4.65	4.65	4.65	4.65
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.99	0.96	0.96	0.96	0.96	0.96	0.93	0.93	0.93	0.93	0.93	0.93	0.93
NL	kg/d	1.07	1.04	1.04	1.04	1.04	1.04	1.01	1.01	1.01	1.01	1.01	1.01	1.01
CHSK	kg/d	1.65	1.60	1.60	1.60	1.60	1.60	1.55	1.55	1.55	1.55	1.55	1.55	1.55
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.99	0.96	0.96	0.96	0.96	0.96	0.93	0.93	0.93	0.93	0.93	0.93	0.93
NL	kg/d	0.74	0.72	0.72	0.72	0.72	0.72	0.70	0.70	0.70	0.70	0.70	0.70	0.70
CHSK	kg/d	1.98	1.92	1.92	1.92	1.92	1.92	1.86	1.86	1.86	1.86	1.86	1.86	1.86
Produkce kalu	m3/r	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0294.01 Lahošť

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	94.50	95.40	96.45	97.50	98.55	99.60	100.65	101.70	102.75	103.80	104.85	105.90	106.95
BSK5	kg/d	37.23	37.59	38.01	38.43	38.85	39.27	39.69	40.11	40.53	40.95	41.37	41.79	42.21
NL	kg/d	34.13	34.46	34.84	35.23	35.61	36.00	36.38	36.77	37.15	37.54	37.92	38.31	38.69
CHSK	kg/d	68.26	68.92	69.69	70.46	71.23	72.00	72.77	73.54	74.31	75.08	75.85	76.62	77.39
Počet EO	os.	620	626	633	640	647	654	661	668	675	682	689	696	703
odp.vod likv.na ČOV	m3/den	62.45	63.05	63.80	64.55	65.15	65.90	66.65	67.25	68.00	68.60	69.35	70.10	70.55
odp.vod likv.v septicích	m3/den	32.05	32.35	32.65	32.95	33.40	33.70	34.00	34.45	34.75	35.20	35.50	35.80	36.40
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSLUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Želénky												
Množství odpadních vod	m3/den	62.45	63.05	63.80	64.55	65.15	65.90	66.65	67.25	68.00	68.60	69.35	70.10	70.55
BSK5	kg/d	24.60	24.84	25.14	25.44	25.68	25.98	26.28	26.52	26.82	27.06	27.36	27.66	27.84
NL	kg/d	22.55	22.77	23.05	23.32	23.54	23.82	24.09	24.31	24.59	24.81	25.08	25.36	25.52
CHSK	kg/d	45.10	45.54	46.09	46.64	47.08	47.63	48.18	48.62	49.17	49.61	50.16	50.71	51.04
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišť.odp.vod	m3/den	32.05	32.35	32.65	32.95	33.40	33.70	34.00	34.45	34.75	35.20	35.50	35.80	36.40
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	6.22	6.28	6.34	6.40	6.49	6.55	6.61	6.70	6.76	6.85	6.91	6.97	7.09
NL	kg/d	6.77	6.84	6.90	6.97	7.06	7.13	7.19	7.29	7.36	7.45	7.52	7.58	7.71
CHSK	kg/d	10.34	10.44	10.54	10.64	10.79	10.89	10.99	11.14	11.24	11.39	11.49	11.59	11.79
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	6.41	6.47	6.53	6.59	6.68	6.74	6.80	6.89	6.95	7.04	7.10	7.16	7.28
NL	kg/d	4.81	4.85	4.90	4.94	5.01	5.06	5.10	5.17	5.21	5.28	5.33	5.37	5.46
CHSK	kg/d	12.82	12.94	13.06	13.18	13.36	13.48	13.60	13.78	13.90	14.08	14.20	14.32	14.56
Produkce kalu	m3/r	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0295.01 Mikulov

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030										
CELKOVÁ PRODUKCE																								
odpadních vod	m3/den	63.15	63.60	64.05	64.65	65.10	65.55	66.15	66.60	67.05	67.65	68.10	68.55	69.15										
BSK5	kg/d	21.66	21.81	21.96	22.17	22.32	22.47	22.68	22.83	22.98	23.19	23.34	23.49	23.70										
NL	kg/d	19.86	19.99	20.13	20.32	20.46	20.60	20.79	20.93	21.07	21.26	21.40	21.53	21.73										
CHSK	kg/d	39.71	39.99	40.26	40.65	40.92	41.20	41.58	41.86	42.13	42.52	42.79	43.07	43.45										
Počet EO	os.	361	363	366	369	372	374	378	380	383	386	389	391	395										
odp.vod likv.na ČOV	m3/den	63.15	63.60	64.05	64.65	65.10	65.55	66.15	66.60	67.05	67.65	68.10	68.55	69.15										
odp.vod likv.v septicích	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
PŘÍTOK NA ČOV																								
Množství odpadních vod	m3/den	63.15	63.60	64.05	64.65	65.10	65.55	66.15	66.60	67.05	67.65	68.10	68.55	69.15										
BSK5	kg/d	21.66	21.81	21.96	22.17	22.32	22.47	22.68	22.83	22.98	23.19	23.34	23.49	23.70										
NL	kg/d	19.86	19.97	20.13	20.30	20.46	20.57	20.79	20.90	21.07	21.23	21.40	21.51	21.73										
CHSK	kg/d	39.71	39.93	40.26	40.59	40.92	41.14	41.58	41.80	42.13	42.46	42.79	43.01	43.45										
Počet EO	os.	361	363	366	369	372	374	378	380	383	386	389	391	395										
Typ ČOV		Aktivační čistírna																						
KONCENTRACE NA ODTOKU		stávající a navrhované řešení																						
	-																							
	mg/l	<table><tr><td>BSK5</td><td>NL</td><td>CHSK</td><td>N-celk</td><td>P-celk</td></tr><tr><td>20.00</td><td>20.00</td><td>90.00</td><td>35.00</td><td>8.00</td></tr></table>													BSK5	NL	CHSK	N-celk	P-celk	20.00	20.00	90.00	35.00	8.00
BSK5	NL	CHSK	N-celk	P-celk																				
20.00	20.00	90.00	35.00	8.00																				
Množství vyčišť.odp.vod	m3/den	63.15	63.60	64.05	64.65	65.10	65.55	66.15	66.60	67.05	67.65	68.10	68.55	69.15										
ODSTRANĚNÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	20.40	20.54	20.68	20.88	21.02	21.16	21.36	21.50	21.64	21.84	21.98	22.12	22.32										
NL	kg/d	18.59	18.69	18.85	19.00	19.16	19.26	19.47	19.57	19.72	19.88	20.03	20.13	20.34										
CHSK	kg/d	34.03	34.21	34.50	34.77	35.06	35.24	35.63	35.81	36.10	36.37	36.66	36.84	37.23										
ZBYTKOVÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	1.26	1.27	1.28	1.29	1.30	1.31	1.32	1.33	1.34	1.35	1.36	1.37	1.38										
NL	kg/d	1.26	1.27	1.28	1.29	1.30	1.31	1.32	1.33	1.34	1.35	1.36	1.37	1.38										
CHSK	kg/d	5.68	5.72	5.76	5.82	5.86	5.90	5.95	5.99	6.03	6.09	6.13	6.17	6.22										
Produkce kalu	m3/r	1.59	1.60	1.61	1.62	1.64	1.65	1.66	1.67	1.69	1.70	1.71	1.72	1.74										
Způsob likv.kalu		odvoz na jinou ČOV																						
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										

CZ042.3509.4213.0296.01 Modlany

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	154.42	154.42	154.57	154.72	154.87	154.87	155.02	155.17	155.32	155.32	155.47	155.62	155.77
BSK5	kg/d	61.21	61.21	61.27	61.33	61.39	61.39	61.45	61.51	61.57	61.57	61.63	61.69	61.75
NL	kg/d	56.10	56.10	56.16	56.21	56.27	56.27	56.32	56.38	56.43	56.43	56.49	56.54	56.60
CHSK	kg/d	112.21	112.21	112.32	112.43	112.54	112.54	112.65	112.76	112.87	112.87	112.98	113.09	113.20
Počet EO	os.	1020	1020	1021	1022	1023	1023	1024	1025	1026	1026	1027	1028	1029
odp.vod likv.na ČOV	m3/den	123.37	123.37	123.52	123.67	123.82	123.82	123.97	123.97	124.12	124.12	124.27	124.42	124.42
odp.vod likv.v septicích	m3/den	31.05	31.05	31.05	31.05	31.05	31.05	31.05	31.20	31.20	31.20	31.20	31.20	31.35
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT 2018 Kvítkov, 2018 Suché, 2018 Věštany														
Množství odpadních vod	m3/den	46.30	46.45	46.15	45.85	45.70	45.40	45.10	44.80	44.65	44.50	44.35	43.90	43.45
BSK5	kg/d	18.18	18.24	18.12	18.00	17.94	17.82	17.70	17.58	17.52	17.46	17.40	17.22	17.04
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY 2018 Bystřany														
Množství odpadních vod	m3/den	0.82	0.82	0.82	0.82	0.82	0.82	0.82	0.82	0.82	0.82	0.82	0.82	0.82
BSK5	kg/d	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22
NL	kg/d	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
CHSK	kg/d	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	168.85	169.00	168.85	168.70	168.70	168.40	168.25	167.95	167.95	167.80	167.80	167.50	167.05
BSK5	kg/d	66.84	66.90	66.84	66.78	66.78	66.66	66.60	66.48	66.48	66.42	66.42	66.30	66.12
NL	kg/d	44.61	44.61	44.66	44.72	44.77	44.77	44.83	44.83	44.88	44.88	44.94	44.99	44.99
CHSK	kg/d	89.21	89.21	89.32	89.43	89.54	89.54	89.65	89.65	89.76	89.76	89.87	89.98	89.98
Počet EO	os.	1114	1115	1114	1113	1113	1111	1110	1108	1108	1107	1107	1105	1102
Typ ČOV		Akt. č. denitrif.+nitrif.												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	3.40 4.40 18.80 0.00 0.00												
Množství vyčištěn.odp.vod	m3/den	199.90	200.05	199.90	199.75	199.75	199.45	199.30	199.15	199.15	199.00	199.00	198.70	198.40
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	72.39	72.45	72.39	72.33	72.33	72.21	72.15	72.06	72.06	72.00	72.00	71.88	71.73
NL	kg/d	50.51	50.51	50.56	50.62	50.67	50.67	50.73	50.76	50.82	50.82	50.87	50.93	50.96
CHSK	kg/d	96.22	96.22	96.33	96.44	96.55	96.56	96.67	96.73	96.84	96.84	96.95	97.07	97.12
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	6.78	6.78	6.78	6.78	6.78	6.78	6.78	6.81	6.81	6.81	6.81	6.81	6.84
NL	kg/d	5.40	5.40	5.40	5.40	5.40	5.40	5.40	5.42	5.42	5.42	5.42	5.42	5.44
CHSK	kg/d	15.59	15.60	15.59	15.59	15.59	15.59	15.58	15.64	15.64	15.63	15.63	15.63	15.68
Produkce kalu	m3/r	4.96	4.96	4.96	4.95	4.95	4.94	4.94	4.93	4.93	4.92	4.92	4.92	4.90
Způsob likv.kalu		odvoz na jinou ČOV												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0296.02 Drahkov

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030										
CELKOVÁ PRODUKCE																								
odpadních vod	m3/den	30.35	30.20	30.05	29.90	29.90	29.75	29.60	29.45	29.45	29.30	29.15	29.00	29.00										
BSK5	kg/d	11.31	11.25	11.19	11.13	11.13	11.07	11.01	10.95	10.95	10.89	10.83	10.77	10.77										
NL	kg/d	10.37	10.31	10.26	10.20	10.20	10.15	10.09	10.04	10.04	9.98	9.93	9.87	9.87										
CHSK	kg/d	20.74	20.63	20.52	20.41	20.41	20.30	20.19	20.08	20.08	19.97	19.86	19.75	19.75										
Počet EO	os.	188	187	186	185	185	184	183	182	182	181	180	179	179										
odp.vod likv.na ČOV	m3/den	28.50	28.50	28.35	28.20	28.20	28.05	27.90	27.75	27.75	27.60	27.45	27.30	27.30										
odp.vod likv.v septicích	m3/den	1.85	1.70	1.70	1.70	1.70	1.70	1.70	1.70	1.70	1.70	1.70	1.70	1.70										
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bystřany																						
Množství odpadních vod	m3/den	28.50	28.50	28.35	28.20	28.20	28.05	27.90	27.75	27.75	27.60	27.45	27.30	27.30										
BSK5	kg/d	10.62	10.62	10.56	10.50	10.50	10.44	10.38	10.32	10.32	10.26	10.20	10.14	10.14										
NL	kg/d	9.74	9.74	9.68	9.63	9.63	9.57	9.52	9.46	9.46	9.41	9.35	9.30	9.30										
CHSK	kg/d	19.47	19.47	19.36	19.25	19.25	19.14	19.03	18.92	18.92	18.81	18.70	18.59	18.59										
PŘÍTOK NA ČOV																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0										
Typ ČOV		žádná																						
KONCENTRACE NA ODTOKU		stávající a navrhované řešení																						
	-	<table><tr><td>BSK5</td><td>NL</td><td>CHSK</td><td>N-celk</td><td>P-celk</td></tr><tr><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td></tr></table>													BSK5	NL	CHSK	N-celk	P-celk	0.00	0.00	0.00	0.00	0.00
BSK5	NL	CHSK	N-celk	P-celk																				
0.00	0.00	0.00	0.00	0.00																				
	mg/l																							
Množství vyčišť.odp.vod	m3/den	1.85	1.70	1.70	1.70	1.70	1.70	1.70	1.70	1.70	1.70	1.70	1.70	1.70										
ODSTRANĚNÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	0.32	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.29										
NL	kg/d	0.36	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32										
CHSK	kg/d	0.53	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48										
ZBYTKOVÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	0.37	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34										
NL	kg/d	0.28	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26										
CHSK	kg/d	0.74	0.68	0.68	0.68	0.68	0.68	0.68	0.68	0.68	0.68	0.68	0.68	0.68										
Produkce kalu	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
Způsob likv.kalu																								
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										

CZ042.3509.4213.0296.03 Kvítkov

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030										
CELKOVÁ PRODUKCE																								
odpadních vod	m3/den	15.77	15.68	15.53	15.53	15.38	15.38	15.23	15.08	15.08	14.93	14.93	14.78	14.72										
BSK5	kg/d	6.22	6.20	6.14	6.14	6.08	6.08	6.02	5.96	5.96	5.90	5.90	5.84	5.80										
NL	kg/d	5.70	5.68	5.63	5.63	5.57	5.57	5.52	5.46	5.46	5.41	5.41	5.35	5.32										
CHSK	kg/d	11.40	11.37	11.26	11.26	11.15	11.15	11.04	10.93	10.93	10.82	10.82	10.71	10.63										
Počet EO	os.	103	103	102	102	101	101	100	99	99	98	98	97	96										
odp.vod likv.na ČOV	m3/den	9.77	9.83	9.68	9.68	9.68	9.68	9.53	9.38	9.38	9.38	9.38	9.23	9.17										
odp.vod likv.v septicích	m3/den	6.00	5.85	5.85	5.85	5.70	5.70	5.70	5.70	5.70	5.55	5.55	5.55	5.55										
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bystřany, 2018 Modlany																						
Množství odpadních vod	m3/den	9.77	9.83	9.68	9.68	9.68	9.68	9.53	9.38	9.38	9.38	9.38	9.23	9.17										
BSK5	kg/d	3.82	3.86	3.80	3.80	3.80	3.80	3.74	3.68	3.68	3.68	3.68	3.62	3.58										
NL	kg/d	3.50	3.54	3.48	3.48	3.48	3.48	3.43	3.37	3.37	3.37	3.37	3.32	3.28										
CHSK	kg/d	7.00	7.08	6.97	6.97	6.97	6.97	6.86	6.75	6.75	6.75	6.75	6.64	6.56										
PŘÍTOK NA ČOV																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0										
Typ ČOV		žádná																						
KONCENTRACE NA ODTOKU		stávající a navrhované řešení																						
	-																							
	mg/l	<table><tr><td>BSK5</td><td>NL</td><td>CHSK</td><td>N-celk</td><td>P-celk</td></tr><tr><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td></tr></table>													BSK5	NL	CHSK	N-celk	P-celk	0.00	0.00	0.00	0.00	0.00
BSK5	NL	CHSK	N-celk	P-celk																				
0.00	0.00	0.00	0.00	0.00																				
Množství vyčišt.odp.vod	m3/den	6.00	5.85	5.85	5.85	5.70	5.70	5.70	5.70	5.70	5.55	5.55	5.55	5.55										
ODSTRANĚNÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	1.20	1.17	1.17	1.17	1.14	1.14	1.14	1.14	1.14	1.11	1.11	1.11	1.11										
NL	kg/d	1.30	1.27	1.27	1.27	1.24	1.24	1.24	1.24	1.24	1.20	1.20	1.20	1.20										
CHSK	kg/d	2.00	1.95	1.95	1.95	1.90	1.90	1.90	1.90	1.90	1.85	1.85	1.85	1.85										
ZBYTKOVÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	1.20	1.17	1.17	1.17	1.14	1.14	1.14	1.14	1.14	1.11	1.11	1.11	1.11										
NL	kg/d	0.90	0.88	0.88	0.88	0.86	0.86	0.86	0.86	0.86	0.83	0.83	0.83	0.83										
CHSK	kg/d	2.40	2.34	2.34	2.34	2.28	2.28	2.28	2.28	2.28	2.22	2.22	2.22	2.22										
Produkce kalu	m3/r	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01										
Způsob likv.kalu																								
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										

CZ042.3509.4213.0296.04 Suché

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	13.90	13.82	13.82	13.67	13.67	13.52	13.52	13.37	13.37	13.22	13.22	13.07	13.00
BSK5	kg/d	5.58	5.56	5.56	5.50	5.50	5.44	5.44	5.38	5.38	5.32	5.32	5.26	5.22
NL	kg/d	5.11	5.09	5.09	5.04	5.04	4.98	4.98	4.93	4.93	4.87	4.87	4.82	4.78
CHSK	kg/d	10.22	10.18	10.18	10.07	10.07	9.96	9.96	9.85	9.85	9.74	9.74	9.63	9.56
Počet EO	os.	92	92	92	91	91	90	90	89	89	88	88	87	86
odp.vod likv.na ČOV	m3/den	10.45	10.37	10.37	10.22	10.22	10.07	10.07	10.07	10.07	9.92	9.92	9.77	9.70
odp.vod likv.v septicích	m3/den	3.45	3.45	3.45	3.45	3.45	3.45	3.45	3.30	3.30	3.30	3.30	3.30	3.30
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY 2018 Bystřany, 2018 Modlany														
Množství odpadních vod	m3/den	10.45	10.37	10.37	10.22	10.22	10.07	10.07	10.07	10.07	9.92	9.92	9.77	9.70
BSK5	kg/d	4.20	4.18	4.18	4.12	4.12	4.06	4.06	4.06	4.06	4.00	4.00	3.94	3.90
NL	kg/d	3.85	3.83	3.83	3.77	3.77	3.72	3.72	3.72	3.72	3.66	3.66	3.61	3.57
CHSK	kg/d	7.69	7.65	7.65	7.54	7.54	7.43	7.43	7.43	7.43	7.32	7.32	7.21	7.14
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	0.00 0.00 0.00 0.00 0.00												
Množství vyčištěn.odp.vod	m3/den	3.45	3.45	3.45	3.45	3.45	3.45	3.45	3.30	3.30	3.30	3.30	3.30	3.30
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.66	0.66	0.66	0.66	0.66	0.66
NL	kg/d	0.75	0.75	0.75	0.75	0.75	0.75	0.75	0.72	0.72	0.72	0.72	0.72	0.72
CHSK	kg/d	1.15	1.15	1.15	1.15	1.15	1.15	1.15	1.10	1.10	1.10	1.10	1.10	1.10
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.66	0.66	0.66	0.66	0.66	0.66
NL	kg/d	0.52	0.52	0.52	0.52	0.52	0.52	0.52	0.50	0.50	0.50	0.50	0.50	0.50
CHSK	kg/d	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.32	1.32	1.32	1.32	1.32	1.32
Produkce kalu	m3/r	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0296.05 Věštany

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	31.10	30.95	30.80	30.65	30.50	30.35	30.20	30.05	29.90	29.75	29.60	29.45	29.45
BSK5	kg/d	12.06	12.00	11.94	11.88	11.82	11.76	11.70	11.64	11.58	11.52	11.46	11.40	11.40
NL	kg/d	11.06	11.00	10.95	10.89	10.84	10.78	10.73	10.67	10.62	10.56	10.51	10.45	10.45
CHSK	kg/d	22.11	22.00	21.89	21.78	21.67	21.56	21.45	21.34	21.23	21.12	21.01	20.90	20.90
Počet EO	os.	201	200	199	198	197	196	195	194	193	192	191	190	190
odp.vod likv.na ČOV	m3/den	27.55	27.55	27.40	27.25	27.10	26.95	26.80	26.65	26.50	26.50	26.35	26.20	26.05
odp.vod likv.v septicích	m3/den	3.55	3.40	3.40	3.40	3.40	3.40	3.40	3.40	3.40	3.25	3.25	3.25	3.40
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY														
2018 Modlany														
Množství odpadních vod	m3/den	27.55	27.55	27.40	27.25	27.10	26.95	26.80	26.65	26.50	26.50	26.35	26.20	26.05
BSK5	kg/d	10.68	10.68	10.62	10.56	10.50	10.44	10.38	10.32	10.26	10.26	10.20	10.14	10.08
NL	kg/d	9.79	9.79	9.74	9.68	9.63	9.57	9.52	9.46	9.41	9.41	9.35	9.30	9.24
CHSK	kg/d	19.58	19.58	19.47	19.36	19.25	19.14	19.03	18.92	18.81	18.81	18.70	18.59	18.48
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	0.00 0.00 0.00 0.00 0.00												
Množství vyčištěn. odp. vod	m3/den	3.55	3.40	3.40	3.40	3.40	3.40	3.40	3.40	3.40	3.25	3.25	3.25	3.40
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.67	0.64	0.64	0.64	0.64	0.64	0.64	0.64	0.64	0.61	0.61	0.61	0.64
NL	kg/d	0.73	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.67	0.67	0.67	0.70
CHSK	kg/d	1.11	1.06	1.06	1.06	1.06	1.06	1.06	1.06	1.06	1.01	1.01	1.01	1.06
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.71	0.68	0.68	0.68	0.68	0.68	0.68	0.68	0.68	0.65	0.65	0.65	0.68
NL	kg/d	0.53	0.51	0.51	0.51	0.51	0.51	0.51	0.51	0.51	0.49	0.49	0.49	0.51
CHSK	kg/d	1.42	1.36	1.36	1.36	1.36	1.36	1.36	1.36	1.36	1.30	1.30	1.30	1.36
Produkce kalu	m3/r	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
Způsob likv. kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0297.01 Moldava

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	29.83	30.28	30.83	31.46	31.91	34.25	34.95	35.40	35.95	36.65	37.10	37.65	38.35
BSK5	kg/d	11.06	11.24	11.45	11.68	11.86	12.87	13.14	13.32	13.53	13.80	13.98	14.19	14.46
NL	kg/d	10.14	10.30	10.50	10.71	10.87	11.80	12.05	12.21	12.40	12.65	12.82	13.01	13.26
CHSK	kg/d	20.28	20.61	20.99	21.41	21.74	23.60	24.09	24.42	24.81	25.30	25.63	26.02	26.51
Počet EO	os.	184	187	190	194	197	214	219	222	225	230	233	236	241
odp.vod likv.na ČOV	m3/den	23.58	24.03	24.43	25.06	25.36	34.25	34.95	35.40	35.95	36.65	37.10	37.65	38.35
odp.vod likv.v septicích	m3/den	6.25	6.25	6.40	6.40	6.55	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY 2018 Bystřany														
Množství odpadních vod	m3/den	1.48	1.48	1.48	1.56	1.56	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.44	0.44	0.44	0.46	0.46	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.40	0.40	0.40	0.42	0.42	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.81	0.81	0.81	0.84	0.84	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	22.10	22.55	22.95	23.50	23.80	34.25	34.95	35.40	35.95	36.65	37.10	37.65	38.35
BSK5	kg/d	8.28	8.46	8.61	8.82	8.94	12.87	13.14	13.32	13.53	13.80	13.98	14.19	14.46
NL	kg/d	7.59	7.76	7.87	8.09	8.20	11.77	12.05	12.21	12.38	12.65	12.82	12.98	13.26
CHSK	kg/d	15.18	15.51	15.73	16.17	16.39	23.54	24.09	24.42	24.75	25.30	25.63	25.96	26.51
Počet EO	os.	138	141	143	147	149	214	219	222	225	230	233	236	241
Typ ČOV		Aktivační čistírna												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	20.00 20.00 90.00 35.00 8.00												
Množství vyčištěn. odp. vod	m3/den	28.35	28.80	29.35	29.90	30.35	34.25	34.95	35.40	35.95	36.65	37.10	37.65	38.35
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	8.93	9.10	9.27	9.47	9.61	12.19	12.44	12.61	12.81	13.07	13.24	13.44	13.69
NL	kg/d	8.36	8.51	8.65	8.86	8.99	11.09	11.35	11.50	11.66	11.92	12.07	12.23	12.49
CHSK	kg/d	14.98	15.27	15.50	15.90	16.14	20.46	20.94	21.23	21.51	22.00	22.29	22.57	23.06
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	1.69	1.70	1.74	1.75	1.79	0.69	0.70	0.71	0.72	0.73	0.74	0.75	0.77
NL	kg/d	1.38	1.39	1.42	1.43	1.46	0.69	0.70	0.71	0.72	0.73	0.74	0.75	0.77
CHSK	kg/d	4.49	4.53	4.63	4.68	4.76	3.08	3.15	3.19	3.24	3.30	3.34	3.39	3.45
Produkce kalu	m3/r	0.62	0.63	0.64	0.66	0.67	0.94	0.96	0.98	0.99	1.01	1.03	1.04	1.06
Způsob likv. kalu		odvoz na jinou ČOV												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0297.02 Nové Město

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	42.40	42.50	42.85	43.05	43.30	43.50	43.85	44.10	44.30	44.65	44.75	45.10	45.45
BSK5	kg/d	12.96	12.99	13.11	13.17	13.26	13.32	13.44	13.53	13.59	13.71	13.74	13.86	13.98
NL	kg/d	11.88	11.91	12.02	12.07	12.16	12.21	12.32	12.40	12.46	12.57	12.60	12.71	12.82
CHSK	kg/d	23.76	23.82	24.04	24.15	24.31	24.42	24.64	24.81	24.92	25.14	25.19	25.41	25.63
Počet EO	os.	216	216	218	219	221	222	224	225	226	228	229	231	233
odp.vod likv.na ČOV	m3/den	4.30	4.40	4.55	4.55	4.55	4.55	4.55	4.65	4.65	4.65	4.65	4.65	4.50
odp.vod likv.v septicích	m3/den	38.10	38.10	38.30	38.50	38.75	38.95	39.30	39.45	39.65	40.00	40.10	40.45	40.95
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	4.30	4.40	4.55	4.55	4.55	4.55	4.55	4.65	4.65	4.65	4.65	4.65	4.50
BSK5	kg/d	1.32	1.35	1.41	1.41	1.41	1.41	1.41	1.44	1.44	1.44	1.44	1.44	1.38
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	22	22	23	23	23	23	23	24	24	24	24	24	23
Typ ČOV		Domovní mikročist., biof.												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	30.0030.00110.0030.006.00												
Množství vyčišť.odp.vod	m3/den	42.40	42.50	42.85	43.05	43.30	43.50	43.85	44.10	44.30	44.65	44.75	45.10	45.45
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	5.21	5.24	5.31	5.33	5.37	5.39	5.44	5.50	5.52	5.57	5.58	5.63	5.65
NL	kg/d	4.83	4.82	4.84	4.87	4.91	4.94	5.00	5.03	5.05	5.11	5.12	5.18	5.27
CHSK	kg/d	5.63	5.62	5.63	5.66	5.72	5.75	5.83	5.87	5.90	5.98	6.00	6.08	6.23
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	7.75	7.75	7.80	7.84	7.89	7.93	8.00	8.03	8.07	8.14	8.16	8.23	8.33
NL	kg/d	5.84	5.85	5.88	5.91	5.95	5.98	6.03	6.06	6.09	6.14	6.15	6.21	6.28
CHSK	kg/d	15.71	15.72	15.82	15.90	16.00	16.08	16.22	16.29	16.37	16.51	16.55	16.69	16.88
Produkce kalu	m3/r	0.19	0.19	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.21	0.21	0.21	0.20
Způsob likv.kalu		neurčeno												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0298.01 Novosedlice

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	318.90	317.25	315.60	313.95	312.30	310.65	309.00	307.50	305.85	304.20	302.55	300.90	299.40
BSK5	kg/d	126.99	126.33	125.67	125.01	124.35	123.69	123.03	122.43	121.77	121.11	120.45	119.79	119.19
NL	kg/d	116.41	115.80	115.20	114.59	113.99	113.38	112.78	112.23	111.62	111.02	110.41	109.81	109.26
CHSK	kg/d	232.82	231.61	230.40	229.19	227.98	226.77	225.56	224.46	223.25	222.04	220.83	219.62	218.52
Počet EO	os.	2116	2105	2094	2083	2072	2061	2050	2040	2029	2018	2007	1996	1986
odp.vod likv.na ČOV	m3/den	293.35	291.85	290.35	288.85	287.35	285.85	284.35	283.00	281.35	279.85	278.35	276.85	275.35
odp.vod likv.v septicích	m3/den	25.55	25.40	25.25	25.10	24.95	24.80	24.65	24.50	24.50	24.35	24.20	24.05	24.05
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY 2018 Bystřany														
Množství odpadních vod	m3/den	293.35	291.85	290.35	288.85	287.35	285.85	284.35	283.00	281.35	279.85	278.35	276.85	275.35
BSK5	kg/d	116.82	116.22	115.62	115.02	114.42	113.82	113.22	112.68	112.02	111.42	110.82	110.22	109.62
NL	kg/d	107.09	106.54	105.99	105.44	104.89	104.34	103.79	103.29	102.69	102.14	101.59	101.04	100.49
CHSK	kg/d	214.17	213.07	211.97	210.87	209.77	208.67	207.57	206.58	205.37	204.27	203.17	202.07	200.97
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	0.00 0.00 0.00 0.00 0.00												
Množství vyčišť.odp.vod	m3/den	25.55	25.40	25.25	25.10	24.95	24.80	24.65	24.50	24.50	24.35	24.20	24.05	24.05
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	5.06	5.03	5.00	4.97	4.94	4.91	4.88	4.85	4.85	4.82	4.79	4.76	4.76
NL	kg/d	5.49	5.46	5.43	5.39	5.36	5.33	5.30	5.26	5.26	5.23	5.20	5.17	5.17
CHSK	kg/d	8.43	8.38	8.33	8.28	8.23	8.18	8.13	8.08	8.08	8.03	7.98	7.93	7.93
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	5.11	5.08	5.05	5.02	4.99	4.96	4.93	4.90	4.90	4.87	4.84	4.81	4.81
NL	kg/d	3.83	3.81	3.79	3.77	3.74	3.72	3.70	3.68	3.68	3.65	3.63	3.61	3.61
CHSK	kg/d	10.22	10.16	10.10	10.04	9.98	9.92	9.86	9.80	9.80	9.74	9.68	9.62	9.62
Produkce kalu	m3/r	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0299.01 Osek

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	692.05	692.10	692.25	692.30	692.45	692.50	692.65	692.70	692.85	692.90	693.05	693.10	693.25
BSK5	kg/d	276.36	276.39	276.45	276.48	276.54	276.57	276.63	276.66	276.72	276.75	276.81	276.84	276.90
NL	kg/d	253.33	253.36	253.41	253.44	253.50	253.52	253.58	253.61	253.66	253.69	253.74	253.77	253.83
CHSK	kg/d	506.66	506.72	506.83	506.88	506.99	507.05	507.16	507.21	507.32	507.38	507.49	507.54	507.65
Počet EO	os.	4606	4606	4607	4608	4609	4609	4610	4611	4612	4612	4613	4614	4615
odp.vod likv.na ČOV	m3/den	629.60	629.75	629.90	629.95	630.10	630.25	630.40	630.45	630.60	630.65	630.80	630.85	631.00
odp.vod likv.v septicích	m3/den	62.45	62.35	62.35	62.35	62.35	62.25	62.25	62.25	62.25	62.25	62.25	62.25	62.25
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY 2018 Želénky														
Množství odpadních vod	m3/den	629.60	629.75	629.90	629.95	630.10	630.25	630.40	630.45	630.60	630.65	630.80	630.85	631.00
BSK5	kg/d	251.43	251.49	251.55	251.58	251.64	251.70	251.76	251.79	251.85	251.88	251.94	251.97	252.03
NL	kg/d	230.48	230.53	230.59	230.62	230.67	230.73	230.78	230.81	230.86	230.89	230.95	230.97	231.03
CHSK	kg/d	460.96	461.07	461.18	461.23	461.34	461.45	461.56	461.62	461.73	461.78	461.89	461.95	462.06
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	0.00 0.00 0.00 0.00 0.00												
Množství vyčišť.odp.vod	m3/den	62.45	62.35	62.35	62.35	62.35	62.25	62.25	62.25	62.25	62.25	62.25	62.25	62.25
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	12.44	12.43	12.43	12.43	12.43	12.42	12.42	12.42	12.42	12.42	12.42	12.42	12.42
NL	kg/d	13.49	13.47	13.47	13.47	13.47	13.46	13.46	13.46	13.46	13.46	13.46	13.46	13.46
CHSK	kg/d	20.73	20.71	20.71	20.71	20.71	20.70	20.70	20.70	20.70	20.70	20.70	20.70	20.70
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	12.49	12.47	12.47	12.47	12.47	12.45	12.45	12.45	12.45	12.45	12.45	12.45	12.45
NL	kg/d	9.37	9.35	9.35	9.35	9.35	9.34	9.34	9.34	9.34	9.34	9.34	9.34	9.34
CHSK	kg/d	24.98	24.94	24.94	24.94	24.94	24.90	24.90	24.90	24.90	24.90	24.90	24.90	24.90
Produkce kalu	m3/r	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0299.02 Dlouhá Louka

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	7.53	7.68	7.76	7.84	7.92	8.00	8.08	8.16	8.31	8.39	8.47	8.55	8.49
BSK5	kg/d	5.36	5.42	5.44	5.46	5.48	5.50	5.52	5.54	5.60	5.62	5.64	5.66	5.60
NL	kg/d	4.91	4.96	4.98	5.00	5.02	5.04	5.06	5.07	5.13	5.15	5.17	5.18	5.13
CHSK	kg/d	9.82	9.93	9.96	10.00	10.04	10.07	10.11	10.15	10.26	10.29	10.33	10.37	10.26
Počet EO	os.	89	90	90	90	91	91	91	92	93	93	93	94	93
odp.vod likv.na ČOV	m3/den	7.53	7.68	7.76	7.84	7.92	8.00	8.08	8.16	8.31	8.39	8.47	8.55	8.49
odp.vod likv.v septicích	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Želénky												
Množství odpadních vod	m3/den	7.38	7.38	7.46	7.54	7.62	7.70	7.78	7.86	7.86	7.94	8.02	8.10	8.34
BSK5	kg/d	5.30	5.30	5.32	5.34	5.36	5.38	5.40	5.42	5.42	5.44	5.46	5.48	5.54
NL	kg/d	4.85	4.85	4.87	4.89	4.91	4.93	4.95	4.96	4.96	4.98	5.00	5.02	5.07
CHSK	kg/d	9.71	9.71	9.74	9.78	9.82	9.85	9.89	9.93	9.93	9.96	10.00	10.04	10.15
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.15	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.45	0.45	0.45	0.45	0.15
BSK5	kg/d	0.06	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.18	0.18	0.18	0.18	0.06
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	1	2	2	2	2	2	2	2	3	3	3	3	1
Typ ČOV		Domovní mikročist.,biof.												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	30.0030.00110.0030.006.00												
Množství vyčišť.odp.vod	m3/den	0.15	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.45	0.45	0.45	0.45	0.15
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.06	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.17	0.17	0.17	0.17	0.06
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.00	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.00
NL	kg/d	0.00	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.00
CHSK	kg/d	0.02	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.05	0.05	0.05	0.05	0.02
Produkce kalu	m3/r	0.00	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.00
Způsob likv.kalu		neurčeno												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0299.03 Hrad Osek

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030										
CELKOVÁ PRODUKCE																								
odpadních vod	m3/den	2.33	2.48	2.62	2.72	2.83	2.93	3.01	3.11	3.18	3.24	3.30	3.39	3.53										
BSK5	kg/d	0.71	0.77	0.79	0.81	0.87	0.89	0.91	0.97	0.99	1.01	1.03	1.09	1.13										
NL	kg/d	0.65	0.71	0.72	0.74	0.80	0.82	0.83	0.89	0.91	0.93	0.94	1.00	1.04										
CHSK	kg/d	1.30	1.41	1.45	1.49	1.60	1.63	1.67	1.78	1.82	1.85	1.89	2.00	2.07										
Počet EO	os.	11	12	13	13	14	14	15	16	16	16	17	18	18										
odp.vod likv.na ČOV	m3/den	2.33	2.48	2.62	2.72	2.83	2.93	3.01	3.11	3.18	3.24	3.30	3.39	3.53										
odp.vod likv.v septicích	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Želénky																						
Množství odpadních vod	m3/den	1.28	1.28	1.42	1.52	1.48	1.58	1.66	1.61	1.68	1.74	1.80	1.74	1.88										
BSK5	kg/d	0.35	0.35	0.37	0.39	0.39	0.41	0.43	0.43	0.45	0.47	0.49	0.49	0.53										
NL	kg/d	0.32	0.32	0.34	0.36	0.36	0.38	0.39	0.39	0.41	0.43	0.45	0.45	0.49										
CHSK	kg/d	0.64	0.64	0.68	0.72	0.72	0.75	0.79	0.79	0.83	0.86	0.90	0.90	0.97										
PŘÍTOK NA ČOV																								
Množství odpadních vod	m3/den	1.05	1.20	1.20	1.20	1.35	1.35	1.35	1.50	1.50	1.50	1.50	1.65	1.65										
BSK5	kg/d	0.36	0.42	0.42	0.42	0.48	0.48	0.48	0.54	0.54	0.54	0.54	0.60	0.60										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
Počet EO	os.	6	7	7	7	8	8	8	9	9	9	9	10	10										
Typ ČOV		Domovní mikročist.,biof.																						
KONCENTRACE NA ODTOKU		stávající a navrhované řešení																						
	-																							
	mg/l	<table><tr><td>BSK5</td><td>NL</td><td>CHSK</td><td>N-celk</td><td>P-celk</td></tr><tr><td>30.00</td><td>30.00</td><td>110.00</td><td>30.00</td><td>6.00</td></tr></table>													BSK5	NL	CHSK	N-celk	P-celk	30.00	30.00	110.00	30.00	6.00
BSK5	NL	CHSK	N-celk	P-celk																				
30.00	30.00	110.00	30.00	6.00																				
Množství vyčišť.odp.vod	m3/den	1.05	1.20	1.20	1.20	1.35	1.35	1.35	1.50	1.50	1.50	1.50	1.65	1.65										
ODSTRANĚNÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	0.33	0.38	0.38	0.38	0.44	0.44	0.44	0.50	0.50	0.50	0.50	0.55	0.55										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
ZBYTKOVÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	0.03	0.04	0.04	0.04	0.04	0.04	0.04	0.05	0.05	0.05	0.05	0.05	0.05										
NL	kg/d	0.03	0.04	0.04	0.04	0.04	0.04	0.04	0.05	0.05	0.05	0.05	0.05	0.05										
CHSK	kg/d	0.12	0.13	0.13	0.13	0.15	0.15	0.15	0.17	0.17	0.17	0.17	0.18	0.18										
Produkce kalu	m3/r	0.03	0.03	0.03	0.03	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04										
Způsob likv.kalu		neurčeno																						
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										

CZ042.3509.4213.0300.01 Proboštov

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	362.15	360.20	358.40	356.60	354.80	353.00	351.20	349.40	347.60	345.80	344.00	342.20	340.40
BSK5	kg/d	143.61	142.83	142.11	141.39	140.67	139.95	139.23	138.51	137.79	137.07	136.35	135.63	134.91
NL	kg/d	131.64	130.93	130.27	129.61	128.95	128.29	127.63	126.97	126.31	125.65	124.99	124.33	123.67
CHSK	kg/d	263.29	261.86	260.54	259.22	257.90	256.58	255.26	253.94	252.62	251.30	249.98	248.66	247.34
Počet EO	os.	2393	2380	2368	2356	2344	2332	2320	2308	2296	2284	2272	2260	2248
odp.vod likv.na ČOV	m3/den	318.65	317.00	315.50	313.85	312.20	310.70	309.05	307.55	305.90	304.40	302.75	301.10	299.60
odp.vod likv.v septicích	m3/den	43.50	43.20	42.90	42.75	42.60	42.30	42.15	41.85	41.70	41.40	41.25	41.10	40.80
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bystřany												
Množství odpadních vod	m3/den	318.65	317.00	315.50	313.85	312.20	310.70	309.05	307.55	305.90	304.40	302.75	301.10	299.60
BSK5	kg/d	126.36	125.70	125.10	124.44	123.78	123.18	122.52	121.92	121.26	120.66	120.00	119.34	118.74
NL	kg/d	115.83	115.23	114.68	114.07	113.47	112.92	112.31	111.76	111.16	110.61	110.00	109.40	108.85
CHSK	kg/d	231.66	230.45	229.35	228.14	226.93	225.83	224.62	223.52	222.31	221.21	220.00	218.79	217.69
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišť.odp.vod	m3/den	43.50	43.20	42.90	42.75	42.60	42.30	42.15	41.85	41.70	41.40	41.25	41.10	40.80
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	8.55	8.49	8.43	8.40	8.37	8.31	8.28	8.22	8.19	8.13	8.10	8.07	8.01
NL	kg/d	9.29	9.22	9.16	9.13	9.09	9.03	9.00	8.93	8.90	8.83	8.80	8.77	8.70
CHSK	kg/d	14.23	14.13	14.03	13.98	13.93	13.83	13.78	13.68	13.63	13.53	13.48	13.43	13.33
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	8.70	8.64	8.58	8.55	8.52	8.46	8.43	8.37	8.34	8.28	8.25	8.22	8.16
NL	kg/d	6.53	6.48	6.44	6.41	6.39	6.35	6.32	6.28	6.26	6.21	6.19	6.17	6.12
CHSK	kg/d	17.40	17.28	17.16	17.10	17.04	16.92	16.86	16.74	16.68	16.56	16.50	16.44	16.32
Produkce kalu	m3/r	0.08	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0300.02 Přítok

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030										
CELKOVÁ PRODUKCE																								
odpadních vod	m3/den	31.85	31.70	31.55	31.40	31.25	31.10	30.95	30.80	30.65	30.50	30.35	30.20	30.20										
BSK5	kg/d	12.27	12.21	12.15	12.09	12.03	11.97	11.91	11.85	11.79	11.73	11.67	11.61	11.61										
NL	kg/d	11.25	11.19	11.14	11.08	11.03	10.97	10.92	10.86	10.81	10.75	10.70	10.64	10.64										
CHSK	kg/d	22.50	22.39	22.28	22.17	22.06	21.95	21.84	21.73	21.62	21.51	21.40	21.29	21.29										
Počet EO	os.	204	203	202	201	200	199	198	197	196	195	194	193	193										
odp.vod likv.na ČOV	m3/den	29.35	29.35	29.20	29.05	28.90	28.75	28.60	28.45	28.30	28.15	28.00	27.85	27.70										
odp.vod likv.v septicích	m3/den	2.50	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.50										
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bystřany																						
Množství odpadních vod	m3/den	29.35	29.35	29.20	29.05	28.90	28.75	28.60	28.45	28.30	28.15	28.00	27.85	27.70										
BSK5	kg/d	11.31	11.31	11.25	11.19	11.13	11.07	11.01	10.95	10.89	10.83	10.77	10.71	10.65										
NL	kg/d	10.37	10.37	10.31	10.26	10.20	10.15	10.09	10.04	9.98	9.93	9.87	9.82	9.76										
CHSK	kg/d	20.74	20.74	20.63	20.52	20.41	20.30	20.19	20.08	19.97	19.86	19.75	19.64	19.53										
PŘÍTOK NA ČOV																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0										
Typ ČOV		žádná																						
KONCENTRACE NA ODTOKU		stávající a navrhované řešení																						
	-																							
	mg/l	<table><tr><td>BSK5</td><td>NL</td><td>CHSK</td><td>N-celk</td><td>P-celk</td></tr><tr><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td></tr></table>													BSK5	NL	CHSK	N-celk	P-celk	0.00	0.00	0.00	0.00	0.00
BSK5	NL	CHSK	N-celk	P-celk																				
0.00	0.00	0.00	0.00	0.00																				
Množství vyčišt.odp.vod	m3/den	2.50	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.35	2.50										
ODSTRANĚNÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	0.46	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.46										
NL	kg/d	0.51	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.51										
CHSK	kg/d	0.76	0.71	0.71	0.71	0.71	0.71	0.71	0.71	0.71	0.71	0.71	0.71	0.76										
ZBYTKOVÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	0.50	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.50										
NL	kg/d	0.38	0.35	0.35	0.35	0.35	0.35	0.35	0.35	0.35	0.35	0.35	0.35	0.38										
CHSK	kg/d	1.00	0.94	0.94	0.94	0.94	0.94	0.94	0.94	0.94	0.94	0.94	0.94	1.00										
Produkce kalu	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
Způsob likv.kalu																								
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										

CZ042.3509.4213.0301.01 Rtně nad Bilinou

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	52.70	52.45	52.15	51.85	51.55	51.25	51.10	50.80	52.15	51.85	51.55	51.25	51.10
BSK5	kg/d	20.79	20.71	20.59	20.47	20.35	20.23	20.17	20.05	20.76	20.64	20.52	20.40	20.34
NL	kg/d	19.06	18.98	18.87	18.76	18.65	18.54	18.49	18.38	19.03	18.92	18.81	18.70	18.65
CHSK	kg/d	38.12	37.97	37.75	37.53	37.31	37.09	36.98	36.76	38.06	37.84	37.62	37.40	37.29
Počet EO	os.	346	345	343	341	339	337	336	334	346	344	342	340	339
odp.vod likv.na ČOV	m3/den	9.95	10.15	10.00	10.00	9.85	9.85	9.85	9.85	52.15	51.85	51.55	51.25	51.10
odp.vod likv.v septicích	m3/den	37.35	37.05	36.90	36.60	36.45	36.30	36.15	35.85	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	5.40	5.25	5.25	5.25	5.25	5.10	5.10	5.10	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT 2026 Malhostice, 2026 Sezemice, 2026 Vrahožily														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	29.90	29.90	29.75	29.75	29.75
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	11.49	11.49	11.43	11.43	11.43
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bystřany												
Množství odpadních vod	m3/den	2.00	1.90	1.90	1.90	1.90	1.90	1.90	1.90	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.51	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.47	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.94	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.00	0.00	0.00	0.00	0.00
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	7.95	8.25	8.10	8.10	7.95	7.95	7.95	7.95	82.05	81.75	81.30	81.00	80.85
BSK5	kg/d	3.18	3.30	3.24	3.24	3.18	3.18	3.18	3.18	32.25	32.13	31.95	31.83	31.77
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	19.03	18.92	18.81	18.70	18.65
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	38.06	37.84	37.62	37.40	37.29
Počet EO	os.	53	55	54	54	53	53	53	53	537	535	532	530	529
Typ ČOV		Domovní mikročist.,biof.						Aktivační čistírna						
KONCENTRACE NA ODTOKU		stávající					navrhované řešení							
	-	BSK5	NL	CHSK	N-celk	P-celk	BSK5	NL	CHSK	N-celk	P-celk			
	mg/l	30.00	30.00	110.00	30.00	6.00	20.00	20.00	90.00	35.00	8.00			
Množství vyčišť.odp.vod	m3/den	45.30	45.30	45.00	44.70	44.40	44.25	44.10	43.80	82.05	81.75	81.30	81.00	80.85
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	10.41	10.46	10.38	10.32	10.23	10.20	10.17	10.11	30.61	30.50	30.32	30.21	30.15
NL	kg/d	7.85	7.78	7.75	7.69	7.66	7.63	7.59	7.53	17.39	17.29	17.18	17.08	17.03
CHSK	kg/d	11.58	11.44	11.41	11.31	11.28	11.23	11.18	11.08	30.68	30.48	30.30	30.11	30.01
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	9.87	9.76	9.72	9.66	9.63	9.54	9.51	9.45	1.64	1.64	1.63	1.62	1.62
NL	kg/d	7.82	7.73	7.70	7.66	7.63	7.55	7.53	7.49	1.64	1.64	1.63	1.62	1.62
CHSK	kg/d	19.77	19.58	19.50	19.38	19.30	19.13	19.07	18.95	7.38	7.36	7.32	7.29	7.28
Produkce kalu	m3/r	0.30	0.30	0.30	0.30	0.30	0.29	0.29	0.29	2.36	2.35	2.34	2.33	2.33
Způsob likv.kalu		neurčeno												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0301.02 Malhostice

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030										
CELKOVÁ PRODUKCE																								
odpadních vod	m3/den	10.05	9.90	9.90	9.90	9.75	9.75	9.75	9.60	9.60	9.60	9.45	9.45	9.45										
BSK5	kg/d	4.02	3.96	3.96	3.96	3.90	3.90	3.90	3.84	3.84	3.84	3.78	3.78	3.78										
NL	kg/d	3.69	3.63	3.63	3.63	3.58	3.58	3.58	3.52	3.52	3.52	3.47	3.47	3.47										
CHSK	kg/d	7.37	7.26	7.26	7.26	7.15	7.15	7.15	7.04	7.04	7.04	6.93	6.93	6.93										
Počet EO	os.	67	66	66	66	65	65	65	64	64	64	63	63	63										
odp.vod likv.na ČOV	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	9.60	9.60	9.45	9.45	9.45										
odp.vod likv.v septicích	m3/den	7.05	7.05	7.05	7.05	6.90	6.90	6.90	6.75	0.00	0.00	0.00	0.00	0.00										
odp.vod likv.jiným způsobem	m3/den	3.00	2.85	2.85	2.85	2.85	2.85	2.85	2.85	0.00	0.00	0.00	0.00	0.00										
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2026 Rtyně nad Bílinou																						
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	9.60	9.60	9.45	9.45	9.45										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.84	3.84	3.78	3.78	3.78										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.52	3.52	3.47	3.47	3.47										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	7.04	7.04	6.93	6.93	6.93										
PŘÍTOK NA ČOV																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0										
Typ ČOV		žádná																						
KONCENTRACE NA ODTOKU		stávající a navrhované řešení																						
	-	<table><tr><td>BSK5</td><td>NL</td><td>CHSK</td><td>N-celk</td><td>P-celk</td></tr><tr><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td></tr></table>													BSK5	NL	CHSK	N-celk	P-celk	0.00	0.00	0.00	0.00	0.00
BSK5	NL	CHSK	N-celk	P-celk																				
0.00	0.00	0.00	0.00	0.00																				
	mg/l																							
Množství vyčišt.odp.vod	m3/den	7.05	7.05	7.05	7.05	6.90	6.90	6.90	6.75	0.00	0.00	0.00	0.00	0.00										
ODSTRANĚNÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	1.41	1.41	1.41	1.41	1.38	1.38	1.38	1.35	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	1.53	1.53	1.53	1.53	1.50	1.50	1.50	1.46	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	2.35	2.35	2.35	2.35	2.30	2.30	2.30	2.25	0.00	0.00	0.00	0.00	0.00										
ZBYTKOVÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	2.61	2.55	2.55	2.55	2.52	2.52	2.52	2.49	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	2.16	2.10	2.10	2.10	2.08	2.08	2.08	2.06	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	5.02	4.91	4.91	4.91	4.85	4.85	4.85	4.79	0.00	0.00	0.00	0.00	0.00										
Produkce kalu	m3/r	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.00										
Způsob likv.kalu																								
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										

CZ042.3509.4213.0301.03 Sezemice

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	16.26	16.18	16.18	16.03	16.03	15.88	15.88	15.88	16.85	16.85	16.70	16.70	16.70
BSK5	kg/d	6.26	6.24	6.24	6.18	6.18	6.12	6.12	6.12	6.27	6.27	6.21	6.21	6.21
NL	kg/d	5.74	5.72	5.72	5.67	5.67	5.61	5.61	5.61	5.75	5.75	5.69	5.69	5.69
CHSK	kg/d	11.48	11.44	11.44	11.33	11.33	11.22	11.22	11.22	11.50	11.50	11.39	11.39	11.39
Počet EO	os.	104	104	104	103	103	102	102	102	104	104	103	103	103
odp.vod likv.na ČOV	m3/den	2.16	2.38	2.38	2.38	2.38	2.38	2.38	2.38	16.85	16.85	16.70	16.70	16.70
odp.vod likv.v septicích	m3/den	12.15	12.00	12.00	11.85	11.85	11.70	11.70	11.70	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	1.95	1.80	1.80	1.80	1.80	1.80	1.80	1.80	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bystřany, 2026 Rtně nad Bílinou												
Množství odpadních vod	m3/den	0.36	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.23	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.21	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.42	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.00	0.00	0.00	0.00	0.00
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	1.80	2.10	2.10	2.10	2.10	2.10	2.10	2.10	1.65	1.65	1.50	1.50	1.50
BSK5	kg/d	0.72	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.66	0.66	0.60	0.60	0.60
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	12	14	14	14	14	14	14	14	11	11	10	10	10
Typ ČOV		Domovní mikročist.,biof.												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	30.0030.00110.0030.006.00												
Množství vyčišt.odp.vod	m3/den	13.95	14.10	14.10	13.95	13.95	13.80	13.80	13.80	1.65	1.65	1.50	1.50	1.50
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	2.77	2.85	2.85	2.82	2.82	2.79	2.79	2.79	0.61	0.61	0.56	0.56	0.56
NL	kg/d	2.28	2.23	2.23	2.20	2.20	2.17	2.17	2.17	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	3.25	3.16	3.16	3.11	3.11	3.06	3.06	3.06	0.00	0.00	0.00	0.00	0.00
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	3.26	3.18	3.18	3.15	3.15	3.12	3.12	3.12	0.05	0.05	0.05	0.05	0.05
NL	kg/d	2.59	2.52	2.52	2.50	2.50	2.48	2.48	2.48	0.05	0.05	0.05	0.05	0.05
CHSK	kg/d	6.49	6.35	6.35	6.29	6.29	6.23	6.23	6.23	0.18	0.18	0.17	0.17	0.17
Produkce kalu	m3/r	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.05	0.05	0.04	0.04	0.04
Způsob likv.kalu		neurčeno												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0301.04 Velvěty

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	30.80	30.57	30.42	30.27	30.12	29.97	29.82	29.67	30.15	30.00	29.85	29.70	29.55
BSK5	kg/d	12.20	12.12	12.06	12.00	11.94	11.88	11.82	11.76	12.06	12.00	11.94	11.88	11.82
NL	kg/d	11.18	11.11	11.06	11.00	10.95	10.89	10.84	10.78	11.06	11.00	10.95	10.89	10.84
CHSK	kg/d	22.37	22.22	22.11	22.00	21.89	21.78	21.67	21.56	22.11	22.00	21.89	21.78	21.67
Počet EO	os.	203	202	201	200	199	198	197	196	201	200	199	198	197
odp.vod likv.na ČOV	m3/den	0.80	0.72	0.72	0.72	0.72	0.72	0.72	0.72	30.15	30.00	29.85	29.70	29.55
odp.vod likv.v septicích	m3/den	25.20	25.20	25.05	24.90	24.75	24.60	24.60	24.45	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	4.80	4.65	4.65	4.65	4.65	4.65	4.50	4.50	0.00	0.00	0.00	0.00	0.00
PŘÍSLUN ODPADNÍCH VOD Z JINÝCH LOKALIT 2026 Kozlíky														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	9.00	8.85	8.85	8.85	8.85
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.60	3.54	3.54	3.54	3.54
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bystřany												
Množství odpadních vod	m3/den	0.80	0.72	0.72	0.72	0.72	0.72	0.72	0.72	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.20	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.18	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.37	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.00	0.00	0.00	0.00	0.00
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	39.15	38.85	38.70	38.55	38.40
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	15.66	15.54	15.48	15.42	15.36
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	11.06	11.00	10.95	10.89	10.84
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.11	22.00	21.89	21.78	21.67
Počet EO	os.	0	0	0	0	0	0	0	0	261	259	258	257	256
Typ ČOV		žádná						Akt. č. denitrif.+nitrif.						
KONCENTRACE NA ODTOKU		stávající					navrhované řešení							
	-	BSK5	NL	CHSK	N-celk	P-celk	BSK5	NL	CHSK	N-celk	P-celk			
	mg/l	0.00	0.00	0.00	0.00	0.00	15.00	20.00	80.00	20.00	7.00			
Množství vyčišť.odp.vod	m3/den	25.20	25.20	25.05	24.90	24.75	24.60	24.60	24.45	39.15	38.85	38.70	38.55	38.40
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	5.04	5.04	5.01	4.98	4.95	4.92	4.92	4.89	15.07	14.96	14.90	14.84	14.78
NL	kg/d	5.46	5.46	5.43	5.40	5.36	5.33	5.33	5.30	10.27	10.22	10.17	10.12	10.07
CHSK	kg/d	8.40	8.40	8.35	8.30	8.25	8.20	8.20	8.15	18.98	18.89	18.79	18.70	18.60
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	6.96	6.90	6.87	6.84	6.81	6.78	6.72	6.69	0.59	0.58	0.58	0.58	0.58
NL	kg/d	5.54	5.49	5.46	5.44	5.42	5.40	5.34	5.32	0.78	0.78	0.77	0.77	0.77
CHSK	kg/d	13.60	13.49	13.43	13.37	13.31	13.25	13.14	13.08	3.13	3.11	3.10	3.08	3.07
Produkce kalu	m3/r	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	1.15	1.14	1.14	1.13	1.13
Způsob likv.kalu		neurčeno												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0301.05 Vrahožily

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030										
CELKOVÁ PRODUKCE																								
odpadních vod	m3/den	5.40	5.25	5.25	5.25	5.25	5.25	5.25	5.10	5.10	5.10	5.10	5.10	5.10										
BSK5	kg/d	2.16	2.10	2.10	2.10	2.10	2.10	2.10	2.04	2.04	2.04	2.04	2.04	2.04										
NL	kg/d	1.98	1.93	1.93	1.93	1.93	1.93	1.93	1.87	1.87	1.87	1.87	1.87	1.87										
CHSK	kg/d	3.96	3.85	3.85	3.85	3.85	3.85	3.85	3.74	3.74	3.74	3.74	3.74	3.74										
Počet EO	os.	36	35	35	35	35	35	35	34	34	34	34	34	34										
odp.vod likv.na ČOV	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.10	5.10	5.10	5.10	5.10										
odp.vod likv.v septicích	m3/den	5.40	5.25	5.25	5.25	5.25	5.25	5.25	5.10	0.00	0.00	0.00	0.00	0.00										
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2026 Rtyně nad Bílinou																						
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.10	5.10	5.10	5.10	5.10										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.04	2.04	2.04	2.04	2.04										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.87	1.87	1.87	1.87	1.87										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.74	3.74	3.74	3.74	3.74										
PŘÍTOK NA ČOV																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0										
Typ ČOV		žádná																						
KONCENTRACE NA ODTOKU		stávající a navrhované řešení																						
	-	<table><tr><td>BSK5</td><td>NL</td><td>CHSK</td><td>N-celk</td><td>P-celk</td></tr><tr><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td></tr></table>													BSK5	NL	CHSK	N-celk	P-celk	0.00	0.00	0.00	0.00	0.00
BSK5	NL	CHSK	N-celk	P-celk																				
0.00	0.00	0.00	0.00	0.00																				
	mg/l																							
Množství vyčišt.odp.vod	m3/den	5.40	5.25	5.25	5.25	5.25	5.25	5.25	5.10	0.00	0.00	0.00	0.00	0.00										
ODSTRANĚNÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	1.08	1.05	1.05	1.05	1.05	1.05	1.05	1.02	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	1.17	1.14	1.14	1.14	1.14	1.14	1.14	1.11	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	1.80	1.75	1.75	1.75	1.75	1.75	1.75	1.70	0.00	0.00	0.00	0.00	0.00										
ZBYTKOVÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	1.08	1.05	1.05	1.05	1.05	1.05	1.05	1.02	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.81	0.79	0.79	0.79	0.79	0.79	0.79	0.77	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	2.16	2.10	2.10	2.10	2.10	2.10	2.10	2.04	0.00	0.00	0.00	0.00	0.00										
Produkce kalu	m3/r	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.00										
Způsob likv.kalu																								
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										

CZ042.3509.4213.0301.06 Kozlíky

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	9.14	9.04	9.04	8.88	8.88	8.88	8.72	8.72	9.00	8.85	8.85	8.85	8.85
BSK5	kg/d	3.50	3.48	3.48	3.42	3.42	3.42	3.36	3.36	3.60	3.54	3.54	3.54	3.54
NL	kg/d	3.21	3.19	3.19	3.14	3.14	3.14	3.08	3.08	3.30	3.25	3.25	3.25	3.25
CHSK	kg/d	6.42	6.38	6.38	6.27	6.27	6.27	6.16	6.16	6.60	6.49	6.49	6.49	6.49
Počet EO	os.	58	58	58	57	57	57	56	56	60	59	59	59	59
odp.vod likv.na ČOV	m3/den	0.74	0.64	0.64	0.63	0.63	0.63	0.62	0.62	9.00	8.85	8.85	8.85	8.85
odp.vod likv.v septicích	m3/den	7.50	7.65	7.65	7.50	7.50	7.50	7.35	7.35	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	0.90	0.75	0.75	0.75	0.75	0.75	0.75	0.75	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bystřany, 2026 Velvěty												
Množství odpadních vod	m3/den	0.74	0.64	0.64	0.63	0.63	0.63	0.62	0.62	9.00	8.85	8.85	8.85	8.85
BSK5	kg/d	0.14	0.12	0.12	0.12	0.12	0.12	0.12	0.12	3.60	3.54	3.54	3.54	3.54
NL	kg/d	0.13	0.11	0.11	0.11	0.11	0.11	0.11	0.11	3.30	3.25	3.25	3.25	3.25
CHSK	kg/d	0.26	0.22	0.22	0.22	0.22	0.22	0.22	0.22	6.60	6.49	6.49	6.49	6.49
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišt.odp.vod	m3/den	7.50	7.65	7.65	7.50	7.50	7.50	7.35	7.35	0.00	0.00	0.00	0.00	0.00
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	1.50	1.53	1.53	1.50	1.50	1.50	1.47	1.47	0.00	0.00	0.00	0.00	0.00
NL	kg/d	1.63	1.66	1.66	1.63	1.63	1.63	1.59	1.59	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	2.50	2.55	2.55	2.50	2.50	2.50	2.45	2.45	0.00	0.00	0.00	0.00	0.00
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	1.86	1.83	1.83	1.80	1.80	1.80	1.77	1.77	0.00	0.00	0.00	0.00	0.00
NL	kg/d	1.46	1.42	1.42	1.40	1.40	1.40	1.38	1.38	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	3.66	3.61	3.61	3.55	3.55	3.55	3.49	3.49	0.00	0.00	0.00	0.00	0.00
Produkce kalu	m3/r	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.00
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0302.01 Srbsice

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	72.50	72.41	72.43	72.45	72.57	76.65	76.40	76.30	76.30	76.20	76.10	76.00	76.00
BSK5	kg/d	26.68	26.71	26.76	26.81	26.89	29.88	29.88	29.94	30.03	30.09	30.15	30.21	30.30
NL	kg/d	24.45	24.48	24.53	24.57	24.64	27.39	27.39	27.45	27.53	27.58	27.64	27.69	27.78
CHSK	kg/d	48.90	48.96	49.05	49.14	49.29	54.78	54.78	54.89	55.06	55.17	55.28	55.39	55.55
Počet EO	os.	444	445	445	446	448	498	498	499	500	501	502	503	505
odp.vod likv.na ČOV	m3/den	72.50	72.41	72.43	72.45	72.57	76.65	76.40	76.30	76.30	76.20	76.10	76.00	76.00
odp.vod likv.v septicích	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bystřany, 2018 Bystřany												
Množství odpadních vod	m3/den	69.35	69.26	69.28	69.30	69.27	73.35	73.10	73.00	73.00	72.75	72.65	72.55	72.55
BSK5	kg/d	25.42	25.45	25.50	25.55	25.57	28.56	28.56	28.62	28.71	28.71	28.77	28.83	28.92
NL	kg/d	23.30	23.32	23.37	23.42	23.43	26.18	26.18	26.24	26.32	26.32	26.37	26.43	26.51
CHSK	kg/d	46.59	46.65	46.74	46.83	46.87	52.36	52.36	52.47	52.64	52.64	52.75	52.86	53.02
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		Domovní mikročist.,biof.												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	30.0030.00110.0030.006.00												
Množství vyčišt.odp.vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Produkce kalu	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Způsob likv.kalu		neurčeno												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0303.01 Teplice

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	7350.77	7312.37	7274.13	7235.84	7197.59	7159.15	7120.90	7082.61	7044.37	7005.97	6967.68	6929.43	6891.14
BSK5	kg/d	2919.76	2904.46	2889.22	2873.94	2858.70	2843.36	2828.12	2812.84	2797.60	2782.30	2767.02	2751.78	2736.50
NL	kg/d	2676.44	2662.42	2648.45	2634.44	2620.47	2606.41	2592.44	2578.43	2564.46	2550.44	2536.43	2522.46	2508.45
CHSK	kg/d	5352.88	5324.83	5296.89	5268.88	5240.94	5212.82	5184.88	5156.86	5128.92	5100.87	5072.86	5044.92	5016.91
Počet EO	os.	48662	48407	48153	47898	47644	47389	47135	46880	46626	46371	46116	45862	45608
odp.vod likv.na ČOV	m3/den	7203.27	7165.78	7128.28	7090.74	7053.24	7015.55	6978.05	6940.51	6903.02	6865.52	6827.98	6790.48	6752.94
odp.vod likv.v septicích	m3/den	147.50	146.60	145.85	145.10	144.35	143.60	142.85	142.10	141.35	140.45	139.70	138.95	138.20
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY														
2018 Bystřany, 2018 Bystřany														
Množství odpadních vod	m3/den	7203.27	7165.78	7128.28	7090.74	7053.24	7015.55	6978.05	6940.51	6903.02	6865.52	6827.98	6790.48	6752.94
BSK5	kg/d	2860.99	2846.05	2831.11	2816.13	2801.19	2786.15	2771.21	2756.23	2741.29	2726.35	2711.37	2696.43	2681.45
NL	kg/d	2622.57	2608.87	2595.18	2581.45	2567.75	2553.97	2540.27	2526.54	2512.84	2499.15	2485.42	2471.72	2457.99
CHSK	kg/d	5245.14	5217.75	5190.36	5162.90	5135.51	5107.93	5080.54	5053.08	5025.69	4998.30	4970.84	4943.45	4915.98
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	0.00 0.00 0.00 0.00 0.00												
Množství vyčištěn. odp.vod	m3/den	147.50	146.60	145.85	145.10	144.35	143.60	142.85	142.10	141.35	140.45	139.70	138.95	138.20
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	29.27	29.09	28.94	28.79	28.64	28.49	28.34	28.19	28.04	27.86	27.71	27.56	27.41
NL	kg/d	31.75	31.55	31.39	31.23	31.07	30.90	30.74	30.58	30.42	30.22	30.06	29.90	29.73
CHSK	kg/d	48.75	48.45	48.20	47.95	47.70	47.45	47.20	46.95	46.70	46.40	46.15	45.90	45.65
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	29.50	29.32	29.17	29.02	28.87	28.72	28.57	28.42	28.27	28.09	27.94	27.79	27.64
NL	kg/d	22.13	21.99	21.88	21.77	21.65	21.54	21.43	21.32	21.20	21.07	20.96	20.84	20.73
CHSK	kg/d	59.00	58.64	58.34	58.04	57.74	57.44	57.14	56.84	56.54	56.18	55.88	55.58	55.28
Produkce kalu	m3/r	0.25	0.25	0.25	0.25	0.25	0.25	0.24	0.24	0.24	0.24	0.24	0.24	0.24
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0304.01 Újezdeček

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	133.70	135.95	138.35	140.75	143.15	145.55	147.95	150.20	152.60	155.00	157.40	159.80	162.20
BSK5	kg/d	53.43	54.33	55.29	56.25	57.21	58.17	59.13	60.03	60.99	61.95	62.91	63.87	64.83
NL	kg/d	48.98	49.80	50.68	51.56	52.44	53.32	54.20	55.03	55.91	56.79	57.67	58.55	59.43
CHSK	kg/d	97.96	99.61	101.37	103.13	104.89	106.65	108.41	110.06	111.82	113.58	115.34	117.10	118.86
Počet EO	os.	890	905	921	937	953	969	985	1000	1016	1032	1048	1064	1080
odp.vod likv.na ČOV	m3/den	133.70	135.95	138.35	140.75	143.15	145.55	147.95	150.20	152.60	155.00	157.40	159.80	162.20
odp.vod likv.v septicích	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY 2018 Bystřany														
Množství odpadních vod	m3/den	133.70	135.95	138.35	140.75	143.15	145.55	147.95	150.20	152.60	155.00	157.40	159.80	162.20
BSK5	kg/d	53.43	54.33	55.29	56.25	57.21	58.17	59.13	60.03	60.99	61.95	62.91	63.87	64.83
NL	kg/d	48.98	49.80	50.68	51.56	52.44	53.32	54.20	55.03	55.91	56.79	57.67	58.55	59.43
CHSK	kg/d	97.96	99.61	101.37	103.13	104.89	106.65	108.41	110.06	111.82	113.58	115.34	117.10	118.86
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	0.00 0.00 0.00 0.00 0.00												
Množství vyčišt.odp.vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Produkce kalu	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0305.01 Zabrušany

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	52.45	52.15	51.85	51.55	51.25	50.95	50.80	50.50	50.20	49.90	49.60	49.30	49.15
BSK5	kg/d	20.94	20.82	20.70	20.58	20.46	20.34	20.28	20.16	20.04	19.92	19.80	19.68	19.62
NL	kg/d	19.20	19.09	18.98	18.87	18.76	18.65	18.59	18.48	18.37	18.26	18.15	18.04	17.99
CHSK	kg/d	38.39	38.17	37.95	37.73	37.51	37.29	37.18	36.96	36.74	36.52	36.30	36.08	35.97
Počet EO	os.	349	347	345	343	341	339	338	336	334	332	330	328	327
odp.vod likv.na ČOV	m3/den	41.70	41.55	41.25	41.10	40.80	40.50	40.50	40.20	39.90	39.75	39.45	39.30	39.00
odp.vod likv.v septicích	m3/den	10.75	10.60	10.60	10.45	10.45	10.45	10.30	10.30	10.30	10.15	10.15	10.00	10.15
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Želénky												
Množství odpadních vod	m3/den	41.70	41.55	41.25	41.10	40.80	40.50	40.50	40.20	39.90	39.75	39.45	39.30	39.00
BSK5	kg/d	16.68	16.62	16.50	16.44	16.32	16.20	16.20	16.08	15.96	15.90	15.78	15.72	15.60
NL	kg/d	15.29	15.24	15.13	15.07	14.96	14.85	14.85	14.74	14.63	14.58	14.47	14.41	14.30
CHSK	kg/d	30.58	30.47	30.25	30.14	29.92	29.70	29.70	29.48	29.26	29.15	28.93	28.82	28.60
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišť.odp.vod	m3/den	10.75	10.60	10.60	10.45	10.45	10.45	10.30	10.30	10.30	10.15	10.15	10.00	10.15
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	2.11	2.08	2.08	2.05	2.05	2.05	2.02	2.02	2.02	1.99	1.99	1.96	1.99
NL	kg/d	2.29	2.26	2.26	2.23	2.23	2.23	2.20	2.20	2.20	2.16	2.16	2.13	2.16
CHSK	kg/d	3.51	3.46	3.46	3.41	3.41	3.41	3.36	3.36	3.36	3.31	3.31	3.26	3.31
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	2.15	2.12	2.12	2.09	2.09	2.09	2.06	2.06	2.06	2.03	2.03	2.00	2.03
NL	kg/d	1.61	1.59	1.59	1.57	1.57	1.57	1.55	1.55	1.55	1.52	1.52	1.50	1.52
CHSK	kg/d	4.30	4.24	4.24	4.18	4.18	4.18	4.12	4.12	4.12	4.06	4.06	4.00	4.06
Produkce kalu	m3/r	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0305.02 Straky

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030										
CELKOVÁ PRODUKCE																								
odpadních vod	m3/den	16.24	16.12	15.97	15.92	15.71	15.66	15.50	15.30	15.25	15.04	14.99	14.84	14.74										
BSK5	kg/d	5.65	5.63	5.57	5.57	5.51	5.51	5.49	5.43	5.43	5.37	5.37	5.35	5.31										
NL	kg/d	5.17	5.16	5.10	5.10	5.05	5.05	5.03	4.97	4.97	4.92	4.92	4.90	4.86										
CHSK	kg/d	10.35	10.31	10.20	10.20	10.09	10.09	10.06	9.95	9.95	9.84	9.84	9.80	9.73										
Počet EO	os.	94	93	92	92	91	91	91	90	90	89	89	89	88										
odp.vod likv.na ČOV	m3/den	4.09	3.97	3.97	3.92	3.86	3.81	3.65	3.60	3.55	3.49	3.44	3.29	3.34										
odp.vod likv.v septicích	m3/den	12.15	12.15	12.00	12.00	11.85	11.85	11.85	11.70	11.70	11.55	11.55	11.55	11.40										
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bílina																						
Množství odpadních vod	m3/den	4.09	3.97	3.97	3.92	3.86	3.81	3.65	3.60	3.55	3.49	3.44	3.29	3.34										
BSK5	kg/d	0.79	0.77	0.77	0.77	0.77	0.77	0.75	0.75	0.75	0.75	0.75	0.73	0.75										
NL	kg/d	0.72	0.70	0.70	0.70	0.70	0.70	0.68	0.68	0.68	0.68	0.68	0.66	0.68										
CHSK	kg/d	1.44	1.40	1.40	1.40	1.40	1.40	1.37	1.37	1.37	1.37	1.37	1.33	1.37										
PŘÍTOK NA ČOV																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0										
Typ ČOV		žádná																						
KONCENTRACE NA ODTOKU		stávající a navrhované řešení																						
	-	<table><tr><td>BSK5</td><td>NL</td><td>CHSK</td><td>N-celk</td><td>P-celk</td></tr><tr><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td></tr></table>													BSK5	NL	CHSK	N-celk	P-celk	0.00	0.00	0.00	0.00	0.00
BSK5	NL	CHSK	N-celk	P-celk																				
0.00	0.00	0.00	0.00	0.00																				
	mg/l																							
Množství vyčišť.odp.vod	m3/den	12.15	12.15	12.00	12.00	11.85	11.85	11.85	11.70	11.70	11.55	11.55	11.55	11.40										
ODSTRANĚNÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	2.43	2.43	2.40	2.40	2.37	2.37	2.37	2.34	2.34	2.31	2.31	2.31	2.28										
NL	kg/d	2.63	2.63	2.60	2.60	2.57	2.57	2.57	2.54	2.54	2.50	2.50	2.50	2.47										
CHSK	kg/d	4.05	4.05	4.00	4.00	3.95	3.95	3.95	3.90	3.90	3.85	3.85	3.85	3.80										
ZBYTKOVÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	2.43	2.43	2.40	2.40	2.37	2.37	2.37	2.34	2.34	2.31	2.31	2.31	2.28										
NL	kg/d	1.82	1.82	1.80	1.80	1.78	1.78	1.78	1.76	1.76	1.73	1.73	1.73	1.71										
CHSK	kg/d	4.86	4.86	4.80	4.80	4.74	4.74	4.74	4.68	4.68	4.62	4.62	4.62	4.56										
Produkce kalu	m3/r	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02										
Způsob likv.kalu																								
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										

CZ042.3509.4213.0305.03 Štěrbina

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	1.98	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90	1.90
BSK5	kg/d	0.75	0.73	0.73	0.73	0.73	0.73	0.73	0.73	0.73	0.73	0.73	0.73	0.73
NL	kg/d	0.68	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66
CHSK	kg/d	1.37	1.33	1.33	1.33	1.33	1.33	1.33	1.33	1.33	1.33	1.33	1.33	1.33
Počet EO	os.	12	12	12	12	12	12	12	12	12	12	12	12	12
odp.vod likv.na ČOV	m3/den	0.78	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70
odp.vod likv.v septicích	m3/den	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Bilina												
Množství odpadních vod	m3/den	0.78	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70
BSK5	kg/d	0.27	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25
NL	kg/d	0.24	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22
CHSK	kg/d	0.49	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišt.odp.vod	m3/den	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24
NL	kg/d	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26
CHSK	kg/d	0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.40
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24
NL	kg/d	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18
CHSK	kg/d	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48
Produkce kalu	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0305.04 Všechny

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	46.90	46.60	46.45	46.15	46.00	45.70	45.55	45.40	45.10	44.95	44.65	44.50	44.35
BSK5	kg/d	18.12	18.00	17.94	17.82	17.76	17.64	17.58	17.52	17.40	17.34	17.22	17.16	17.10
NL	kg/d	16.61	16.50	16.45	16.34	16.28	16.17	16.12	16.06	15.95	15.90	15.79	15.73	15.68
CHSK	kg/d	33.22	33.00	32.89	32.67	32.56	32.34	32.23	32.12	31.90	31.79	31.57	31.46	31.35
Počet EO	os.	302	300	299	297	296	294	293	292	290	289	287	286	285
odp.vod likv.na ČOV	m3/den	42.25	42.10	41.95	41.65	41.50	41.20	41.05	40.90	40.75	40.60	40.30	40.15	40.00
odp.vod likv.v septicích	m3/den	4.65	4.50	4.50	4.50	4.50	4.50	4.50	4.50	4.35	4.35	4.35	4.35	4.35
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Želénky												
Množství odpadních vod	m3/den	42.25	42.10	41.95	41.65	41.50	41.20	41.05	40.90	40.75	40.60	40.30	40.15	40.00
BSK5	kg/d	16.32	16.26	16.20	16.08	16.02	15.90	15.84	15.78	15.72	15.66	15.54	15.48	15.42
NL	kg/d	14.96	14.91	14.85	14.74	14.69	14.58	14.52	14.47	14.41	14.36	14.25	14.19	14.14
CHSK	kg/d	29.92	29.81	29.70	29.48	29.37	29.15	29.04	28.93	28.82	28.71	28.49	28.38	28.27
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišť.odp.vod	m3/den	4.65	4.50	4.50	4.50	4.50	4.50	4.50	4.50	4.35	4.35	4.35	4.35	4.35
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.87	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.81	0.81	0.81	0.81	0.81
NL	kg/d	0.95	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.89	0.89	0.89	0.89	0.89
CHSK	kg/d	1.44	1.39	1.39	1.39	1.39	1.39	1.39	1.39	1.34	1.34	1.34	1.34	1.34
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.93	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.87	0.87	0.87	0.87	0.87
NL	kg/d	0.70	0.68	0.68	0.68	0.68	0.68	0.68	0.68	0.65	0.65	0.65	0.65	0.65
CHSK	kg/d	1.86	1.80	1.80	1.80	1.80	1.80	1.80	1.80	1.74	1.74	1.74	1.74	1.74
Produkce kalu	m3/r	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0305.05 Želénky

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	53.30	53.00	52.70	52.40	52.25	51.95	51.65	51.35	51.20	50.90	50.60	50.30	50.15
BSK5	kg/d	21.03	20.91	20.79	20.67	20.61	20.49	20.37	20.25	20.19	20.07	19.95	19.83	19.77
NL	kg/d	19.28	19.17	19.06	18.95	18.89	18.78	18.67	18.56	18.51	18.40	18.29	18.18	18.12
CHSK	kg/d	38.56	38.34	38.12	37.90	37.79	37.57	37.35	37.13	37.02	36.80	36.58	36.36	36.25
Počet EO	os.	350	348	346	344	343	341	339	337	336	334	332	330	329
odp.vod likv.na ČOV	m3/den	32.55	32.40	32.25	32.10	31.95	51.95	51.65	51.35	51.20	50.90	50.60	50.30	50.15
odp.vod likv.v septicích	m3/den	20.75	20.60	20.45	20.30	20.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT 2018 Duchcov, 2018 Háj u Duchcova, 2018 Domaslavice, 2018 Jeníkov, 2018 Oldřichov, 2018 Lahošt, 2018 Osek														
Množství odpadních vod	m3/den	2140.11	2133.66	2127.73	2121.36	2114.95	2108.68	2102.84	2096.17	2090.24	2083.68	2077.52	2070.84	2064.92
BSK5	kg/d	852.13	849.54	847.13	844.56	842.00	839.46	837.10	834.44	832.07	829.44	826.96	824.31	821.88
NL	kg/d	5.12	5.12	5.17	5.17	5.23	5.23	5.28	5.34	5.34	5.34	5.39	5.45	5.50
CHSK	kg/d	10.23	10.23	10.34	10.34	10.45	10.45	10.56	10.67	10.67	10.67	10.78	10.89	11.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	2172.66	2166.06	2159.98	2153.46	2146.90	2160.63	2154.49	2147.52	2141.44	2134.58	2128.12	2121.14	2115.07
BSK5	kg/d	864.97	862.33	859.85	857.22	854.60	859.95	857.47	854.70	852.26	849.51	846.91	844.14	841.66
NL	kg/d	16.89	16.83	16.83	16.78	16.78	23.98	23.93	23.87	23.82	23.71	23.65	23.60	23.60
CHSK	kg/d	33.77	33.66	33.66	33.55	33.55	47.96	47.85	47.74	47.63	47.41	47.30	47.19	47.19
Počet EO	os.	14416	14372	14330	14286	14243	14332	14291	14244	14204	14158	14115	14068	14027
Typ ČOV		ČOV se systémem R - D- N												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	2.30 1.95 15.39 6.30 1.42												
Množství vyčištěn. odp. vod	m3/den	2193.41	2186.66	2180.43	2173.76	2167.20	2160.63	2154.49	2147.52	2141.44	2134.58	2128.12	2121.14	2115.07
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	864.01	861.35	858.86	856.21	853.61	854.98	852.51	849.76	847.33	844.60	842.01	839.26	836.79
NL	kg/d	17.04	16.97	16.95	16.87	16.89	19.77	19.72	19.68	19.64	19.54	19.50	19.46	19.47
CHSK	kg/d	7.05	6.99	7.03	6.97	7.07	14.71	14.69	14.69	14.67	14.56	14.55	14.55	14.64
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	9.15	9.10	9.06	9.01	9.00	4.97	4.96	4.94	4.93	4.91	4.89	4.88	4.86
NL	kg/d	7.35	7.31	7.28	7.24	7.23	4.21	4.20	4.19	4.18	4.16	4.15	4.14	4.12
CHSK	kg/d	41.74	41.58	41.42	41.26	41.16	33.25	33.16	33.05	32.96	32.85	32.75	32.64	32.55
Produkce kalu	m3/r	63.47	63.27	63.09	62.89	62.70	63.06	62.88	62.67	62.50	62.30	62.11	61.90	61.72
Způsob likv. kalu		odvoz na jinou ČOV												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0306.01 Žalany

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030										
CELKOVÁ PRODUKCE																								
odpadních vod	m3/den	65.30	64.85	64.55	64.25	63.95	63.65	63.20	62.90	62.60	62.30	62.00	61.70	61.40										
BSK5	kg/d	25.74	25.56	25.44	25.32	25.20	25.08	24.90	24.78	24.66	24.54	24.42	24.30	24.18										
NL	kg/d	23.60	23.43	23.32	23.21	23.10	22.99	22.83	22.72	22.61	22.50	22.39	22.28	22.17										
CHSK	kg/d	47.19	46.86	46.64	46.42	46.20	45.98	45.65	45.43	45.21	44.99	44.77	44.55	44.33										
Počet EO	os.	429	426	424	422	420	418	415	413	411	409	407	405	403										
odp.vod likv.na ČOV	m3/den	28.80	28.65	28.50	28.35	28.20	28.05	27.90	27.75	27.60	27.45	27.30	27.15	27.00										
odp.vod likv.v septicích	m3/den	36.50	36.20	36.05	35.90	35.75	35.60	35.30	35.15	35.00	34.85	34.70	34.55	34.40										
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT 2018 Bořislav, 2018 Bílka																								
Množství odpadních vod	m3/den	35.40	35.25	35.10	34.95	34.80	34.50	34.35	34.05	33.90	33.75	33.60	33.45	33.00										
BSK5	kg/d	14.16	14.10	14.04	13.98	13.92	13.80	13.74	13.62	13.56	13.50	13.44	13.38	13.20										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
PŘÍTOK NA ČOV																								
Množství odpadních vod	m3/den	64.20	63.90	63.60	63.30	63.00	62.55	62.25	61.80	61.50	61.20	60.90	60.60	60.00										
BSK5	kg/d	25.68	25.56	25.44	25.32	25.20	25.02	24.90	24.72	24.60	24.48	24.36	24.24	24.00										
NL	kg/d	10.56	10.51	10.45	10.40	10.34	10.29	10.23	10.18	10.12	10.07	10.01	9.96	9.90										
CHSK	kg/d	21.12	21.01	20.90	20.79	20.68	20.57	20.46	20.35	20.24	20.13	20.02	19.91	19.80										
Počet EO	os.	428	426	424	422	420	417	415	412	410	408	406	404	400										
Typ ČOV		Akt. č. denitrif.+nitrif.																						
KONCENTRACE NA ODTOKU		stávající a navrhované řešení																						
	-	<table><tr><td>BSK5</td><td>NL</td><td>CHSK</td><td>N-celk</td><td>P-celk</td></tr><tr><td>4.31</td><td>4.27</td><td>24.86</td><td>0.00</td><td>0.00</td></tr></table>													BSK5	NL	CHSK	N-celk	P-celk	4.31	4.27	24.86	0.00	0.00
BSK5	NL	CHSK	N-celk	P-celk																				
4.31	4.27	24.86	0.00	0.00																				
	mg/l																							
Množství vyčišť.odp.vod	m3/den	100.70	100.10	99.65	99.20	98.75	98.15	97.55	96.95	96.50	96.05	95.60	95.15	94.40										
ODSTRANĚNÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	32.32	32.14	32.00	31.85	31.70	31.49	31.31	31.10	30.95	30.81	30.66	30.51	30.24										
NL	kg/d	17.85	17.73	17.64	17.55	17.47	17.38	17.26	17.18	17.09	17.01	16.92	16.83	16.75										
CHSK	kg/d	30.99	30.79	30.64	30.49	30.33	30.19	29.98	29.83	29.68	29.53	29.38	29.22	29.08										
ZBYTKOVÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	7.58	7.52	7.48	7.45	7.42	7.39	7.33	7.30	7.27	7.23	7.20	7.17	7.14										
NL	kg/d	5.75	5.70	5.68	5.66	5.63	5.61	5.56	5.54	5.51	5.49	5.47	5.44	5.42										
CHSK	kg/d	16.20	16.07	16.00	15.93	15.87	15.79	15.67	15.60	15.53	15.46	15.39	15.33	15.25										
Produkce kalu	m3/r	1.95	1.94	1.93	1.92	1.91	1.90	1.89	1.88	1.87	1.86	1.85	1.84	1.82										
Způsob likv.kalu		odvoz na jinou ČOV																						
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										

CZ042.3509.4213.0306.02 Černčice

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90
BSK5	kg/d	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36
NL	kg/d	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33
CHSK	kg/d	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66
Počet EO	os.	6	6	6	6	6	6	6	6	6	6	6	6	6
odp.vod likv.na ČOV	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.v septicích	m3/den	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišt.odp.vod	m3/den	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90	0.90
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18
NL	kg/d	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
CHSK	kg/d	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18
NL	kg/d	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14
CHSK	kg/d	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36
Produkce kalu	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0306.03 Lelov

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	8.65	8.50	8.50	8.35	8.35	8.35	8.20	8.20	8.20	8.05	8.05	8.05	8.05
BSK5	kg/d	3.45	3.39	3.39	3.33	3.33	3.33	3.27	3.27	3.27	3.21	3.21	3.21	3.21
NL	kg/d	3.16	3.11	3.11	3.05	3.05	3.05	3.00	3.00	3.00	2.94	2.94	2.94	2.94
CHSK	kg/d	6.33	6.22	6.22	6.11	6.11	6.11	6.00	6.00	6.00	5.89	5.89	5.89	5.89
Počet EO	os.	57	56	56	55	55	55	54	54	54	53	53	53	53
odp.vod likv.na ČOV	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.v septicích	m3/den	8.65	8.50	8.50	8.35	8.35	8.35	8.20	8.20	8.20	8.05	8.05	8.05	8.05
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišť.odp.vod	m3/den	8.65	8.50	8.50	8.35	8.35	8.35	8.20	8.20	8.20	8.05	8.05	8.05	8.05
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	1.72	1.69	1.69	1.66	1.66	1.66	1.63	1.63	1.63	1.60	1.60	1.60	1.60
NL	kg/d	1.87	1.83	1.83	1.80	1.80	1.80	1.77	1.77	1.77	1.74	1.74	1.74	1.74
CHSK	kg/d	2.87	2.82	2.82	2.77	2.77	2.77	2.72	2.72	2.72	2.67	2.67	2.67	2.67
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	1.73	1.70	1.70	1.67	1.67	1.67	1.64	1.64	1.64	1.61	1.61	1.61	1.61
NL	kg/d	1.30	1.28	1.28	1.25	1.25	1.25	1.23	1.23	1.23	1.21	1.21	1.21	1.21
CHSK	kg/d	3.46	3.40	3.40	3.34	3.34	3.34	3.28	3.28	3.28	3.22	3.22	3.22	3.22
Produkce kalu	m3/r	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0307.01 Žim

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	24.30	24.60	24.90	25.20	25.50	25.80	26.10	26.55	26.85	27.15	27.45	27.75	28.20
BSK5	kg/d	9.72	9.84	9.96	10.08	10.20	10.32	10.44	10.62	10.74	10.86	10.98	11.10	11.28
NL	kg/d	8.91	9.02	9.13	9.24	9.35	9.46	9.57	9.74	9.85	9.96	10.07	10.18	10.34
CHSK	kg/d	17.82	18.04	18.26	18.48	18.70	18.92	19.14	19.47	19.69	19.91	20.13	20.35	20.68
Počet EO	os.	162	164	166	168	170	172	174	177	179	181	183	185	188
odp.vod likv.na ČOV	m3/den	24.30	24.60	24.90	25.20	25.50	25.80	26.10	26.55	26.85	27.15	27.45	27.75	28.20
odp.vod likv.v septicích	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	24.30	24.60	24.90	25.20	25.50	25.80	26.10	26.55	26.85	27.15	27.45	27.75	28.20
BSK5	kg/d	9.72	9.84	9.96	10.08	10.20	10.32	10.44	10.62	10.74	10.86	10.98	11.10	11.28
NL	kg/d	8.91	9.02	9.13	9.24	9.35	9.46	9.57	9.74	9.85	9.96	10.07	10.18	10.34
CHSK	kg/d	17.82	18.04	18.26	18.48	18.70	18.92	19.14	19.47	19.69	19.91	20.13	20.35	20.68
Počet EO	os.	162	164	166	168	170	172	174	177	179	181	183	185	188
Typ ČOV		Aktivační čistírna												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	20.00 20.00 90.00 35.00 8.00												
Množství vyčištěn.odp.vod	m3/den	24.30	24.60	24.90	25.20	25.50	25.80	26.10	26.55	26.85	27.15	27.45	27.75	28.20
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	9.23	9.35	9.46	9.58	9.69	9.80	9.92	10.09	10.20	10.32	10.43	10.55	10.72
NL	kg/d	8.42	8.53	8.63	8.74	8.84	8.94	9.05	9.20	9.31	9.41	9.52	9.62	9.78
CHSK	kg/d	15.63	15.83	16.02	16.21	16.41	16.60	16.79	17.08	17.27	17.47	17.66	17.85	18.14
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.49	0.49	0.50	0.50	0.51	0.52	0.52	0.53	0.54	0.54	0.55	0.56	0.56
NL	kg/d	0.49	0.49	0.50	0.50	0.51	0.52	0.52	0.53	0.54	0.54	0.55	0.56	0.56
CHSK	kg/d	2.19	2.21	2.24	2.27	2.30	2.32	2.35	2.39	2.42	2.44	2.47	2.50	2.54
Produkce kalu	m3/r	0.71	0.72	0.73	0.74	0.75	0.76	0.77	0.78	0.79	0.80	0.81	0.81	0.83
Způsob likv.kalu		neurčeno												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3509.4213.0307.02 Záhoví

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	2.25	2.25	2.40	2.40	2.55	2.55	2.70	2.70	2.85	2.85	3.00	3.00	3.15
BSK5	kg/d	0.90	0.90	0.96	0.96	1.02	1.02	1.08	1.08	1.14	1.14	1.20	1.20	1.26
NL	kg/d	0.83	0.83	0.88	0.88	0.94	0.94	0.99	0.99	1.05	1.05	1.10	1.10	1.16
CHSK	kg/d	1.65	1.65	1.76	1.76	1.87	1.87	1.98	1.98	2.09	2.09	2.20	2.20	2.31
Počet EO	os.	15	15	16	16	17	17	18	18	19	19	20	20	21
odp.vod likv.na ČOV	m3/den	2.25	2.25	2.40	2.40	2.55	2.55	2.70	2.70	2.85	2.85	3.00	3.00	3.15
odp.vod likv.v septicích	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	2.25	2.25	2.40	2.40	2.55	2.55	2.70	2.70	2.85	2.85	3.00	3.00	3.15
BSK5	kg/d	0.90	0.90	0.96	0.96	1.02	1.02	1.08	1.08	1.14	1.14	1.20	1.20	1.26
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	15	15	16	16	17	17	18	18	19	19	20	20	21
Typ ČOV		Domovní mikročist.,biof.												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	30.0030.00110.0030.006.00												
Množství vyčišť.odp.vod	m3/den	2.25	2.25	2.40	2.40	2.55	2.55	2.70	2.70	2.85	2.85	3.00	3.00	3.15
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.83	0.83	0.89	0.89	0.94	0.94	1.00	1.00	1.05	1.05	1.11	1.11	1.17
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.07	0.07	0.07	0.07	0.08	0.08	0.08	0.08	0.09	0.09	0.09	0.09	0.09
NL	kg/d	0.07	0.07	0.07	0.07	0.08	0.08	0.08	0.08	0.09	0.09	0.09	0.09	0.09
CHSK	kg/d	0.25	0.25	0.26	0.26	0.28	0.28	0.30	0.30	0.31	0.31	0.33	0.33	0.35
Produkce kalu	m3/r	0.07	0.07	0.07	0.07	0.07	0.07	0.08	0.08	0.08	0.08	0.09	0.09	0.09
Způsob likv.kalu		neurčeno												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00