

CZ042.3502.4215.0331.01 Dolní Podluží

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	150.94	150.86	150.71	150.62	150.47	150.32	150.32	150.24	150.09	149.94	149.86	149.71	175.89
BSK5	kg/d	56.44	56.42	56.36	56.34	56.28	56.22	56.22	56.20	56.14	56.08	56.06	56.00	71.60
NL	kg/d	51.73	51.71	51.66	51.64	51.59	51.53	51.53	51.51	51.46	51.40	51.38	51.33	65.63
CHSK	kg/d	103.46	103.43	103.32	103.28	103.17	103.06	103.06	103.02	102.91	102.80	102.77	102.66	131.26
Počet EO	os.	940	940	939	938	937	936	936	936	935	934	934	933	1193
odp.vod likv.na ČOV	m3/den	63.94	64.01	64.01	63.92	63.92	63.77	63.77	63.84	63.69	63.69	63.61	63.61	175.89
odp.vod likv.v septicích	m3/den	87.00	86.85	86.70	86.70	86.55	86.55	86.55	86.40	86.40	86.25	86.25	86.10	0.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Varnsdorf, 2030 Varnsdorf												
Množství odpadních vod	m3/den	36.19	36.11	36.11	36.02	36.02	36.02	36.02	35.94	35.94	35.94	35.86	35.86	175.89
BSK5	kg/d	10.54	10.52	10.52	10.50	10.50	10.50	10.50	10.48	10.48	10.48	10.46	10.46	71.60
NL	kg/d	9.66	9.64	9.64	9.62	9.62	9.62	9.62	9.60	9.60	9.60	9.58	9.58	65.63
CHSK	kg/d	19.31	19.28	19.28	19.24	19.24	19.24	19.24	19.20	19.20	19.20	19.17	19.17	131.26
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	27.75	27.90	27.90	27.90	27.90	27.75	27.75	27.90	27.75	27.75	27.75	27.75	0.00
BSK5	kg/d	11.10	11.16	11.16	11.16	11.16	11.10	11.10	11.16	11.10	11.10	11.10	11.10	0.00
NL	kg/d	10.18	10.23	10.23	10.23	10.23	10.18	10.18	10.23	10.18	10.18	10.18	10.18	0.00
CHSK	kg/d	20.35	20.46	20.46	20.46	20.46	20.35	20.35	20.46	20.35	20.35	20.35	20.35	0.00
Počet EO	os.	185	186	186	186	186	185	185	186	185	185	185	185	0
Typ ČOV		ČOV se systémem R - D - N						žádná						
KONCENTRACE NA ODTOKU		stávající					navrhované řešení							
	-	BSK5	NL	CHSK	N-celk	P-celk	BSK5	NL	CHSK	N-celk	P-celk			
	mg/l	0.01	0.02	0.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
Množství vyčišť.odp.vod	m3/den	114.75	114.75	114.60	114.60	114.45	114.30	114.30	114.30	114.15	114.00	114.00	113.85	0.00
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	28.50	28.53	28.50	28.50	28.47	28.41	28.41	28.44	28.38	28.35	28.35	28.32	0.00
NL	kg/d	29.02	29.05	29.01	29.01	28.98	28.93	28.93	28.95	28.89	28.86	28.86	28.83	0.00
CHSK	kg/d	49.35	49.41	49.36	49.36	49.31	49.20	49.20	49.26	49.15	49.10	49.10	49.05	0.00
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	17.40	17.37	17.34	17.34	17.31	17.31	17.31	17.28	17.28	17.25	17.25	17.22	0.00
NL	kg/d	13.05	13.03	13.01	13.01	12.98	12.98	12.98	12.96	12.96	12.94	12.94	12.92	0.00
CHSK	kg/d	34.80	34.74	34.68	34.68	34.62	34.62	34.62	34.56	34.56	34.50	34.50	34.44	0.00
Produkce kalu	m3/r	0.96	0.97	0.97	0.97	0.97	0.96	0.96	0.97	0.96	0.96	0.96	0.96	0.00
Způsob likv.kalu		odvoz na jinou ČOV												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3502.4215.0331.02 Kateřina

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	9.44	9.34	9.34	9.19	9.19	9.11	9.11	9.09	8.94	8.94	8.86	8.86	9.00
BSK5	kg/d	3.38	3.35	3.35	3.29	3.29	3.27	3.27	3.25	3.19	3.19	3.17	3.17	3.25
NL	kg/d	3.10	3.07	3.07	3.01	3.01	2.99	2.99	2.98	2.92	2.92	2.91	2.91	2.98
CHSK	kg/d	6.20	6.13	6.13	6.02	6.02	5.99	5.99	5.96	5.85	5.85	5.81	5.81	5.96
Počet EO	os.	56	55	55	54	54	54	54	54	53	53	52	52	54
odp.vod likv.na ČOV	m3/den	6.44	6.49	6.49	6.34	6.34	6.26	6.26	6.24	6.09	6.09	6.16	6.16	9.00
odp.vod likv.v septicích	m3/den	3.00	2.85	2.85	2.85	2.85	2.85	2.85	2.85	2.85	2.85	2.70	2.70	0.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Varnsdorf, 2030 Varnsdorf												
Množství odpadních vod	m3/den	3.44	3.34	3.34	3.34	3.34	3.26	3.26	3.24	3.24	3.24	3.16	3.16	3.00
BSK5	kg/d	0.98	0.95	0.95	0.95	0.95	0.93	0.93	0.91	0.91	0.91	0.89	0.89	0.85
NL	kg/d	0.90	0.87	0.87	0.87	0.87	0.85	0.85	0.83	0.83	0.83	0.82	0.82	0.78
CHSK	kg/d	1.80	1.73	1.73	1.73	1.73	1.70	1.70	1.67	1.67	1.67	1.63	1.63	1.56
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	3.00	3.15	3.15	3.00	3.00	3.00	3.00	3.00	2.85	2.85	3.00	3.00	0.00
BSK5	kg/d	1.20	1.26	1.26	1.20	1.20	1.20	1.20	1.20	1.14	1.14	1.20	1.20	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	20	21	21	20	20	20	20	20	19	19	20	20	0
Typ ČOV		Domovní mikročist., biof.												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	30.0030.00110.0030.006.00												
Množství vyčišť.odp.vod	m3/den	6.00	6.00	6.00	5.85	5.85	5.85	5.85	5.85	5.70	5.70	5.70	5.70	0.00
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	1.71	1.74	1.74	1.68	1.68	1.68	1.68	1.68	1.62	1.62	1.65	1.65	0.00
NL	kg/d	0.56	0.52	0.52	0.53	0.53	0.53	0.53	0.53	0.53	0.53	0.50	0.50	0.00
CHSK	kg/d	0.67	0.60	0.60	0.62	0.62	0.62	0.62	0.62	0.64	0.64	0.57	0.57	0.00
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.69	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.63	0.63	0.00
NL	kg/d	0.54	0.52	0.52	0.52	0.52	0.52	0.52	0.52	0.51	0.51	0.50	0.50	0.00
CHSK	kg/d	1.53	1.49	1.49	1.47	1.47	1.47	1.47	1.47	1.45	1.45	1.41	1.41	0.00
Produkce kalu	m3/r	0.09	0.10	0.10	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.00
Způsob likv.kalu		neurčeno												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3502.4215.0332.01 Horní Podluží

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	128.05	130.65	133.40	136.10	138.85	141.45	144.30	147.05	149.65	152.50	155.10	157.85	160.70
BSK5	kg/d	49.50	50.52	51.60	52.65	53.73	54.75	55.86	56.94	57.96	59.07	60.09	61.17	62.28
NL	kg/d	45.38	46.31	47.30	48.26	49.25	50.19	51.21	52.20	53.13	54.15	55.08	56.07	57.09
CHSK	kg/d	90.75	92.62	94.60	96.53	98.51	100.38	102.41	104.39	106.26	108.30	110.17	112.15	114.18
Počet EO	os.	825	842	860	877	895	912	931	949	966	984	1001	1019	1038
odp.vod likv.na ČOV	m3/den	92.30	94.50	96.45	98.40	100.60	102.55	104.65	106.75	108.80	110.90	112.85	114.95	112.70
odp.vod likv.v septicích	m3/den	35.75	36.15	36.95	37.70	38.25	38.90	39.65	40.30	40.85	41.60	42.25	42.90	48.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT 2018 Žofín														
Množství odpadních vod	m3/den	2.10	2.10	2.10	2.10	2.10	2.10	1.95	1.95	1.95	1.95	1.95	1.95	1.95
BSK5	kg/d	0.84	0.84	0.84	0.84	0.84	0.84	0.78	0.78	0.78	0.78	0.78	0.78	0.78
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	94.40	96.60	98.55	100.50	102.70	104.65	106.60	108.70	110.75	112.85	114.80	116.90	114.65
BSK5	kg/d	37.56	38.43	39.21	39.99	40.86	41.64	42.42	43.26	44.07	44.91	45.69	46.53	45.66
NL	kg/d	33.66	34.43	35.15	35.86	36.69	37.40	38.17	38.94	39.66	40.43	41.14	41.91	41.14
CHSK	kg/d	67.32	68.86	70.29	71.72	73.37	74.80	76.34	77.88	79.31	80.85	82.28	83.82	82.28
Počet EO	os.	626	640	653	666	681	694	707	721	734	748	761	775	761
Typ ČOV		Akt. č. denitrif.+nitrif.												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	0.02 0.03 0.00 0.00 0.00												
Množství vyčištěn.odp.vod	m3/den	130.15	132.75	135.50	138.20	140.95	143.55	146.25	149.00	151.60	154.45	157.05	159.80	162.65
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	43.19	44.13	45.05	45.95	46.92	47.81	48.71	49.66	50.57	51.53	52.42	53.37	53.46
NL	kg/d	40.01	40.86	41.73	42.58	43.51	44.35	45.25	46.15	46.97	47.88	48.71	49.61	49.89
CHSK	kg/d	76.45	78.11	79.77	81.39	83.21	84.82	86.55	88.27	89.87	91.60	93.21	94.93	94.98
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	7.15	7.23	7.39	7.54	7.65	7.78	7.93	8.06	8.17	8.32	8.45	8.58	9.60
NL	kg/d	5.37	5.43	5.55	5.66	5.74	5.84	5.95	6.05	6.13	6.24	6.34	6.44	7.20
CHSK	kg/d	14.30	14.46	14.78	15.08	15.30	15.56	15.86	16.12	16.34	16.64	16.90	17.16	19.20
Produkce kalu	m3/r	2.83	2.89	2.95	3.01	3.07	3.13	3.19	3.25	3.31	3.38	3.43	3.50	3.45
Způsob likv.kalu		odvoz na jinou ČOV												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3502.4215.0332.02 Ladečka

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	1.68	1.60	1.60	1.60	1.60	1.60	1.60	1.60	1.60	1.60	1.60	1.60	1.60
BSK5	kg/d	0.42	0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.40
NL	kg/d	0.39	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37
CHSK	kg/d	0.77	0.73	0.73	0.73	0.73	0.73	0.73	0.73	0.73	0.73	0.73	0.73	0.73
Počet EO	os.	7	6	6	6	6	6	6	6	6	6	6	6	6
odp.vod likv.na ČOV	m3/den	1.68	1.60	1.60	1.60	1.60	1.60	1.60	1.60	1.60	1.60	1.60	1.60	1.60
odp.vod likv.v septicích	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY 2018 Varnsdorf														
Množství odpadních vod	m3/den	1.68	1.60	1.60	1.60	1.60	1.60	1.60	1.60	1.60	1.60	1.60	1.60	1.60
BSK5	kg/d	0.42	0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.40	0.40
NL	kg/d	0.39	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37	0.37
CHSK	kg/d	0.77	0.73	0.73	0.73	0.73	0.73	0.73	0.73	0.73	0.73	0.73	0.73	0.73
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	0.00 0.00 0.00 0.00 0.00												
Množství vyčišt.odp.vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Produkce kalu	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3502.4215.0332.04 Žofín

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	3.37	3.28	3.28	3.28	3.28	3.28	3.13	3.13	3.13	3.13	3.13	3.13	3.13
BSK5	kg/d	1.10	1.08	1.08	1.08	1.08	1.08	1.02	1.02	1.02	1.02	1.02	1.02	1.02
NL	kg/d	1.01	0.99	0.99	0.99	0.99	0.99	0.94	0.94	0.94	0.94	0.94	0.94	0.94
CHSK	kg/d	2.02	1.98	1.98	1.98	1.98	1.98	1.87	1.87	1.87	1.87	1.87	1.87	1.87
Počet EO	os.	18	18	18	18	18	18	17	17	17	17	17	17	17
odp.vod likv.na ČOV	m3/den	3.37	3.28	3.28	3.28	3.28	3.28	3.13	3.13	3.13	3.13	3.13	3.13	3.13
odp.vod likv.v septicích	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Varnsdorf, 2018 Horní Podluží												
Množství odpadních vod	m3/den	3.37	3.28	3.28	3.28	3.28	3.28	3.13	3.13	3.13	3.13	3.13	3.13	3.13
BSK5	kg/d	1.10	1.08	1.08	1.08	1.08	1.08	1.02	1.02	1.02	1.02	1.02	1.02	1.02
NL	kg/d	1.01	0.99	0.99	0.99	0.99	0.99	0.94	0.94	0.94	0.94	0.94	0.94	0.94
CHSK	kg/d	2.02	1.98	1.98	1.98	1.98	1.98	1.87	1.87	1.87	1.87	1.87	1.87	1.87
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5					NL	CHSK	N-celk	P-celk				
	mg/l	0.00					0.00	0.00	0.00	0.00				
Množství vyčišt.odp.vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Produkce kalu	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3502.4215.0333.01 Chřibská

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030										
CELKOVÁ PRODUKCE																								
odpadních vod	m3/den	221.70	220.07	218.46	216.85	215.37	213.76	212.15	210.52	209.06	207.45	205.82	204.21	202.75										
BSK5	kg/d	99.18	98.64	98.12	97.59	97.11	96.59	96.06	95.52	95.06	94.53	93.99	93.47	93.00										
NL	kg/d	90.92	90.42	89.94	89.46	89.02	88.54	88.06	87.56	87.13	86.65	86.16	85.68	85.25										
CHSK	kg/d	181.83	180.84	179.88	178.92	178.04	177.07	176.11	175.12	174.27	173.31	172.32	171.35	170.50										
Počet EO	os.	1653	1644	1635	1626	1618	1609	1601	1592	1584	1575	1566	1557	1550										
odp.vod likv.na ČOV	m3/den	160.35	159.47	158.46	157.45	156.57	155.56	154.55	153.52	152.66	151.65	150.62	149.76	202.75										
odp.vod likv.v septicích	m3/den	61.35	60.60	60.00	59.40	58.80	58.20	57.60	57.00	56.40	55.80	55.20	54.45	0.00										
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Varnsdorf, 2018 Dolní Chřibská																						
Množství odpadních vod	m3/den	121.95	121.52	120.96	120.25	119.82	119.11	118.55	117.97	117.41	116.85	116.12	115.71	177.55										
BSK5	kg/d	59.28	59.22	59.12	58.95	58.89	58.73	58.62	58.50	58.40	58.29	58.11	58.07	82.92										
NL	kg/d	54.34	54.29	54.19	54.04	53.98	53.83	53.74	53.63	53.53	53.43	53.27	53.23	76.01										
CHSK	kg/d	108.68	108.57	108.38	108.08	107.97	107.66	107.47	107.25	107.06	106.87	106.54	106.45	152.02										
PŘÍTOK NA ČOV																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0										
Typ ČOV		Domovní mikročist.,biof.																						
KONCENTRACE NA ODTOKU		stávající a navrhované řešení																						
	-	<table><tr><td>BSK5</td><td>NL</td><td>CHSK</td><td>N-celk</td><td>P-celk</td></tr><tr><td>30.00</td><td>30.00</td><td>110.00</td><td>30.00</td><td>6.00</td></tr></table>													BSK5	NL	CHSK	N-celk	P-celk	30.00	30.00	110.00	30.00	6.00
BSK5	NL	CHSK	N-celk	P-celk																				
30.00	30.00	110.00	30.00	6.00																				
	mg/l																							
Množství vyčišť.odp.vod	m3/den	61.35	60.60	60.00	59.40	58.80	58.20	57.60	57.00	56.40	55.80	55.20	54.45	0.00										
ODSTRANĚNÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	12.27	12.12	12.00	11.88	11.76	11.64	11.52	11.40	11.28	11.16	11.04	10.89	0.00										
NL	kg/d	13.29	13.13	13.00	12.87	12.74	12.61	12.48	12.35	12.22	12.09	11.96	11.80	0.00										
CHSK	kg/d	20.45	20.20	20.00	19.80	19.60	19.40	19.20	19.00	18.80	18.60	18.40	18.15	0.00										
ZBYTKOVÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	12.27	12.12	12.00	11.88	11.76	11.64	11.52	11.40	11.28	11.16	11.04	10.89	0.00										
NL	kg/d	9.20	9.09	9.00	8.91	8.82	8.73	8.64	8.55	8.46	8.37	8.28	8.17	0.00										
CHSK	kg/d	24.54	24.24	24.00	23.76	23.52	23.28	23.04	22.80	22.56	22.32	22.08	21.78	0.00										
Produkce kalu	m3/r	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.09	0.09	0.09	0.00										
Způsob likv.kalu		neurčeno																						
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										

CZ042.3502.4215.0333.02 Dolní Chříbská

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030										
CELKOVÁ PRODUKCE																								
odpadních vod	m3/den	45.45	45.15	44.85	44.70	44.40	44.25	43.95	43.65	43.50	43.20	43.05	42.75	42.60										
BSK5	kg/d	18.39	18.27	18.15	18.09	17.97	17.91	17.79	17.67	17.61	17.49	17.43	17.31	17.25										
NL	kg/d	16.86	16.75	16.64	16.58	16.47	16.42	16.31	16.20	16.14	16.03	15.98	15.87	15.81										
CHSK	kg/d	33.72	33.50	33.28	33.17	32.95	32.84	32.62	32.40	32.29	32.07	31.96	31.74	31.63										
Počet EO	os.	306	304	302	301	299	298	296	294	293	291	290	288	287										
odp.vod likv.na ČOV	m3/den	27.60	27.45	27.30	27.15	27.00	27.00	26.70	26.55	26.55	26.25	26.25	26.10	38.40										
odp.vod likv.v septicích	m3/den	17.85	17.70	17.55	17.55	17.40	17.25	17.25	17.10	16.95	16.95	16.80	16.65	4.20										
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT 2018 Chříbská																								
Množství odpadních vod	m3/den	91.95	91.20	90.30	89.25	88.50	87.45	86.55	85.65	84.75	83.85	82.80	82.05	143.55										
BSK5	kg/d	36.78	36.48	36.12	35.70	35.40	34.98	34.62	34.26	33.90	33.54	33.12	32.82	57.42										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY 2018 Dolní Kamenice																								
Množství odpadních vod	m3/den	0.60	0.60	0.60	0.60	0.60	0.60	0.60	0.60	0.60	0.60	0.60	0.60	0.60										
BSK5	kg/d	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45										
NL	kg/d	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41										
CHSK	kg/d	0.83	0.83	0.83	0.83	0.83	0.83	0.83	0.83	0.83	0.83	0.83	0.83	0.83										
PŘÍTOK NA ČOV																								
Množství odpadních vod	m3/den	118.95	118.05	117.00	115.80	114.90	113.85	112.65	111.60	110.70	109.50	108.45	107.55	181.35										
BSK5	kg/d	47.58	47.22	46.80	46.32	45.96	45.54	45.06	44.64	44.28	43.80	43.38	43.02	72.54										
NL	kg/d	9.90	9.85	9.79	9.74	9.68	9.68	9.57	9.52	9.52	9.41	9.41	9.35	13.86										
CHSK	kg/d	19.80	19.69	19.58	19.47	19.36	19.36	19.14	19.03	19.03	18.81	18.81	18.70	27.72										
Počet EO	os.	793	787	780	772	766	759	751	744	738	730	723	717	1209										
Typ ČOV		Čist. s biolog. filtry																						
KONCENTRACE NA ODTOKU		stávající a navrhované řešení																						
	-	<table><tr><td>BSK5</td><td>NL</td><td>CHSK</td><td>N-celk</td><td>P-celk</td></tr><tr><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td><td>0.00</td></tr></table>													BSK5	NL	CHSK	N-celk	P-celk	0.00	0.00	0.00	0.00	0.00
BSK5	NL	CHSK	N-celk	P-celk																				
0.00	0.00	0.00	0.00	0.00																				
	mg/l																							
Množství vyčišť.odp.vod	m3/den	136.80	135.75	134.55	133.35	132.30	131.10	129.90	128.70	127.65	126.45	125.25	124.20	185.55										
ODSTRANĚNÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	51.15	50.76	50.31	49.83	49.44	48.99	48.51	48.06	47.67	47.19	46.74	46.35	73.38										
NL	kg/d	13.77	13.68	13.59	13.54	13.45	13.42	13.31	13.22	13.19	13.08	13.05	12.96	14.77										
CHSK	kg/d	25.75	25.59	25.43	25.32	25.16	25.11	24.89	24.73	24.68	24.46	24.41	24.25	29.12										
ZBYTKOVÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	3.57	3.54	3.51	3.51	3.48	3.45	3.45	3.42	3.39	3.39	3.36	3.33	0.84										
NL	kg/d	2.68	2.66	2.63	2.63	2.61	2.59	2.59	2.57	2.54	2.54	2.52	2.50	0.63										
CHSK	kg/d	7.14	7.08	7.02	7.02	6.96	6.90	6.90	6.84	6.78	6.78	6.72	6.66	1.68										
Produkce kalu	m3/r	3.52	3.49	3.46	3.43	3.40	3.37	3.33	3.30	3.28	3.24	3.21	3.18	5.33										
Způsob likv.kalu		neurčeno																						
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	38.13	37.87	37.72	37.53	37.18	36.99	36.80	36.46	36.31	36.12	35.78	35.59	35.35
BSK5	kg/d	14.56	14.48	14.42	14.36	14.24	14.18	14.12	14.00	13.98	13.92	13.80	13.74	13.64
NL	kg/d	13.35	13.27	13.22	13.16	13.05	13.00	12.94	12.83	12.82	12.76	12.65	12.60	12.50
CHSK	kg/d	26.69	26.55	26.44	26.33	26.11	26.00	25.89	25.67	25.63	25.52	25.30	25.19	25.01
Počet EO	os.	242	241	240	239	237	236	235	233	233	232	230	229	227
odp.vod likv.na ČOV	m3/den	8.88	8.92	8.92	8.73	8.68	8.64	8.45	8.41	8.41	8.22	8.18	8.14	7.90
odp.vod likv.v septicích	m3/den	29.25	28.95	28.80	28.80	28.50	28.35	28.35	28.05	27.90	27.90	27.60	27.45	27.45
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY 2018 Dolní Kamenice														
Množství odpadních vod	m3/den	3.03	2.92	2.92	2.88	2.83	2.79	2.75	2.71	2.56	2.52	2.48	2.44	2.50
BSK5	kg/d	0.52	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.48	0.48	0.48	0.48	0.50
NL	kg/d	0.48	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.44	0.44	0.44	0.44	0.46
CHSK	kg/d	0.95	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.88	0.88	0.88	0.88	0.92
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	5.85	6.00	6.00	5.85	5.85	5.85	5.70	5.70	5.85	5.70	5.70	5.70	5.40
BSK5	kg/d	2.34	2.40	2.40	2.34	2.34	2.34	2.28	2.28	2.34	2.28	2.28	2.28	2.16
NL	kg/d	2.15	2.20	2.20	2.15	2.15	2.15	2.09	2.09	2.15	2.09	2.09	2.09	1.98
CHSK	kg/d	4.29	4.40	4.40	4.29	4.29	4.29	4.18	4.18	4.29	4.18	4.18	4.18	3.96
Počet EO	os.	39	40	40	39	39	39	38	38	39	38	38	38	36
Typ ČOV		Domovní mikročist., biof.												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	30.00 30.00 110.00 30.00 6.00												
Množství vyčišť.odp.vod	m3/den	35.10	34.95	34.80	34.65	34.35	34.20	34.05	33.75	33.75	33.60	33.30	33.15	32.85
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	8.01	8.01	7.98	7.92	7.86	7.83	7.78	7.72	7.74	7.69	7.63	7.60	7.49
NL	kg/d	8.31	8.29	8.26	8.21	8.14	8.11	8.06	8.00	8.01	7.96	7.90	7.87	7.77
CHSK	kg/d	13.40	13.39	13.34	13.25	13.15	13.10	13.00	12.90	12.95	12.85	12.75	12.70	12.52
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	6.03	5.97	5.94	5.94	5.88	5.85	5.84	5.78	5.76	5.75	5.69	5.66	5.65
NL	kg/d	4.56	4.52	4.50	4.50	4.45	4.43	4.42	4.38	4.36	4.36	4.31	4.29	4.28
CHSK	kg/d	12.34	12.24	12.18	12.16	12.04	11.98	11.97	11.85	11.80	11.79	11.67	11.61	11.57
Produkce kalu	m3/r	0.22	0.23	0.22	0.22	0.22	0.22	0.22	0.21	0.22	0.21	0.21	0.21	0.21
Způsob likv.kalu		neurčeno												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3502.4215.0333.04 Krásné Pole

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	17.98	17.90	17.75	17.75	17.60	17.45	17.45	17.37	17.22	17.22	17.07	16.92	16.92
BSK5	kg/d	6.78	6.76	6.70	6.70	6.64	6.58	6.58	6.56	6.50	6.50	6.44	6.38	6.38
NL	kg/d	6.22	6.20	6.14	6.14	6.09	6.03	6.03	6.01	5.96	5.96	5.90	5.85	5.85
CHSK	kg/d	12.43	12.39	12.28	12.28	12.17	12.06	12.06	12.03	11.92	11.92	11.81	11.70	11.70
Počet EO	os.	113	112	111	111	110	109	109	109	108	108	107	106	106
odp.vod likv.na ČOV	m3/den	4.63	4.70	4.70	4.70	4.55	4.55	4.55	4.62	4.47	4.47	4.47	4.47	4.32
odp.vod likv.v septicích	m3/den	13.35	13.20	13.05	13.05	13.05	12.90	12.90	12.75	12.75	12.75	12.60	12.45	12.60
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Dolní Kamenice, 2030 Varnsdorf												
Množství odpadních vod	m3/den	2.68	2.60	2.60	2.60	2.60	2.60	2.60	2.52	2.52	2.52	2.52	2.52	2.52
BSK5	kg/d	0.66	0.64	0.64	0.64	0.64	0.64	0.64	0.62	0.62	0.62	0.62	0.62	0.62
NL	kg/d	0.61	0.59	0.59	0.59	0.59	0.59	0.59	0.57	0.57	0.57	0.57	0.57	0.57
CHSK	kg/d	1.21	1.17	1.17	1.17	1.17	1.17	1.17	1.14	1.14	1.14	1.14	1.14	1.14
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	1.95	2.10	2.10	2.10	1.95	1.95	1.95	2.10	1.95	1.95	1.95	1.95	1.80
BSK5	kg/d	0.78	0.84	0.84	0.84	0.78	0.78	0.78	0.84	0.78	0.78	0.78	0.78	0.72
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	13	14	14	14	13	13	13	14	13	13	13	13	12
Typ ČOV		Domovní mikročist.,biof.												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	30.0030.00110.0030.006.00												
Množství vyčišť.odp.vod	m3/den	15.30	15.30	15.15	15.15	15.00	14.85	14.85	14.85	14.70	14.70	14.55	14.40	14.40
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	3.39	3.42	3.39	3.39	3.33	3.30	3.30	3.33	3.27	3.27	3.24	3.21	3.19
NL	kg/d	2.83	2.80	2.76	2.76	2.77	2.74	2.74	2.70	2.70	2.70	2.67	2.64	2.68
CHSK	kg/d	4.24	4.17	4.12	4.12	4.14	4.09	4.09	4.02	4.04	4.04	3.99	3.94	4.00
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	2.73	2.70	2.67	2.67	2.67	2.64	2.64	2.61	2.61	2.61	2.58	2.55	2.57
NL	kg/d	2.06	2.04	2.02	2.02	2.02	1.99	1.99	1.98	1.97	1.97	1.95	1.93	1.94
CHSK	kg/d	5.55	5.51	5.45	5.45	5.43	5.37	5.37	5.33	5.31	5.31	5.25	5.19	5.24
Produkce kalu	m3/r	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.07
Způsob likv.kalu		neurčeno												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3502.4215.0334.01 Jiřetín pod Jedlovou

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	117.80	117.72	117.72	117.57	117.57	117.42	117.42	117.42	117.27	117.27	117.12	117.12	116.25
BSK5	kg/d	44.66	44.64	44.64	44.58	44.58	44.52	44.52	44.52	44.46	44.46	44.40	44.40	44.21
NL	kg/d	40.94	40.92	40.92	40.87	40.87	40.81	40.81	40.81	40.76	40.76	40.70	40.70	40.53
CHSK	kg/d	81.88	81.84	81.84	81.73	81.73	81.62	81.62	81.62	81.51	81.51	81.40	81.40	81.05
Počet EO	os.	744	744	744	743	743	742	742	742	741	741	740	740	736
odp.vod likv.na ČOV	m3/den	114.95	115.02	115.02	114.87	114.87	114.72	114.72	114.72	114.57	114.57	114.42	114.42	113.40
odp.vod likv.v septicích	m3/den	2.85	2.70	2.70	2.70	2.70	2.70	2.70	2.70	2.70	2.70	2.70	2.70	2.85
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY 2018 Varnsdorf														
Množství odpadních vod	m3/den	1.60	1.52	1.52	1.52	1.52	1.52	1.52	1.52	1.52	1.52	1.52	1.52	1.80
BSK5	kg/d	0.44	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.59
NL	kg/d	0.40	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.54
CHSK	kg/d	0.81	0.77	0.77	0.77	0.77	0.77	0.77	0.77	0.77	0.77	0.77	0.77	1.08
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	113.35	113.50	113.50	113.35	113.35	113.20	113.20	113.20	113.05	113.05	112.90	112.90	111.60
BSK5	kg/d	43.08	43.14	43.14	43.08	43.08	43.02	43.02	43.02	42.96	42.96	42.90	42.90	42.48
NL	kg/d	39.49	39.55	39.55	39.49	39.49	39.44	39.44	39.44	39.38	39.38	39.33	39.33	38.94
CHSK	kg/d	78.98	79.09	79.09	78.98	78.98	78.87	78.87	78.87	78.76	78.76	78.65	78.65	77.88
Počet EO	os.	718	719	719	718	718	717	717	717	716	716	715	715	708
Typ ČOV		Aktivační čistírna												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	20.00 20.00 90.00 35.00 8.00												
Množství vyčištěn. odp.vod	m3/den	116.20	116.20	116.20	116.05	116.05	115.90	115.90	115.90	115.75	115.75	115.60	115.60	114.45
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	41.38	41.41	41.41	41.35	41.35	41.30	41.30	41.30	41.24	41.24	41.18	41.18	40.82
NL	kg/d	37.84	37.86	37.86	37.81	37.81	37.76	37.76	37.76	37.70	37.70	37.65	37.65	37.33
CHSK	kg/d	69.73	69.78	69.78	69.68	69.68	69.58	69.58	69.58	69.49	69.49	69.39	69.39	68.79
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	2.84	2.81	2.81	2.81	2.81	2.80	2.80	2.80	2.80	2.80	2.80	2.80	2.80
NL	kg/d	2.69	2.68	2.68	2.67	2.67	2.67	2.67	2.67	2.67	2.67	2.66	2.66	2.66
CHSK	kg/d	11.34	11.30	11.30	11.28	11.28	11.27	11.27	11.27	11.25	11.25	11.24	11.24	11.18
Produkce kalu	m3/r	3.16	3.17	3.17	3.16	3.16	3.16	3.16	3.16	3.15	3.15	3.15	3.15	3.12
Způsob likv.kalu		odvoz na jinou ČOV												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3502.4215.0334.02 Jedlová

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030										
CELKOVÁ PRODUKCE																								
odpadních vod	m3/den	5.38	5.38	5.38	5.48	5.48	5.50	5.50	5.50	5.52	5.52	5.62	5.62	5.56										
BSK5	kg/d	2.44	2.44	2.44	2.47	2.47	2.48	2.48	2.48	2.50	2.50	2.53	2.53	2.53										
NL	kg/d	2.23	2.23	2.23	2.26	2.26	2.27	2.27	2.27	2.29	2.29	2.31	2.31	2.31										
CHSK	kg/d	4.46	4.46	4.46	4.52	4.52	4.55	4.55	4.55	4.57	4.57	4.63	4.63	4.63										
Počet EO	os.	40	40	40	41	41	41	41	41	41	41	42	42	42										
odp.vod likv.na ČOV	m3/den	5.38	5.38	5.38	5.48	5.48	5.50	5.50	5.50	5.52	5.52	5.62	5.62	5.56										
odp.vod likv.v septicích	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Varnsdorf																						
Množství odpadních vod	m3/den	2.18	2.18	2.18	2.18	2.18	2.20	2.20	2.20	2.22	2.22	2.22	2.22	2.26										
BSK5	kg/d	1.48	1.48	1.48	1.48	1.48	1.49	1.49	1.49	1.51	1.51	1.51	1.51	1.54										
NL	kg/d	1.35	1.35	1.35	1.35	1.35	1.37	1.37	1.37	1.38	1.38	1.38	1.38	1.41										
CHSK	kg/d	2.70	2.70	2.70	2.70	2.70	2.73	2.73	2.73	2.76	2.76	2.76	2.76	2.81										
PŘÍTOK NA ČOV																								
Množství odpadních vod	m3/den	3.20	3.20	3.20	3.30	3.30	3.30	3.30	3.30	3.30	3.30	3.40	3.40	3.30										
BSK5	kg/d	0.96	0.96	0.96	0.99	0.99	0.99	0.99	0.99	0.99	0.99	1.02	1.02	0.99										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
Počet EO	os.	16	16	16	16	16	16	16	16	16	16	17	17	16										
Typ ČOV		Aktiv. čistírna s nitrif.																						
KONCENTRACE NA ODTOKU		stávající a navrhované řešení																						
	-																							
	mg/l	<table><tr><td>BSK5</td><td>NL</td><td>CHSK</td><td>N-celk</td><td>P-celk</td></tr><tr><td>15.00</td><td>20.00</td><td>80.00</td><td>30.00</td><td>8.00</td></tr></table>													BSK5	NL	CHSK	N-celk	P-celk	15.00	20.00	80.00	30.00	8.00
BSK5	NL	CHSK	N-celk	P-celk																				
15.00	20.00	80.00	30.00	8.00																				
Množství vyčišt.odp.vod	m3/den	3.20	3.20	3.20	3.30	3.30	3.30	3.30	3.30	3.30	3.30	3.40	3.40	3.30										
ODSTRANĚNÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	0.91	0.91	0.91	0.94	0.94	0.94	0.94	0.94	0.94	0.94	0.97	0.97	0.94										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
ZBYTKOVÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05										
NL	kg/d	0.06	0.06	0.06	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07										
CHSK	kg/d	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.27	0.27	0.26										
Produkce kalu	m3/r	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07										
Způsob likv.kalu		neurčeno																						
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										

CZ042.3502.4215.0334.03 Lesné

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	15.04	15.04	15.04	15.04	15.04	15.04	15.04	15.04	15.04	15.04	15.04	15.04	15.04
BSK5	kg/d	5.11	5.11	5.11	5.11	5.11	5.11	5.11	5.11	5.11	5.11	5.11	5.11	5.11
NL	kg/d	4.68	4.68	4.68	4.68	4.68	4.68	4.68	4.68	4.68	4.68	4.68	4.68	4.68
CHSK	kg/d	9.37	9.37	9.37	9.37	9.37	9.37	9.37	9.37	9.37	9.37	9.37	9.37	9.37
Počet EO	os.	85	85	85	85	85	85	85	85	85	85	85	85	85
odp.vod likv.na ČOV	m3/den	15.04	15.04	15.04	15.04	15.04	15.04	15.04	15.04	15.04	15.04	15.04	15.04	15.04
odp.vod likv.v septicích	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Varnsdorf												
Množství odpadních vod	m3/den	2.04	2.04	2.04	2.04	2.04	2.04	2.04	2.04	2.04	2.04	2.04	2.04	2.04
BSK5	kg/d	1.21	1.21	1.21	1.21	1.21	1.21	1.21	1.21	1.21	1.21	1.21	1.21	1.21
NL	kg/d	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11
CHSK	kg/d	2.22	2.22	2.22	2.22	2.22	2.22	2.22	2.22	2.22	2.22	2.22	2.22	2.22
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	13.00	13.00	13.00	13.00	13.00	13.00	13.00	13.00	13.00	13.00	13.00	13.00	13.00
BSK5	kg/d	3.90	3.90	3.90	3.90	3.90	3.90	3.90	3.90	3.90	3.90	3.90	3.90	3.90
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	65	65	65	65	65	65	65	65	65	65	65	65	65
Typ ČOV		Domovní mikročist.,biof.												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	30.0030.00110.0030.006.00												
Množství vyčišt.odp.vod	m3/den	13.00	13.00	13.00	13.00	13.00	13.00	13.00	13.00	13.00	13.00	13.00	13.00	13.00
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	3.51	3.51	3.51	3.51	3.51	3.51	3.51	3.51	3.51	3.51	3.51	3.51	3.51
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39
NL	kg/d	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39
CHSK	kg/d	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43	1.43
Produkce kalu	m3/r	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.29
Způsob likv.kalu		neurčeno												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3502.4215.0334.04 Rozhled

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	7.15	7.15	7.15	7.15	7.15	7.15	7.15	7.15	7.15	7.15	7.15	7.15	7.15
BSK5	kg/d	4.49	4.49	4.49	4.49	4.49	4.49	4.49	4.49	4.49	4.49	4.49	4.49	4.49
NL	kg/d	4.12	4.12	4.12	4.12	4.12	4.12	4.12	4.12	4.12	4.12	4.12	4.12	4.12
CHSK	kg/d	8.23	8.23	8.23	8.23	8.23	8.23	8.23	8.23	8.23	8.23	8.23	8.23	8.23
Počet EO	os.	74	74	74	74	74	74	74	74	74	74	74	74	74
odp.vod likv.na ČOV	m3/den	7.15	7.15	7.15	7.15	7.15	7.15	7.15	7.15	7.15	7.15	7.15	7.15	7.15
odp.vod likv.v septicích	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Varnsdorf												
Množství odpadních vod	m3/den	5.80	5.80	5.80	5.80	5.80	5.80	5.80	5.80	5.80	5.80	5.80	5.80	5.80
BSK5	kg/d	3.95	3.95	3.95	3.95	3.95	3.95	3.95	3.95	3.95	3.95	3.95	3.95	3.95
NL	kg/d	3.62	3.62	3.62	3.62	3.62	3.62	3.62	3.62	3.62	3.62	3.62	3.62	3.62
CHSK	kg/d	7.24	7.24	7.24	7.24	7.24	7.24	7.24	7.24	7.24	7.24	7.24	7.24	7.24
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	1.35	1.35	1.35	1.35	1.35	1.35	1.35	1.35	1.35	1.35	1.35	1.35	1.35
BSK5	kg/d	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	9	9	9	9	9	9	9	9	9	9	9	9	9
Typ ČOV		Domovní mikročist., biof.												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5					NL	CHSK	N-celk	P-celk				
	mg/l	30.00					30.00	110.00	30.00	6.00				
Množství vyčišť.odp.vod	m3/den	1.35	1.35	1.35	1.35	1.35	1.35	1.35	1.35	1.35	1.35	1.35	1.35	1.35
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04
NL	kg/d	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04
CHSK	kg/d	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
Produkce kalu	m3/r	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04
Způsob likv.kalu		neurčeno												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3502.4215.0335.01 Rybníště

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	50.30	49.98	49.74	49.50	49.26	48.95	48.71	48.47	48.23	47.99	47.68	47.44	47.06
BSK5	kg/d	13.52	13.44	13.38	13.32	13.26	13.16	13.10	13.04	12.98	12.92	12.82	12.76	12.62
NL	kg/d	12.39	12.32	12.27	12.21	12.16	12.06	12.01	11.95	11.90	11.84	11.75	11.70	11.57
CHSK	kg/d	24.79	24.64	24.53	24.42	24.31	24.13	24.02	23.91	23.80	23.69	23.50	23.39	23.14
Počet EO	os.	225	224	223	222	221	219	218	217	216	215	213	212	210
odp.vod likv.na ČOV	m3/den	50.30	49.98	49.74	49.50	49.26	48.95	48.71	48.47	48.23	47.99	47.68	47.44	47.06
odp.vod likv.v septicích	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY 2018 Varnsdorf														
Množství odpadních vod	m3/den	44.00	43.68	43.44	43.20	42.96	42.80	42.56	42.32	42.08	41.84	41.68	41.44	41.36
BSK5	kg/d	11.00	10.92	10.86	10.80	10.74	10.70	10.64	10.58	10.52	10.46	10.42	10.36	10.34
NL	kg/d	10.08	10.01	9.96	9.90	9.85	9.81	9.75	9.70	9.64	9.59	9.55	9.50	9.48
CHSK	kg/d	20.17	20.02	19.91	19.80	19.69	19.62	19.51	19.40	19.29	19.18	19.10	18.99	18.96
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	6.30	6.30	6.30	6.30	6.30	6.15	6.15	6.15	6.15	6.15	6.00	6.00	5.70
BSK5	kg/d	2.52	2.52	2.52	2.52	2.52	2.46	2.46	2.46	2.46	2.46	2.40	2.40	2.28
NL	kg/d	2.31	2.31	2.31	2.31	2.31	2.26	2.26	2.26	2.26	2.26	2.20	2.20	2.09
CHSK	kg/d	4.62	4.62	4.62	4.62	4.62	4.51	4.51	4.51	4.51	4.51	4.40	4.40	4.18
Počet EO	os.	42	42	42	42	42	41	41	41	41	41	40	40	38
Typ ČOV		Domovní mikročist.												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5 NL CHSK N-celk P-celk												
	mg/l	45.00 20.00 0.00 0.00 0.00												
Množství vyčištěn.odp.vod	m3/den	6.30	6.30	6.30	6.30	6.30	6.15	6.15	6.15	6.15	6.15	6.00	6.00	5.70
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	2.24	2.24	2.24	2.24	2.24	2.18	2.18	2.18	2.18	2.18	2.13	2.13	2.02
NL	kg/d	2.18	2.18	2.18	2.18	2.18	2.13	2.13	2.13	2.13	2.13	2.08	2.08	1.98
CHSK	kg/d	4.62	4.62	4.62	4.62	4.62	4.51	4.51	4.51	4.51	4.51	4.40	4.40	4.18
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.27	0.27	0.26
NL	kg/d	0.13	0.13	0.13	0.13	0.13	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.11
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Produkce kalu	m3/r	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.17
Způsob likv.kalu		odvoz na jinou ČOV												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3502.4215.0335.02 Nová Chříbská

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030										
CELKOVÁ PRODUKCE																								
odpadních vod	m3/den	11.33	11.25	11.25	11.10	11.10	11.02	11.02	10.87	10.87	10.79	10.79	10.64	10.64										
BSK5	kg/d	3.92	3.90	3.90	3.84	3.84	3.82	3.82	3.76	3.76	3.74	3.74	3.68	3.68										
NL	kg/d	3.59	3.58	3.58	3.52	3.52	3.50	3.50	3.45	3.45	3.43	3.43	3.37	3.37										
CHSK	kg/d	7.19	7.15	7.15	7.04	7.04	7.00	7.00	6.89	6.89	6.86	6.86	6.75	6.75										
Počet EO	os.	65	65	65	64	64	63	63	62	62	62	62	61	61										
odp.vod likv.na ČOV	m3/den	11.33	11.25	11.25	11.10	11.10	11.02	11.02	10.87	10.87	10.79	10.79	10.64	10.64										
odp.vod likv.v septicích	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT																								
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Varnsdorf																						
Množství odpadních vod	m3/den	3.98	3.90	3.90	3.90	3.90	3.82	3.82	3.82	3.82	3.74	3.74	3.74	3.74										
BSK5	kg/d	0.98	0.96	0.96	0.96	0.96	0.94	0.94	0.94	0.94	0.92	0.92	0.92	0.92										
NL	kg/d	0.90	0.88	0.88	0.88	0.88	0.86	0.86	0.86	0.86	0.84	0.84	0.84	0.84										
CHSK	kg/d	1.80	1.76	1.76	1.76	1.76	1.72	1.72	1.72	1.72	1.69	1.69	1.69	1.69										
PŘÍTOK NA ČOV																								
Množství odpadních vod	m3/den	7.35	7.35	7.35	7.20	7.20	7.20	7.20	7.05	7.05	7.05	7.05	6.90	6.90										
BSK5	kg/d	2.94	2.94	2.94	2.88	2.88	2.88	2.88	2.82	2.82	2.82	2.82	2.76	2.76										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
Počet EO	os.	49	49	49	48	48	48	48	47	47	47	47	46	46										
Typ ČOV		Domovní mikročist., biof.																						
KONCENTRACE NA ODTOKU		stávající a navrhované řešení																						
	-																							
	mg/l	<table><tr><td>BSK5</td><td>NL</td><td>CHSK</td><td>N-celk</td><td>P-celk</td></tr><tr><td>30.00</td><td>30.00</td><td>110.00</td><td>30.00</td><td>6.00</td></tr></table>													BSK5	NL	CHSK	N-celk	P-celk	30.00	30.00	110.00	30.00	6.00
BSK5	NL	CHSK	N-celk	P-celk																				
30.00	30.00	110.00	30.00	6.00																				
Množství vyčišť.odp.vod	m3/den	7.35	7.35	7.35	7.20	7.20	7.20	7.20	7.05	7.05	7.05	7.05	6.90	6.90										
ODSTRANĚNÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	2.72	2.72	2.72	2.66	2.66	2.66	2.66	2.61	2.61	2.61	2.61	2.55	2.55										
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										
ZBYTKOVÉ ZNEČIŠTĚNÍ																								
BSK5	kg/d	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.21	0.21	0.21	0.21	0.21	0.21										
NL	kg/d	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.21	0.21	0.21	0.21	0.21	0.21										
CHSK	kg/d	0.81	0.81	0.81	0.79	0.79	0.79	0.79	0.78	0.78	0.78	0.78	0.76	0.76										
Produkce kalu	m3/r	0.22	0.22	0.22	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.20	0.20										
Způsob likv.kalu		neurčeno																						
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00										

CZ042.3502.4215.0336.01 Varnsdorf

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	2258.22	2246.59	2235.04	2223.34	2211.79	2200.09	2188.54	2177.06	2165.36	2153.81	2142.11	2130.56	2119.01
BSK5	kg/d	900.73	896.09	891.47	886.79	882.17	877.49	872.87	868.29	863.61	858.99	854.31	849.69	845.07
NL	kg/d	825.67	821.42	817.18	812.89	808.66	804.37	800.13	795.93	791.64	787.41	783.12	778.88	774.65
CHSK	kg/d	1651.34	1642.83	1634.36	1625.78	1617.31	1608.73	1600.26	1591.87	1583.29	1574.82	1566.24	1557.77	1549.30
Počet EO	os.	15012	14934	14857	14779	14702	14624	14547	14471	14393	14316	14238	14161	14084
odp.vod likv.na ČOV	m3/den	2240.07	2228.59	2217.19	2205.49	2194.09	2182.54	2170.99	2159.66	2148.11	2136.56	2125.01	2113.46	2102.06
odp.vod likv.v septicích	m3/den	18.15	18.00	17.85	17.85	17.70	17.55	17.55	17.40	17.25	17.25	17.10	17.10	16.95
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT 2018 Dolní Podluží, 2018 Kateřina, 2018 Ladečka, 2018 Žofín, 2018 Chříbská, 2018 Jedlová, 2018 Lesné														
Množství odpadních vod	m3/den	140.96	140.44	140.46	140.39	140.47	140.43	140.45	140.42	140.46	140.40	140.39	140.41	286.58
BSK5	kg/d	55.83	55.86	56.03	56.19	56.37	56.54	56.71	56.86	57.05	57.20	57.36	57.54	121.30
NL	kg/d	50.99	50.99	51.15	51.26	51.43	51.48	51.70	51.87	52.09	52.20	52.31	52.47	45.60
CHSK	kg/d	101.97	101.97	102.30	102.52	102.85	102.96	103.40	103.73	104.17	104.39	104.61	104.94	91.19
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY														
Množství odpadních vod	m3/den	2.32	2.24	2.24	2.24	2.24	2.24	2.24	2.16	2.16	2.16	2.16	2.16	2.16
BSK5	kg/d	0.58	0.56	0.56	0.56	0.56	0.56	0.56	0.54	0.54	0.54	0.54	0.54	0.54
NL	kg/d	0.53	0.51	0.51	0.51	0.51	0.51	0.51	0.50	0.50	0.50	0.50	0.50	0.50
CHSK	kg/d	1.06	1.03	1.03	1.03	1.03	1.03	1.03	0.99	0.99	0.99	0.99	0.99	0.99
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	2381.03	2369.03	2357.65	2345.88	2334.56	2322.97	2311.44	2300.08	2288.57	2276.96	2265.40	2253.87	2388.64
BSK5	kg/d	949.30	944.75	940.36	935.84	931.46	927.01	922.56	918.19	913.76	909.29	904.83	900.39	959.59
NL	kg/d	869.99	865.76	861.74	857.56	853.55	849.37	845.35	841.39	837.38	833.25	829.13	825.06	814.00
CHSK	kg/d	1739.98	1731.51	1723.48	1715.12	1707.09	1698.73	1690.70	1682.78	1674.75	1666.50	1658.25	1650.11	1628.00
Počet EO	os.	15821	15745	15672	15597	15524	15450	15376	15303	15229	15154	15080	15006	15993
Typ ČOV		Aktivační čistírna					ČOV-denitr.+nitr.,s.chem.sr. P							
KONCENTRACE NA ODTOKU		stávající					navrhované řešení							
	-	BSK5	NL	CHSK	N-celk	P-celk	BSK5	NL	CHSK	N-celk	P-celk			
	mg/l	20.00	20.00	90.00	0.00	0.00	12.00	20.00	65.00	28.00	1.00			
Množství vyčištěn.odp.vod	m3/den	2399.18	2387.03	2375.50	2363.73	2352.26	2340.52	2328.99	2317.48	2305.82	2294.21	2282.50	2270.97	2405.59
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	905.31	919.92	915.64	911.25	906.98	902.64	898.33	894.06	889.74	885.42	881.07	876.76	934.32
NL	kg/d	826.30	822.27	818.45	814.51	810.69	806.71	802.92	799.16	795.34	791.45	787.52	783.68	769.90
CHSK	kg/d	1531.74	1583.52	1576.18	1568.59	1561.24	1553.59	1546.31	1539.07	1531.74	1524.25	1516.70	1509.31	1478.39
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	51.25	32.03	31.86	31.72	31.55	31.39	31.25	31.08	30.91	30.77	30.60	30.47	32.05
NL	kg/d	50.34	50.08	49.83	49.60	49.35	49.09	48.86	48.61	48.36	48.13	47.87	47.64	50.32
CHSK	kg/d	221.55	161.19	160.39	159.62	158.83	158.01	157.26	156.47	155.66	154.90	154.09	153.34	162.04
Produkce kalu	m3/r	69.64	69.31	68.99	68.66	68.34	68.01	67.68	67.36	67.04	66.71	66.38	66.06	70.40
Způsob likv.kalu		neurčeno												
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CZ042.3502.4215.0336.02 Studánka

č. a název lokality

	jedn.	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
CELKOVÁ PRODUKCE														
odpadních vod	m3/den	18.63	18.55	18.46	18.38	18.23	18.15	18.07	17.92	17.83	17.75	17.60	17.52	17.52
BSK5	kg/d	5.82	5.80	5.78	5.76	5.70	5.68	5.66	5.60	5.58	5.56	5.50	5.48	5.48
NL	kg/d	5.34	5.32	5.30	5.28	5.23	5.21	5.19	5.13	5.12	5.10	5.04	5.02	5.02
CHSK	kg/d	10.67	10.63	10.60	10.56	10.45	10.41	10.38	10.27	10.23	10.19	10.08	10.05	10.05
Počet EO	os.	97	96	96	96	95	94	94	93	93	92	91	91	91
odp.vod likv.na ČOV	m3/den	10.38	10.30	10.21	10.13	10.13	10.05	9.97	9.97	9.88	9.80	9.80	9.72	9.72
odp.vod likv.v septicích	m3/den	8.25	8.25	8.25	8.25	8.10	8.10	8.10	7.95	7.95	7.95	7.80	7.80	7.80
odp.vod likv.jiným způsobem	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
PŘÍSUN ODPADNÍCH VOD Z JINÝCH LOKALIT														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
ODVEDENÍ ODP.VOD NA JINÉ LOKALITY		2018 Varnsdorf												
Množství odpadních vod	m3/den	10.38	10.30	10.21	10.13	10.13	10.05	9.97	9.97	9.88	9.80	9.80	9.72	9.72
BSK5	kg/d	2.52	2.50	2.48	2.46	2.46	2.44	2.42	2.42	2.40	2.38	2.38	2.36	2.36
NL	kg/d	2.31	2.29	2.27	2.26	2.26	2.24	2.22	2.22	2.20	2.18	2.18	2.16	2.16
CHSK	kg/d	4.62	4.58	4.55	4.51	4.51	4.47	4.44	4.44	4.40	4.36	4.36	4.33	4.33
PŘÍTOK NA ČOV														
Množství odpadních vod	m3/den	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
BSK5	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
NL	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
CHSK	kg/d	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Počet EO	os.	0	0	0	0	0	0	0	0	0	0	0	0	0
Typ ČOV		žádná												
KONCENTRACE NA ODTOKU		stávající a navrhované řešení												
	-	BSK5NLCHSKN-celkP-celk												
	mg/l	0.000.000.000.000.00												
Množství vyčišť.odp.vod	m3/den	8.25	8.25	8.25	8.25	8.10	8.10	8.10	7.95	7.95	7.95	7.80	7.80	7.80
ODSTRANĚNÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	1.65	1.65	1.65	1.65	1.62	1.62	1.62	1.59	1.59	1.59	1.56	1.56	1.56
NL	kg/d	1.79	1.79	1.79	1.79	1.76	1.76	1.76	1.72	1.72	1.72	1.69	1.69	1.69
CHSK	kg/d	2.75	2.75	2.75	2.75	2.70	2.70	2.70	2.65	2.65	2.65	2.60	2.60	2.60
ZBYTKOVÉ ZNEČIŠTĚNÍ														
BSK5	kg/d	1.65	1.65	1.65	1.65	1.62	1.62	1.62	1.59	1.59	1.59	1.56	1.56	1.56
NL	kg/d	1.24	1.24	1.24	1.24	1.22	1.22	1.22	1.19	1.19	1.19	1.17	1.17	1.17
CHSK	kg/d	3.30	3.30	3.30	3.30	3.24	3.24	3.24	3.18	3.18	3.18	3.12	3.12	3.12
Produkce kalu	m3/r	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
Způsob likv.kalu														
Množství kalu po odvodnění	m3/r	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00